

621 DUNDAS STREET EAST
Dundas Street East at Haig Road, City of Belleville

FUNCTIONAL SERVICING REPORT



Prepared For: 2255718 Ontario Inc.

van MEER limited
83 North Park Street
Belleville, ON K8N 2Y6

January 24, 2024
Revised February 6, 2025

Table of Contents

1.0	INTRODUCTION	1
2.0	SITE DESCRIPTION	2
3.0	SITE SERVICING	3
3.1	Sanitary Sewer Design	3
3.1.1	Existing Services	3
3.1.2	Proposed Servicing	4
3.2	Watermain Distribution System	6
3.2.1	Existing Services	6
3.2.2	Proposed Servicing	6
3.3	Storm Sewer Design	7
3.3.1	Existing Services	7
3.3.2	Proposed Services	8
3.4	Storm Water Management	8
3.4.1	Stormwater Quantity Control	8
3.4.2	Stormwater Quality	8
3.5	Utility Servicing	13
3.5.1	Services	13
3.6	Roadwork	13
3.6.1	Existing	13
3.6.2	Proposed	13
4.0	EROSION AND SEDIMENT CONTROL DURING CONSTRUCTION	14
5.0	PHASING	14
6.0	SUMMARY	15

List of Figures

Figure 1: Key Plan..... 2
Figure 2: Sanitary Sewer Areas 5
Figure 3: Storm Treatment Areas 10

List of Tables

Table 1: Hydrant Table Maximum Day Demand and Fire Flow..... 7
Table 2: Summary of TSS Removal of Quality Treatment Units (ADS Treatment Train)..... 11
Table 3: Vegetated Spreader Berm Weir Flow..... 12

List of Appendices

Appendix A: **Conceptual Site Plan**

Proposed Site Plan (Cynthia Zahoruk Architect) Drawing A0.1
December 5, 2024 Issued for ZBA

Appendix B: **Sanitary Sewer Design**

Sanitary Sewer Design Sheets
Sanitary Sewer Design Drawing DUN/621-Sa1
Drainage Area Plan & Pipe Network
E-One Low Pressure Sewer System Using Environmental One Grinder Pumps

Appendix C: **Watermain Design**

Hydrant Flow Test – Flow at 20 psi Residual Calculation
Fire Hydrant Flow Test (614 Dundas St E.)
Domestic Water Demand
Fire Flow Requirements
Junction Table – Maximum Day Demand
Pipe Table – Maximum Day Demand
Hydrant Table – Watermain Model Calibration
Hydrant Table (H-4) Maximum Day Demand and Fire Flow
Hydrant Table (H-6) Maximum Day Demand and Fire Flow
Hydrant Table (H-8) Maximum Day Demand and Fire Flow
Hydrant Table (H-18) Maximum Day Demand and Fire Flow
Hydrant Table (H-19) Maximum Day Demand and Fire Flow
Watermain Design – Pipe Network Drawing DUN/621-W1

Appendix D: **Storm Sewer Design**

Storm Sewer Design Sheets – 5-Year Storm Event
Storm Sewer Design Sheets – 100-Year Storm Event
Storm Sewer Design Drawing DUN/621-St1
Drainage Area Plan & Pipe Network
Storm Sewer Design Drawing DUN/621-St2
Haig Road Sub-catchment
Ontario IDF Curve Look-up

Appendix E: **Stormwater Management – Design**

Storm Sewer Design Drawing DUN/621-St3
Pre-Development Overland Flow Route 100yr Storm Event
Storm Sewer Design Drawing DUN/621-St4
Post-Development Overland Flow Route 100yr Storm Event
Storm Sewer Design Sheets – Imperviousness and Tc / Flow Calculations
MOE Quality Event Calculations
Summary of TSS Removal of ADS Treatment Train Sizing
ADS Treatment Train Sizing – SQU 100
ADS Treatment Train Sizing – SQU 200
ADS Treatment Train Sizing – SQU 300
ADS Treatment Train Sizing – SQU 400
ADS Treatment Train Sizing – SQU 500
ADS Treatment Train Sizing – SQU 600
StormTech Isolator Row PLUS
StormTech Isolator Row PLUS O&M Manual

Appendix F: **Engineering Drawings**

<u>Drawing Name</u>	<u>Drawing Number</u>
Cover Page – Land Use	DUN/621-00
General Servicing Plan – Overall Development	DUN/621-01
General Servicing Plan – West Portion of Site	DUN/621-01A
General Servicing Plan – Middle Portion of Site	DUN/621-01B
General Servicing Plan – South Portion of Site	DUN/621-01C
General Servicing Plan – East Portion of Site	DUN/621-01D1

1.0 INTRODUCTION

This Functional Servicing Report is prepared in support of an application for Draft Plan of Subdivision and Rezoning approval for a residential subdivision in the City of Belleville.

The subject property is located at 621 Dundas Street East and the Haig Road intersection.

The property is located within Part of Lot 13, Concession 1, Part of the Road Allowance between the Broken Front Concession and Concession 1, Part of Lots 12 and 13, Broken Front Concession, Township of Thurlow, now in the City of Belleville, County of Hastings as illustrated in Figure 1- Key Plan.

The property has a frontage along Dundas Street East for access.

The site is bounded by the Bay of Quinte to the south; the Canadian Pacific Railway (CP Rail) and Dundas Street East to the north; commercial and residential developments to the east; and Parkland/Open Space to the west.

The site has approximately 16.17 hectares of developable land with a provincial significant wetland along the shore of the Bay of Quinte.

The property was the location of the former Bakelite operation and used by Union Carbide of Canada as a chemical manufacturing and resin (Bakelite) production facility. Environmental Site Assessments were completed as there were potential for impacts on the property as a result of historical activities on the property.

There is also a requirement to provide municipal water to four (4) existing residences located along the shore of the Bay of Quinte to the east of the subject property being described as Osprey Shores East Subdivision.

An Emergency Access Road is proposed to be developed through this adjacent residential and industrial lands to the east. The residential lands will have a potential residential development of 12 Townhouses, 6 Single Detached and 3 existing dwellings for a total of 21 units.

The residential development is proposed to consist of the following:

621 Dundas Street

Apartments	162 units
Stacked Townhouses	242 units
Townhouses	133 units
Single Detached	<u>42 units</u>
Subtotal	579 units

Osprey Shores East Subdivision

Townhouses	12 units
Single Detached	<u>9 units</u>
Subtotal	21 units
Total	600 units

The proposed Draft Plan of Subdivision indicated the type of land use to the respective Blocks.

With a potential of 600 various types of units, the anticipated population would be 1,526 persons.

A proposed Site Plan for the development prepared by Cynthia Zahoruk Architects has been included in Appendix A.



Figure 1 - Key Plan

2.0 SITE DESCRIPTION

The previous development and use of the property defined the various services and facilities on the property.

Access was a driveway from Dundas Street East at the northeast corner of the property.

The previous use of the property had its own water supply from the Bay of Quinte, there was no indication if a municipal water service and sanitary building sewer connection was provided to the property.

A 600mm diameter trunk sanitary sewer is located in an easement on the property located along the west and north boundaries of the property.

A 300mm diameter watermain is located on the south side of Dundas Street East and connects with the 300mm diameter watermain located on Haig Road.

The property falls gradually to the south and sheet drains into the existing wetland and Bay of Quinte. The rail spur lines and driveways previously on the property have created four separate sub-catchments as shown on the Pre-Development Overland Flow Route. Sub-catchment 100 along the east side of the property also receives the runoff conveyed from the storm sewer on Haig Road. The storm sewer on Haig Road outlets on the south side of Dundas Street East into a ditch along the east boundary of the property and discharges to the Bay of Quinte. Sub-catchment 200, located through the middle of the property was also defined by the existing rail spur bed and driveway to the pump house discharges to the Bay of Quinte via a short drainage ditch. Sub-catchment 300 drains westerly along a minor drainage course/ditch to the Bay of Quinte. Sub-catchment 400 also drains westerly onto adjacent lands into a pond before outlasting through a culvert under a former railway bed, which is now used as a multi-purpose trail and a trunk sanitary sewer to the wastewater treatment plan. There are two large sub-catchments north of Dundas Street East - the Bradgate and Farley Sub-catchments that outlet into ditches on the south side of the Canadian Pacific Railway (CP Rail) and also discharges into the existing pond to the west of the property and on the north side of the multi-purpose trail.

The property has approximately 180m of frontage along Dundas Street East. Dundas Street East, formerly Highway 2, is a divided highway with two lanes in each direction. For this section, the road drainage is addressed with roadside ditches. Haig Road also connects to Dundas Street East from the north at the northeast corner of the property. The CP Rail crosses at two locations - Dundas Street East approximately 140m to the west from the Haig Road intersection, and then crosses Haig Road approximately 50m north of Dundas Street East.

The City of Belleville has developed multi-purpose trails along the Bay of Quinte which loop back around to the west property boundary. These trails consist of a 3m wide asphalt trail and a 3m wide ski/snowshoe trail with light standards installed in between the trails.

Electrical services are available with Elexicon Energy.

Natural gas can be provided by Enbridge Gas.

Communications, telephone, television and internet is available from Bell Canada and Cogeco.

3.0 SITE SERVICING

3.1 Sanitary Sewer Design

3.1.1 Existing Services

An existing 600mm diameter trunk sanitary sewer at 0.16% grade is presently located on the easement along the west side of the property with the lowest point approximately 130m south of the northwest corner of the property. The depth of the sanitary sewer is only 2.1m at this location. Any development south of this point across the property would require to be serviced with a sewage lift station.

3.1.2 Proposed Servicing

A proposed 200mm diameter PVC sanitary sewer connected into the 600mm diameter trunk sanitary sewer will be able to service all the lots/units within the proposed development.

Extending the sanitary sewer easterly at a minimum 0.4% slope will raise the invert of the pipe too high to the proposed grading at the east limit of the property. Therefore, it is proposed that the lots/units at the east end of the centre driveway will also need to be connected to the sewage lift station with the lots/units along the southerly east-west leg of Road "A".

The sewage lift station would serve 51 single detached units and 86 townhouse units with a population of 386 persons. The lands that can be serviced directly with a gravity sewer to the Keegan Parkway Sanitary Trunk Sewer would serve 463 units with a population of 1,158 persons. The areas/units to be serviced with a sewage lift station are shown in green and the areas/units to be serviced with a gravity sanitary is shown in magenta, as shown in Fig 2.

Proposed throughout the development are 200mm dia. PVC sanitary sewer mains with a minimum full-flow pipe velocity of 0.6m/s.

Residential design parameters for the development include 350 L/cap/day, residential densities of 3 persons per lot, 2.5 persons per unit and extraneous flows of 0.28 L/sec/ha.

Design flow calculations and the accompanying Sanitary Drainage Area Plan are included in Appendix B.

The ultimate peak design flow for the sewage lift station would be 8.4 L/s.

The sewage lift station will consist of two submersible pumps, sized for capacity with one unit out-of-service.

The forcemain would be sized for a cleansing velocity between 0.6m/s and 1.2m/s with the maximum velocity limited to 3m/s. A 100mm dia. forcemain would maintain a velocity of 0.69m/s.

The pumping station design would be based on system-head calculation and curves using the appropriate Hasen-Williams factor "C" as follows:

- (a) Low sewage level in the wet well, C = 120;
- (b) Median sewage level over the normal operating range in the wet well, C = 130; and
- (c) Overflow sewage level in the wet well, C = 140.

Future sanitary sewer servicing for lands to the east of this development, the Osprey Shores East Subdivision including the existing four (4) dwellings, cannot be provided with a gravity sanitary sewer connection, but would require a sewage lift station or individual low pressure sewer system such as an E/One.

There should also be the option to service parts of the development area that require the Sewage Lift Station with a Low-Pressure Sewer System having E-One pumps installed in each unit. This option could be more beneficial for Block G on the Proposed Site Plan where habitable spaces in the dwellings will need to be above the high water level of the Bay of Quinte




Figure 2 Sanitary Sewer Areas

3.2 Watermain Distribution System

3.2.1 Existing Services

There is an existing 300mm dia. watermain on Dundas Street East and Haig Road that supplies domestic water and fire flow for this area. This existing watermain on Dundas Street East will be utilized to connect the proposed development into the system.

Fire Hydrant Flow Test data was available for an existing hydrant located at 665 Dundas Street East; copy provided in Appendix C. It was calculated that the available fire flow at 20psi residual pressure ranges from 470 to 500 L/s (28,200 to 30,000 L/min).

The flows and corresponding pressure from the Hydrant Flow Test would be used to calibrate the Bentley WaterCAD V8i Watermain Model.

3.2.2 Proposed Servicing

The proposed watermain will be PVC DR 18, class 150 and range in size from 200mm to 250mm diameter.

Two (2) 250mm dia. watermains will be installed on Road "A" from Dundas Street East southerly to the first Road "A" Tee intersection. This will provide a looped water supply to the development.

A 200mm dia. watermain would be installed on the P-Crescent of Road "A". A 200mm dia. watermain would also be installed to provide fire flows to Blocks "F" and "G".

A 200mm dia. watermain would also be installed along the driveway through the centre of Block "E" to supply water and fire protection for the 2-storey Townhouses. This watermain would either be installed in an easement for ownership and maintenance of the watermain and provide individual services to the units or be part of a Block development with a private service.

A 200mm dia. watermain is also included to supply municipal water to the four (4) existing dwellings along the bay shore immediately to the east of this development, being the proposed Osprey Shores East Subdivision.

It was determined that the Maximum Day Demand would be 11.1 L/s.

The Required Fire Flow, based on Water Supply for Public Fire Protection – A Guide to Recommended Practice in Canada – 2020 by Fire Underwriters Survey would range from 6,000 L/min to 15,000 L/min. It is expected the effective building area of the townhouse blocks will be reduced so that the fire flow requirements can be limited to 8,000 L/min when provisions for firewalls are incorporated between some of the units.

The Maximum Day Demand was incorporated into the Bentley WaterCAD V8i Watermain Model. The modelling was completed with only one (1) 250mm dia. watermain supplying water from Dundas Street East. Also, a possible watermain loop connection along the internal driveway through the centre of Block "E" was not considered for the model.

The Demands applied to the various junctions in the watermain distribution system are provided in the Junction Table. A Pipe Table is also provided indicating the various pipe lengths, diameters, Hazen-Williams C Coefficients, Flows, Velocities and Head loss.

Available Fire Flows were calculated during the Maximum Day Demand for various building types and sideyards. For example, the Available Fire Flow at Hydrant H-4 located at the westerly end of Block “F” was determined to be 8,040 L/min with a Residual pressure of 140kPa for 3-Storey Stacked Townhouses with lower level being at least 50% below grade allowing the Building Floor Area to be reduced accordingly.

The following table summarizes available fire flows at select hydrants in the system:

Fire Hydrant No.	Location	Location Description	Available Fire Flow (L/min.)	Residual Pressure
H-5	Block “F”	Westerly end of Block “F”	8,040	140 kPa
H-6	Block “A”	Road “A”, in front of apartment block	13,200	140 kPa
H-8	Block “F”	Road “A”, in front of townhouse block	10,980	140 kPa
H-18	Osprey Shores East	Existing dwellings east of development	10,080	141 kPa
H-19	Block “F”	South Driveway Servicing Detached Units	7,200	143 kPa

Table 1 – HYDRANT TABLE MAXIMUM DAY DEMAND AND FIRE FLOW

Supporting calculations and drawings for the above have been provided in Appendix C.

3.3 Storm Sewer Design

3.3.1 Existing Services

The property grades gradually to the south and sheet drains into the existing wetland and Bay of Quinte. The rail spur lines and driveways previously on the property have created four separate sub-catchments as shown on the Pre-Development Overland Flow Route, Drawing Dun/621-St3 included in Appendix D.

Sub-catchment 100 along the east side of the property also receives the runoff conveyed from the storm sewer on Haig Road. The storm sewer on Haig Road outlets at the south side of Dundas Street East into a ditch along the east boundary of the property and discharges to the Bay of Quinte.

Sub-catchment 200, located through the middle of the property is defined by the existing rail spur bed and roadway to the pumphouse and discharges to the Bay of Quinte via a short drainage ditch.

Sub-catchment 300 drains westerly along a minor drainage course/ditch to the Bay of Quinte.

Sub-catchment 400 also drains westerly onto adjacent lands then into a pond before outletting through a culvert under a former railway bed, which now uses as a multi-purpose trail and a trunk sanitary sewer to the wastewater treatment plan.

The two large sub-catchments north of Dundas Street East, the Bradgate and Farley Sub-catchments, outlet into ditches on the south side of the Canadian Pacific Railway (CP Rail) and discharges into the existing pond to the west of the property on the north side of the multi-purpose trail.

3.3.2 Proposed Services

Stormwater will be directed into the storm sewer system in two manners; the streets are proposed to be constructed to allow stormwater to convey along the road to the sewer system, and grassed swales located in the rear yards will direct the surface flows into catchbasins or ditch inlets and into the storm sewer system. The pipe network will be designed to accommodate 1:5 year storm events.

Rainfall Intensity Duration Frequency (IDF) data for Belleville is as follows:

5-Year Storm	$I = 26.4 t^{-0.677}$
100-Year Storm	$I = 45.6 t^{-0.699}$

The weighted average of the Runoff Coefficient for the overall development was determined to be 0.67 but was rounded to 0.70.

The sections of storm sewer connecting to an ADS Treatment Train Oil-Grit Separator (OGS) have a steep slope as the inlet to the OGS is constructed lower than the outlet resulting in this section of pipe being submerged. The length of pipe is short to minimize the amount of pipe submerged. The velocity of flow in the pipe would be comparable to the flow in the outlet pipe, that is, less than 6m/s.

Storms in excess in excess of a 1:5 year event would result in surcharging of the storm sewer system and conveyance during these major events will be overland along the roads and swales towards a stormwater relief system.

Detailed storm sewer calculations have been provided in Appendix D.

3.4 Storm Water Management

3.4.1 Stormwater Quantity Control

With the property being adjacent to the Bay of Quinte to discharge the stormwater runoff, no quantity controls measures will be required.

3.4.2 Stormwater Quality

Stormwater from the development will be collected and treated on site such that the final outflow will meet Ministry of Environment, Conservation Authority, Bay of Quinte Remedial Action Plan and City of Belleville approvals. Stormwater management facilities (SWM) will be constructed to provide end of pipe quality control where necessary.

Considering the Bay of Quinte Remedial Action Plan, Level 1 Enhance Quality Treatment as outlined in the Ministry of Environment, Conservation and Parks (MECP) Stormwater Management Planning and Design Manual (March 2003) will need to be provided. Treatment will be required to achieve the MECP Level 1 threshold of 80% Total Suspended Solids (TSS) removal of materials 50 microns in size.

Maintaining small sub-catchment areas will also permit the ADS StormTech Treatment Train to be utilized in series with vegetated spreader berms to treat stormwater in lieu of detention ponds as the end-of-pipe treatment method. Runoff would then sheet flow over the vegetated spreader berms and disperse into the existing wetland.

The ADS StormTech Treatment Train is both a NJCAT and ETV verified water quality treatment device achieving over 81% TSS removal per the ISO 14034:2016 ETV standard AND THE Canadian Environmental Technology Verification Process.

A stormwater quality treatment unit (Downstream Defender) will be in line with a StormTech Isolator Row Plus chamber. A splitter structure will be installed between the stormwater quality treatment unit and the isolator row to by-pass any excess flow exceeding the flow for a quality storm event. The release flow from the isolator row will be control to the quality storm event.

The patented FLAMP (Flared End Ramp) provides a smooth transition from pipe invert to fabric bottom. The FLAMP improves chamber function over time by distributing sediment and debris that would otherwise collect at the inlet. It also serves to improve the fluid and solid flow back into the inlet pipe during maintenance and cleaning,

The proprietary ADS Plus fabric maintains durability and sediment removal while allowing for higher water quality flow rates.

Based on the 5-year storm sewer design, six (6) separate sub-catchments ranging in area from 0.77 ha. to 3.58 ha. can be treated with oil grit separators, such as the DownStream Defender in series with an ADS StormTech Isolator Row Plus, to provide over 90% Total Net Annual Removal Efficiency of the Total Suspended Solids (TSS). The Downstream Defender can also be sized to provide a lower level of treatment during the 5-year storm event. The separate sub-catchments have been highlighted in colour in Figure 3.

The existing runoff from Haig Road would not require quality treatment by the Developer as a requirement for this development.

The overland flow will be directed along the streets to the midpoint of the southerly East-West section of Road "A" and sheet flow over Vegetated Spreader Berm 100 having a length of 170 m. The runoff during a 100-year storm event includes the area along Haig Road north of Dundas Street East. The overland flow to Vegetated Spreader Berm 100 will be the runoff during the 100-year storm event less the 5-year storm event from the Haig Road and 100 Series Sub-catchments, which will outlet from the storm sewer treated directly to the Bay of Quinte. The overland flow to Vegetated Spreader Berm 100 was calculated to be 2.36m³/s, having a depth of flow 0.28m and velocity of only 0.28m/s.

Runoff from Block "F" will be directed to the wetland and Bay of Quinte through a Downstream Quality Treatment Unit in series with the ADS Storm Tech Isolator Row Plus and sheet flow over Vegetated Spreader Berm 400 having a length of 40 m. The flow over this Vegetated Spreader Berm would be 0.14 m³/s and 0.30 m³/s during the 5-year and 100-year storm events respectively. Depth of flow would be 28 mm at a velocity of 0.28 m/s

Quality Treatment Unit in series with the ADS Storm Tech Isolator Row Plus and sheet flow over Vegetated Spreader Berm 400 having a length of 40 m. The flow over this Vegetated Spreader Berm would be $0.12 \text{ m}^3/\text{s}$ and $0.26 \text{ m}^3/\text{s}$ during the 5-year and 100-year storm events respectively. Depth of flow would be 25 mm at a velocity of 0.26 m/s




Figure 3 Storm Treatment Areas

Runoff from Block "G" will also be directed to the wetland and Bay of Quinte through a Downstream

The calculations for the overland flows are included in Appendix E.

It is also proposed all roof area will be directed towards the streets and driveways to be directed to the respecting Treatment Train. With Low Impact Development (LID), the swales and sheet flow will provide at least 50% reduction in TSS for any uncontrolled runoff into the wetlands. This is being considered with the percentage of Net Annual Removal Efficiency of the TSS reduction during the Quality Storm Event with the developed portions of the subdivision to calculate that 90.3% Total Net Annual Removal Efficiency will still be provided.

Considering the storm sewer design is based on the Rational Method, the runoff for the Storm Quality Event 25mm Intensity was determined based on equation 4.9 MECP Manual being:

$$i = 43C + 5.9$$

where, i = rainfall intensity (mm/h)
 C = runoff coefficient

The average runoff coefficient (C) was rounded to 0.70 for the overall development.

The Ministry of the Environment (MOE) Quality Event Calculations are included in Appendix E.

The Downstream Defender is being considered to provide removal of the larger suspended solids before discharging into the ADS StormTech Isolator Row Plus for more readily cleaning of the systems. This also allows for the Total Suspended Solids Removal being considered for both the quality storm event and the 5-year storm event when the storm sewer would be flowing at capacity into the quality treatment units.

The Water Quality Flow Rate Worksheets for Water Quality Flow and Peak Storm Flow are included in Appendix "E" for each of the Quality Treatment Train Units.

The following Table 2 summarizes the levels of TSS Removal for the Water Quality Flow and Peak Storm Flow for the respective Stormwater Quality Treatment Units:

SQU No	TREATMENT UNIT SPECIFICATIONS					QUALITY		5 YEAR		NET ANNUAL
	DIA	PEAK FLOW	SEDIMENT STORAGE	OIL STORAGE	AREA	FLOW	TSS Removal	FLOW	TSS Removal	
						L/s	%	L/s	%	
100	3000	708	19.45	3,975	3.58	167.9	80.2%	426.5	59.0%	91.8%
200	3000	708	19.45	3,975	3.35	177.1	80.5%	335.3	60.0%	92.1%
300	3000	708	19.45	3,975	3.35	188.0	80.4%	327.2	60.0%	92.0%
400	1800	227.0	6.71	818	1.24	69.4	80.5%	140.6	58.0%	91.5%
500	1800	227.0	6.71	818	1.24	65.8	80.1%	123.6	58.0%	91.2%
600	1800	227.0	6.71	818	0.77	49.9	80.8%	89.7	61.0%	92.3%
					13.53		80.38%			91.87%
					Uncontrolled Area (Rear Yards)	1.14	50.00%			50.00%
						14.67	78.02%			88.62%

Table 2 - SUMMARY of TSS REMOVAL of QUALITY TREATMENT UNITS (Downstream Defender)

During Peak Flow in the storm sewer, the Downstream Defender OGS are still able to provide from 60% to 82% TSS Removal Efficiency depending on the flows at the respective Quality Treatment Units.

To minimize impact on the wetlands, vegetated spreader berms will also be constructed downstream of the storm sewer outlets and the overland discharge locations. The MOE Manual recommends a depth of flow of 50-100mm through the vegetation during a 10mm storm. The depth of flow is calculated based on:

$$Q = a L H^{1.5}$$

where,
 Q = discharge
 a = coefficient
 L = length of crest of weir
 H = head

A coefficient of 1.67 was used to calculate the depth of flow (Head) for the respective discharge and length of crest of the weir and are summarized in the following Table 3:

Vegetated Spreader Berm Weir Flow					
MOE SWM Planning & Design Manual Equation 4.4: Weir Flow					
$Q = aLH^{1.5}$					
Spreader Berm Filter Strip Outlet Weir (Subcatchment Haig, 100, 200, 300)					
	5 _{yr}		100 _{yr}		
100-year Peak Flow			2.36		
Less 5-year Outlet to Bay (ST-A6 to Outlet)			0.72		
Less 5-year to SQU-100 to Outlet			0.33		
Q =	0.72	m ³ /s	1.32	m ³ /s	Flow Volume
a =	1.67		1.67		Broad Crested Weir Coefficient
L =	170	m	170	m	
H =	18.5	mm	27.8	mm	Flow Depth (max)
V =	0.23	m/s	0.28	m/s	Velocity
Spreader Berm Filter Strip Outlet Weir (Subcatchment 400)					
	5 _{yr}		100 _{yr}		
Q =	0.14	m ³ /s	0.30	m ³ /s	Flow Volume
a =	1.67		1.67		Broad Crested Weir Coefficient
L =	40	m	40	m	
H =	16.3	mm	27.5	mm	Flow Depth (max)
V =	0.21	m/s	0.28	m/s	Velocity
Spreader Berm Filter Strip Outlet Weir (Subcatchment 500)					
	5 _{yr}		100 _{yr}		
Q =	0.12	m ³ /s	0.26	m ³ /s	Flow Volume
a =	1.67		1.67		Broad Crested Weir Coefficient
L =	40	m	40	m	
H =	15.0	mm	24.5	mm	Flow Height (max)
V =	0.20	m/s	0.26	m/s	Velocity

Table 3 - VEGETATED SPREADER BERM WEIR FLOW (Berm Nos. 100/200/300, 400 and 500)

During a major storm event, the depth of flow over the Vegetated Spreader Berm will range from only 24mm to 38mm with velocities ranging from 0.26m/s to 0.33m/s; being less than 0.5m/s which is considered acceptable for flow in a grassed swale.

The SWM facilities in conjunction with lot level controls, sedimentation and erosion control practices during construction of the roads and services, as well as the dwellings, will provide protection to the Bay of Quinte. The placement of the Vegetated Spreader Berms has also been shown on the Engineering Drawings.

3.5 Utility Servicing

3.5.1 Services

Utility services to the area have been provided to date by Elexicon Energy, Bell Canada, Cogeco and Enbridge Gas for electricity, telephone/internet communication, cable television and natural gas respectively and will be available for this development.

The utilities will be installed underground in a combined utility trench. Electricity will be supplied from pad mount transformers. The electrical design is coordinated with Elexicon Energy.

3.6 Roadwork

3.6.1 Existing

Dundas Street East, formerly Highway 2, is a divided 4-lane street along the limited frontage of the parcel land. Haig Road also connects to Dundas Street East at this location while immediately to the west the CP Rail crosses Dundas Street East and to the immediate north crosses Haig Road.

There is also a driveway immediately to the east of the property that may cause traffic conflicts.

3.6.2 Proposed

This new development will have direct access to Dundas Street East, which is maintained on a year-round basis by the Municipality. It is proposed to provide a divided 5-lane entrance, 2 inbound and 3 outbound, for turning lane movements. The divided lane can also provide a second emergency access.

There will be a conflict with traffic movement between the proposed intersection and the existing driveway to the immediate east. This driveway should be able to be relocated further easterly. This property also has a major entrance further to the east for larger trucks to access.

A Traffic Impact Statement is being prepared by others to address the intersection requirements.

Osprey Shores East Subdivision is proposed to also be developed in the near future. Four of the existing dwellings on this property are to be serviced with a watermain as a condition for the site clean up. A maintenance road will be required to access the watermain. This maintenance road will be extended easterly and then north to connect to Dundas Street East through the maintained parking lot / driveway of the industrial building for a secondary emergency access road. This maintenance road would be built to the requirements for a fire route, being 6m wide and granular road base to support emergency vehicles similar to a municipal street.

With the secondary access road being available through the proposed Osprey Shores East Subdivision, limiting the number of units to be developed as the initial phase should not be required.

A 3m wide paved multi-use trail will also be provided to connect from the existing Bay Shore Trail to the west through the subdivision to Dundas Street East.

The street within the development will be constructed with a 20m road allowance to City of Belleville current standards for a 20m road cross-section. A sidewalk or the multi-purpose trail will be provided along one side of the street. The street will also be part of the street scape, designed using 20m wide cross sections.

4.0 EROSION AND SEDIMENT CONTROL DURING CONSTRUCTION

A number of erosion and sediment control measures can be established during construction. These measures are as follows:

- Minimize the area of soil exposed at any time;
- Apply soil cover as soon as possible after soil is disturbed;
- Sediment will be intercepted as close to the source as possible. Proposed sediment control would include covering catchbasins and ditch inlets with a filter cloth, installing straw bale check dams or crushed stone filter berms in drainage swales, and installing sediment control fences around disturbed areas of building lots before construction begins;
- Ensure the sediment control structures are properly constructed, inspected and maintained during its use;
- Control dust during construction with application of dust suppressants to gravel roads as required, and periodic sweeping of paved roads;
- If dewatering is required, pumped water to be discharged to sediment traps to reduce the amount of sediment sent to storm sewers and ditch inlets;
- Stockpiles expected to remain for a significant length of time should be temporarily covered with a vegetative mulch,
- Inspect and remove sediment from sumps in downstream catchbasins and ditch inlets within the development as required,
- Stormwater Treatment Train should be installed in the respective subcatchment that development and servicing is in progress for ant phase of the development,
- Stormwater Treatment Train to be monitored, maintained and cleaned out during construction of the services and development of the property

5.0 PHASING

Considering the size and scope of this development, it is anticipated the project will be phased.

The sanitary sewer connection is at the west side of the property, watermain connection and road connection will be at the northeast corner of the property, and storm sewer outlets will be along the south boundary.

A secondary emergency access will be required when development of the property would exceed 100 units.

The various types of dwelling units should assist with the absorption of the units in the market.

There would be two options to phase the development:


Option 1: Extend the sanitary sewer from the west property limit to Street A and construct the north leg of Street A to Dundas Street East intersection utilizing the proposed gravity sanitary sewer. Temporary turn-around would be provided at any temporary street terminations. If number of units exceeds 100, a temporary secondary emergency access would be constructed if the road network has not been completed.

Option 2: Extend the sanitary sewer from the west property limit to Street A, construct the south leg of Street A to Dundas Street East intersection, construct the sewage lift station with forcemain to the gravity sanitary sewer, and standby generator, Temporary turn-around would be provided at any temporary street terminations. If number of units exceeds 100, a temporary secondary emergency access would be constructed if the road network has not been completed.

6.0 SUMMARY

This design brief has been prepared to assist in municipal approvals for this development and is to be read in conjunction with Engineering Drawings prepared by van MEER limited included in Appendix F.

van **MEER** limited



Arnold H. Vandermeer, P.Eng.
Pres.



APPENDIX A


Conceptual Site Plan

Proposed Site Plan (Cynthia Zahoruk Architects) Drawing A0.1
December 5, 2024 – Issued for ZBA

PROPOSED LAND USE LEGEND

- CONDO APARTMENTS
- CONDO STACKED TOWNHOUSES (2 1/2 STOREY)
- CONDO TOWNHOUSES
- CONDO DETACHED SINGLE FAMILY HOUSES (2 STOREY)
- CONDO DETACHED SINGLE FAMILY HOUSES (2 STOREY)
- CONDO TOWNHOUSES
- CONDO STACKED TOWNHOUSES (2 1/2 STOREY)
- PARKLAND DEDICATION
- OPEN SPACE AREA
- FIRE ROUTE
- ZONING BY-LAW COMPLIANT PARKING SPACES

621 DUNDAS STREET - BELLEVILLE		December 5, 2024	
PROJECT DATA CHART		AREAS (Ha)	
DEVELOPABLE AREA (AS PER OCA DEVELOPMENT LIMIT)		2.04	
MUNICIPAL ROAD ALLOWANCE (EXCLUDING TRAIL)			
AREA OF EXISTING EASEMENT INCLUDED = 0.01 Ha		0.21	
ENVIRONMENTALLY PROTECTED LAND WITHIN DEVELOPABLE AREA		0.26	
AREA OF TRAIL WITHIN ROAD ALLOWANCE			
ENVIRONMENTALLY PROTECTED LAND WITHIN DEVELOPABLE AREA		0.04	
SEWAGE LIFT STATION AREA		0.75	
PARKLAND DEDICATION (INCLUDING 3.0 M TRAIL)		0.58	
VEGETATED SPREADER BERM			
BLOCKS	DESCRIPTION	REQUIRED	PROVIDED
APARTMENTS			
BLOCK - A	BLOCK AREA	N/A	1.94
	AREA OF EXISTING EASEMENT INCLUDED = 0.10 Ha		1.62
	UNITS		201
	VEHICULAR PARKING SPACES	0.75 space per dwelling unit for residents (122 Spaces) and 0.20 space per dwelling unit for visitors (33 Spaces)	
	BIKE SPACES	0.50 space per dwelling unit (81 Spaces)	93
STACKED TOWNHOUSES (2 1/2 STOREY)			
BLOCK - B	BLOCK AREA	N/A	0.97
	UNITS		80
	VEHICULAR PARKING SPACES	0.75 space per dwelling unit for residents (60 Spaces) and 0.20 space per dwelling unit for visitors (16 Spaces)	88
	BIKE SPACES	0.50 space per dwelling unit (40 Spaces)	40
TOWNHOUSES			
BLOCK - C	BLOCK AREA	N/A	1.00
	UNITS		37
	VEHICULAR PARKING SPACES (INCLUDING GARAGES)	1.0 space per dwelling unit for residents (37 Spaces)	74
DETACHED SINGLE FAMILY HOUSES (2 STOREY)			
BLOCK - D	BLOCK AREA	N/A	0.68
	UNITS		10
	PARKING SPACES (INCLUDING GARAGES)	1.0 space per dwelling unit (10 Spaces) and 1.0 space for every 5 units (2 Spaces)	30
TOWNHOUSES			
BLOCK - E	BLOCK AREA	N/A	2.18
	UNITS		81
	VEHICULAR PARKING SPACES (INCLUDING GARAGES)	1.0 space per dwelling unit for residents (81 Spaces)	162
	VISITORS PARKING SPACES	Not Required	14
STACKED TOWNHOUSES (2 1/2 STOREY)			
BLOCK - F	BLOCK AREA	N/A	2.75
	UNITS		162
	VEHICULAR PARKING SPACES	0.75 space per dwelling unit for residents (122 Spaces) and 0.20 space per dwelling unit for visitors (33 Spaces)	186
	BIKE SPACES	0.50 space per dwelling unit (81 Spaces)	81
DETACHED SINGLE FAMILY HOUSES (2 STOREY)			
BLOCK - G	BLOCK AREA	N/A	2.20
	UNITS		32
	VEHICULAR PARKING SPACES (INCLUDING GARAGES)	1.0 space per dwelling unit for residents (32 Spaces)	96
	VISITORS PARKING SPACES	Not Required	2
TOWNHOUSES			
BLOCK - H	BLOCK AREA	N/A	0.43
	UNITS		15
	VEHICULAR PARKING SPACES (INCLUDING GARAGES)	1.0 space per dwelling unit for residents (15 Spaces)	30
TOTAL NUMBER OF UNITS			579
TOTAL DEVELOPABLE AREA (A)			16.03
UNDEVELOPABLE AREA			
AREA OF WETLANDS			12.29
AREA OF WETLANDS			9.02
TOTAL UNDEVELOPABLE AREA (B)			21.31
TOTAL PROPERTY AREA (A+B)			37.34



APPENDIX B

Sanitary Sewer Design

Sanitary Sewer Design Sheet

Sanitary Sewer Design

Drainage Area Plan & Pipe Network

Drawing DUN/621-Sa1

SANITARY SEWER DESIGN SHEET

P = Persons / ha 3 Persons / Lot 2.5 Persons/Unit

q = 350 l/capita/day



I = 0.28 l/sec/ha

M = 1+(14/(4+P^{0.5}))

LOCATION		INDIVIDUAL			CUMULATIVE		Peaking Factor	Pop. Flow (l/s)	Peak Extraneous Flow (l/s)	Peak Design Flow (l/s) (% Cap)	Length (m)	Pipe Size (mm)	Type of Pipe	Grade %	PROPOSED SEWER		
		RESIDENTIAL		RESIDENTIAL		Capacity (L/s)									Velocity (m/s)		
STREET	AREA	FROM	TO	Units	Pop.	Areas	Units	Pop.	Areas	Design Flow (l/s)	Length (m)	Pipe Size (mm)	Type of Pipe	Grade %	Capacity (L/s)	Velocity (m/s)	
ROAD A North Leg Block A		SA 101	SA 102	129	323	1.94	129	323	1.94	5.85	116.3	200	DR 35	0.90%	31.1	0.99	
		SA 102	SA 103	114	285	1.84	243	608	3.78	10.73	115.0	200	DR 35	0.40%	20.7	0.66	
		SA 103	SA 104	6	15	0.19	249	623	3.97	11.01	53.1%	35.1	200	DR 35	0.40%	20.7	0.66
		SA 104	SA 105	18	45	0.28	18	45	0.28	0.87	2.6%	40.4	200	DR 35	0.40%	20.7	0.66
BLOCK F (East Portion)		SA-F1E	SA 104	31	78	0.88	298	745	5.13	1.44	13.14	200	DR 35	0.40%	20.7	0.66	
		SA 105	SA 106	12	30	0.88	310	775	6.01	1.68	13.83	200	DR 35	0.50%	23.2	0.74	
		SA 106	SA 107				310	775	6.01	1.68	13.83	200	DR 35	0.40%	20.7	0.66	
MIDDLE DRIVEWAY West Portion		SA 201	SA 202	17	43	0.54	17	43	0.54	0.90	81.8	200	DR35	0.70%	27.4	0.87	
		SA 202	SA 203	27	68	0.76	44	110	1.30	2.25	10.8%	120.0	200	DR35	0.40%	20.7	0.66
MIDDLE DRIVEWAY East Portion		SA 203	SA 107	44	110	1.30	44	110	1.30	2.25	10.8%	38.5	200	DR35	0.40%	20.7	0.66
		SA 301	SA 302	23	58	0.57	23	58	0.57	1.16	3.5%	84.7	200	DR35	1.00%	32.8	1.04
ROAD A		SA 301	SA 302	14	35	0.44	37	93	1.01	1.88	9.0%	66.1	200	DR35	0.40%	20.7	0.66
		SA 302	SA 303	37	92.5	1.01	37	92.5	1.01	1.88	4.8%	28.0	200	DR35	1.40%	38.8	1.24
STREET A (Osprey Shores East Subdivision) Low Flow Pressure Sewer		SA 303	SA 303	9	57	3.01	12	57	3.01	1.84	154.0	75	HDPE	Low Pressure Sewer			
		SA 303	SA 304	93	260	5.32	93	260	5.32	1.49	28.0%	37.7	200	DR35	0.40%	20.7	0.66
ROAD A South Portion		SA 304	SA 305	93	260	5.32	93	260	5.32	1.49	28.0%	13.3	200	DR35	0.40%	20.7	0.66
		SA 305	SA 306	4	10	0.19	97	270	5.51	6.02	29.0%	35.4	200	DR35	0.40%	20.7	0.66
BLOCK D		SA 401	SA 306	10	30	0.79	53	190	5.00	1.40	16.7%	48.4	200	DR35	0.70%	27.4	0.87
		SA 306	SA 307	13	33	0.45	66	222	5.46	5.24	25.3%	114.4	200	DR35	0.40%	20.7	0.66
		SA 307	SA 308	2	36	0.58	21	55	5.47	4.90	23.6%	114.4	200	DR35	0.40%	20.7	0.66
SOUTH DRIVEWAY (Bik G)		SA 501	SA 502	6	18	0.51	18	51	0.51	0.46	1.7%	46.7	200	DR35	0.70%	27.4	0.87
		SA 502	SA 503	3	9	0.20	27	71	0.71	0.68	3.3%	72.5	200	DR35	0.40%	20.7	0.66
		SA 503	SA 504	27	60	0.51	54	122	4.31	1.28	6.2%	97.9	200	DR35	0.40%	20.7	0.66
		SA 504	SA 405	8	24	0.52	78	1.73	4.27	1.84	8.8%	87.6	200	DR35	0.40%	20.7	0.66
ROAD A South Leg SEWAGE LIFT STATION		SA 505	SA 308	4	32	0.69	86	368	8.46	4.04	40.4%	76.0	200	DR35	0.40%	20.7	0.66
		SA 308	SL STN	51	86	8.46	86	368	8.46	8.39	40.4%	15.8	200	DR35	0.40%	20.7	0.66
SANITARY EASEMENT		SA 107	SA 108	21	53	0.26	461	1,306	16.03	4.49	64.3%	74.2	250	DR 35	0.40%	37.6	0.77
		SA 108	SA 109	24	60	0.22	485	1,366	16.25	4.55	66.6%	74.2	250	DR35	0.40%	37.6	0.77
BLOCK F (West Portion)		SA 601	SA 602	54	135	1.26	54	135	1.26	2.65	9.7%	105.3	200	DR35	0.70%	27.4	0.87
		SA 602	SA 109	9	23	0.10	63	158	1.35	3.05	13.1%	48.1	200	DR35	0.50%	23.2	0.74
SANITARY EASEMENT		SA 109	SA 110	51	123	0.54	51	123	0.54	4.93	73.4%	46.4	250	DR35	0.40%	37.6	0.77
		SA 110	SANITARY TRUNK SEWER							27.60	13.6%	600	CP	0.11%	203.6	0.51	
										Commercial Design Flows 1.05 l/ha sec (includes infiltration)							
										Extraneous Flows							
										27.60							
										4.8%							

REVISIONS	
Date	Description
DEC. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-02-09
JAN. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-17
JAN. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-04
DEC. 20/23	UNDERLAY 23-12-15 SITE LAYOUT FROM ARCHITECT
NOV. 8/23	REVISED SITE LAYOUT FROM ARCHITECT


SCALE: 1/8" = 1'-0"
 DESIGNER: A.H.V.
 DRAWN: S.D.S.
 DATE: 7/07
 COMPUTER: Dundas St (621) Belleville Property



E/ONE

EXTREME

S E R I E S



Low Pressure Sewer Systems Using Environment One Grinder Pumps

Contents

Introduction	3
Advantages of LPS Systems	3
Description and Operation	3
Pump Operation	4
Pump Type	4
Motor Selection	5
Power Outages	7
Power Consumption	7
LPS System Design	9
Information Required	9
Grinder Pump Station Size Selection	9
Grinder Pump Placement	10
Pipe Selection	10
System Layout	11
Zone Designations	12
Completion of Pipe Schedule and Zone Analysis	14
Review	17
References	22
Manufacturer Evaluation List	30

Introduction

E/One low pressure sewer (LPS) systems offer the designer new freedom in solving many problem situations that have defied reasonably economical solutions using the conventional approach.

Each LPS system design should be considered on the basis of its own unique circumstances. On such a basis, a sound choice between gravity and low pressure systems can be made.

General criteria aid the engineer in making a preliminary choice between several alternative systems: entirely low pressure, entirely gravity, entirely vacuum or a combination of systems. These criteria are presented and are intended to serve as a general guide. The final decision and design are the responsibility of the project consulting engineer, whose knowledge of local conditions, including construction costs, regulatory requirements and the client's particular needs, become vital to the preparation of the final designs and specifications.

Advantages of LPS Systems

LPS systems have low initial (front end) cost compared to gravity systems, which have nearly all the total investment allocated in the first stage. With the LPS system, grinder pump costs are incurred only as construction progresses. These costs will be deferred for many years in certain types of development programs.

An LPS system is not subject to infiltration from ground water or from surface storm water entering through leaking pipe joints and manholes. With zero infiltration, treatment plants need not be sized to handle the peak flow rates caused by infiltration. Treatment efficiencies can be more consistent, and treatment plant operating costs decrease.

An LPS system may become the critical factor in determining whether "marginal" land can be economically developed. Many attractive sites have been considered unsuitable for development because of the excessive costs typically associated with conventional sewer systems — sites with hilly terrain, land with negligible slope, high water tables, poor percolation characteristics, rock, seasonal occupancy or low population density.

Many communities are planning to convert from septic tanks to central sewage collection and treatment systems to minimize health hazards and/or environmental deterioration. The major reduction in cost and the simplicity of installation of an LPS system have strong appeal for such community improvement programs. Small-diameter pipe pressure mains can be laid along existing roadways with minimum disruption to streets, sidewalks, lawns, driveways and underground utilities. Surface restoration costs are similarly minimized. Sewage delivered to the treatment plant (because it contains no infiltration) is more uniform in "strength," the volume is smaller, and peaks are greatly reduced.

Description and Operation

Grinder pumps of approved design accomplish all pumping and sewage-grinding processes for small-diameter LPS systems.

The system consists of conventional drain, waste and vent (DWV) piping within the residence connected to the grinder pump inlet. The grinder pump may be installed above or below grade, indoors or outdoors. Depending on flow factors and model used, it may serve one or more resi-

dences, or several families in the case of apartment buildings.

Grinder pumps discharge a finely ground slurry into small-diameter pressure piping. In a completely pressurized collection system, all the piping downstream from the grinder pump (including laterals and mains) will normally be under low pressure. Pipe sizes will start at 1 1/4 inches for house connections (compared to 4 or 6 inches in gravity systems) and will be proportionally smaller than the equivalent gravity pipeline throughout the system. All pipes are arranged as zone networks without loops.

Depending on topography, size of the system and planned rate of buildout, appurtenances may include valve boxes, flushing arrangements, air release valves at significant high points, check valves and full-ported stops at the junction of each house connection with the low pressure sewer main.

Pump Operation

Low pressure sewer systems have become feasible with the availability of the Environment One grinder pump, the reliability of which has been proven in almost 40 years of service. The grinder pump station provides adequate holding capacity, reliable grinding and pressure transport of a fine slurry to an existing gravity sewer, pump station or directly to a wastewater treatment plant.

In operation, the grinder pump station will handle sewage and many items that should not, but often do, appear in domestic wastewater. For example, plastic, wood, rubber and light metal objects can be routinely handled without jamming the grinder or clogging the pump or piping system. The grinder pump will discharge this slurry at a maximum rate of 15 gpm or 11 gpm at a pressure of 40 psig. Transporting sewage several thousand feet to a discharge point at a higher elevation is possible as long as the sum of the static and friction losses does not exceed design limits of 185 feet TDH (80 psig).

The grinder pump is actuated when the depth of the sewage in the tank reaches a predetermined “turn-on” level, and pumping continues until the “turn off” level is reached. The pump’s running time is short, power consumption is low, and long pump life is ensured. The unit is protected against backflow from discharge lines by an integral check valve. Several grinder pump station models are available to satisfy various total and peak demand conditions.

Pump Type

The semi-positive displacement pump in the grinder pump station has a nearly vertical H-Q curve. This is the best type of pump for successful parallel operation of many pumps into a system of common low pressure mains. Since each pump will be located at a different point along common low pressure mains and at various elevations, each pump should operate in an efficient and predictable manner, whether one pump or numerous pumps are operating at a given moment; the pumps in such a system do not have a single fixed “operating point,” but must operate consistently over a wide range of heads that are continually, and often rapidly, changing.

The Environment One grinder pump has the capability of operating above the LPS system design criteria of 80 psig, or 185 feet (Figure 1). Based on the maximum daily number of pumps operating simultaneously (Table 3) versus the number of pumps connected to the system at the design pressure of 185 feet, the capability to operate significantly above the system’s design pressure is mandatory in order for the system to operate properly during the approximately bimonthly peaks when

the “absolute maximum” numbers of pumps are operating. This feature also ensures that pumping will continue under those conditions when higher-than-normal pressure occurs in the pipeline.

System designs with calculated heads approaching the upper limits of recommended heads should be reviewed by Environment One application specialists. Contact your local Environment One Regional Sales Office or authorized distributor for a no-cost, computerized review of your design.

Occasionally during “normal” operation, there will be short periods when higher-than-design pressures will be experienced. These can result from a variety of causes including solids buildup (obstructions) or air bubbles.

Deposits of solids or air accumulation will be purged from the line since the pump continues to produce an essentially constant flow, even though the cross section of the pipeline has temporarily been reduced. Higher velocities through the reduced cross section will provide the scouring action needed to correct such conditions as soon as they start to appear.

These higher-than-expected pressure conditions are transitory occurrences. The only requirement is that no damage be done to the pumping equipment, pipelines or appurtenances during these occasional short periods. Environment One grinder pumps are driven by motors rated for continuous operation at 104 F/40 C above ambient temperature. They can operate at 50 percent above rated pressure for at least 5 minutes without excessive temperature rise. Based on the Albany, New York, demonstration project⁴, for this type of overload to last even as long as one minute would be rare.

Motor Selection

A grinder pump station is an electromechanical system that depends on electric power for its operating, control and alarm functions. The design and selection of Environment One’s pump, motor, grinder and level-sensing controls were accomplished by optimizing the wastewater transport function of the unit within the necessary constraints for unattended, trouble-free operation in a residential environment.


A single grinder pump core is common to all models of Environment One grinder pumps (models DH071, DH151, DH152, DH272 and DH502). This central core contains all of the working and control elements of the unit and is powered by a 1 hp, 240v (or 120v), 1,725 rpm capacitor start, thermally protected induction motor. Each of these motor features was carefully considered in the design of the grinder pump station.

The pump should be considered as a residential appliance. For this reason, performing the grinding and pumping functions using no more than 1 hp to permit occasional use at 120v in older homes not wired for 240v is desirable. In order to achieve the high heads desired and provide constant flow at varying heads, the 1-hp motor is coupled to a pump of semi-positive displacement design (Figure 1).

At a rating of 1 hp and 1,725 rpm, the Environment One grinder pump develops more than 8.4 foot-pounds of torque. Motors used to drive centrifugal pumps are often rated at 2.0 hp at 3,450 rpm and may produce less torque. When handling residential sewage, grinding torque may be demanded during any portion of the starting or running cycle. When the pump stops (controlled by level) in the midst of grinding hard objects (e.g. tongue depressors, plastic items, etc.), it must, upon restarting, be able to provide sufficient torque to the grinder to overcome the resistance of any object remaining from the previous cycle.

Figure 1

Grinder Pump Performance Characteristics



Power Outages

Environment One grinder pump stations have adequate excess holding capacity to provide wastewater storage during most electrical power outages (Figure 2). This excess holding capacity is shown on curve A. Data from the Federal Power Commission on national electrical power outages is plotted as a cumulative distribution function (curve B). Note that only volume above the normal “turn-on” level was counted as available storage. The average flow of 1.54 gallons/hour/person is based on the actual measured flow over a one-year period at the Albany Demonstration Project⁴.

The local electrical power utility should be contacted to obtain a history on the power interruptions of the feeder(s) scheduled to serve the low pressure sewer site. From this data, curve B should be replotted to reflect local conditions. In those rare local areas where the frequency and/or the duration of outages exceed 7.5 hours, the use of Model DH151, with its greater holding capacity than that of the DH071, could be considered.

When power has been restored after a power outage, it is likely that nearly all the pumps in the system will try to operate simultaneously. Under these conditions, the dynamic head loss component of the total head will rise significantly. A number of pumps in the system would see a total back pressure high enough to cause the thermal overload protectors to automatically trip in a few minutes. Operation under conditions that could cause damage to the pumps or the system would be avoided. While these pumps are offline, other pumps in the system would be able to empty their tanks. After one to two minutes, the group that tripped off on thermal overload would cool and restart. The system back pressure would have been reduced and the group would be able to pump down normally. This process repeats itself automatically under the influence of each unit’s own thermal protector, reliably restoring the system to normal operation.

Power Consumption

Monthly power consumption of a residential grinder pump station is substantially less than that of other major appliances. The power consumption will vary based on the system operating parameters. The monthly cost can be approximated using the following equation and operating data:

$\frac{* \text{ Watts} \times \text{ GPD} \times \text{ Days/Mo}}{** \text{ GPM} \times 60 \text{ min} \times 1000} = \text{ kwhr per month}$	<table border="1"> <tr> <td>Discharge Pressure (PSI)</td> <td>0</td> <td>25</td> <td>60</td> <td>80</td> </tr> <tr> <td>* Watts</td> <td>690</td> <td>770</td> <td>1100</td> <td>1400</td> </tr> <tr> <td>** Flow (GPM)</td> <td>15</td> <td>12.4</td> <td>9.3</td> <td>7.7</td> </tr> </table>	Discharge Pressure (PSI)	0	25	60	80	* Watts	690	770	1100	1400	** Flow (GPM)	15	12.4	9.3	7.7
Discharge Pressure (PSI)	0	25	60	80												
* Watts	690	770	1100	1400												
** Flow (GPM)	15	12.4	9.3	7.7												


As an example of the calculation for a typical single-family home using 250 GPD, pumping at 25 psi is:

$$\frac{770 \text{ W} \times 250 \text{ GPD} \times 30 \text{ Days}}{12.4 \text{ GPM} \times 60 \text{ min} \times 1000} = 7.76 \text{ kwhr per month}$$

Then, multiply the kilowatt hours by the current cost of electricity and you will have an approximate monthly cost of running the unit.

Figure 2

Relationship of GP Storage Capacity to Power Outage Experience



LPS System Design

Once the initial analysis of a project has confirmed the feasibility of using the low-pressure approach, the completion of a preliminary system design is straightforward. This is primarily a result of two characteristics of E/One's semi-positive displacement pump: near-constant flow over the entire range of operating pressures and the ability of the pump to handle transient overpressures.

The balance of this section outlines a systematic approach to LPS system design, leading from pump model and pipe selection to a detailed zone and system analysis.

Information Required

The information that should be assembled prior to initiation of the LPS system design includes:

- Topography map
- Soil conditions
- Climatic conditions (frost depth, low temperature and duration)
- Water table
- Applicable codes
- Discharge location
- Lot layout (with structures shown, if available)
- Total number of lots
- Dwelling type(s)
- Use and flow factors (seasonal occupancy or year-round, appliances, water supply sources)
- Area development sequence and timetable

Grinder Pump Station Size Selection

Use this table to select grinder pump models for the types of occupancy to be served.

Model	Recommended Flow (gpd)	Adequate for Managing ...
DH071	up to 700	Flow from one average single-family home, and up to two average, single-family homes where codes allow and with consent of the factory.
DH151	up to 1,500	Flow from up to two average single-family homes, and up to six average, single-family homes where codes allow and with consent of the factory.
DH152	up to 3,000	Flow from up to four average single-family homes, and up to 12 average, single-family homes with consent of the factory.
DH272	up to 5,000	Flow from up to six average single-family homes, and up to 20 average, single-family homes with consent of the factory.
DH502	up to 6,000	Flow from up to nine average single-family homes,

and up to 24 average, single-family homes with consent of the factory.

Considerations include:

- Wetwell and discharge piping must be protected from freezing
- Model and basin size must be appropriate for incoming flows, including peak flows
- Appropriate alarm device must be used
- Suitable location

Daily flows above those recommended may exceed the tank's peak flow holding capacity and/or shorten the interval between pump overhauls. The company should be consulted if higher inflows are expected.

The final selection will have to be determined by the engineer on the basis of actual measurements or best estimates of the expected sewage flow.

Grinder Pump Placement

The most economical location for installation of the grinder pump station is in the basement of the building it will serve. However, due consideration must be given when choosing an indoor location. If there is a risk of damage to items located in the basement level, other provisions should be made during basement installation or an outdoor unit should be considered.

Considerations such as ownership of the pumps by a municipality or private organization and/or the need for outdoor accessibility frequently dictate outdoor, in-ground installations. For outdoor installations, all GP models are available with high density polyethylene (HDPE) integral accessways ranging in height up to 10 feet. By keeping the unit as close as possible to the building, the lengths of gravity sewer and wiring will be minimized, keeping installation costs lower while reducing the chances of infiltration in the gravity flow section.

AC power from the building being served should be used for the grinder pump. Separate power sources add to installation and O&M costs, decrease overall reliability and frequently represent an aesthetic issue.

When two dwellings are to be served by a single unit, the station is usually placed in a position requiring the shortest gravity drains from each home. With multi-family buildings, more than one grinder pump may be required.

Pipe Selection

The final determination of the type of pipe to be used is the responsibility of the consulting engineer. In addition, the requirements of local codes, soil, terrain, water and weather conditions that prevail will guide this decision.

Although pipe fabricated from any approved material may be used, most LPS systems have been built with PVC and HDPE pipe. Continuous coils of small-diameter, HDPE pipe can be installed with automatic trenching machines and horizontal drilling machines to sewer areas at lower cost.

Table 1 PIPE WATER CAPACITY <i>Gallons/100 feet of Pipe Length</i>			
Nominal Pipe Size (in.)	Sch 40 PVC	SDR 21 PVC	SDR 11 HDPE
1 1/4	7.8	9.2	7.4
1 1/2	10.6	12.1	9.9
2	17.4	18.8	15.4
2 1/2	23.9	27.6	—
3	38.4	40.9	33.5
4	66.1	67.5	55.3
5	103.7	103.1	84.5
6	150.0	146.0	119.9
8	260.0	249.0	203.2

Table 2 PVC PIPE COMPARISONS <i>Nominal Pipe Size = 2 in.</i>		
Parameter	Sch 40	SDR 21
Wall Thickness, in.	0.154	0.113
Inside Diameter, in.	2.067	2.149
50 gpm Friction Loss, ft/100 ft	4.16	3.44

Table 1 compares the water capacity of two types of PVC pipe commonly used: SDR-21 and Sch 40, and one type of HDPE, SDR-11. All three have adequate pressure ratings for low pressure sewer service.

Although both types of PVC pipes are suitable, the three parameters compared in Table 2 illustrate why SDR-21 is suggested as a good compromise between capacity, strength, friction loss characteristics and cost.

System Layout

A preliminary sketch of the entire pressure sewer system should be prepared (Figure 3). Pump models should be selected and their location (elevation) should be noted. The location and direction of flow of each lateral, zone and main, and the point of discharge should be shown.

The system should be designed to give the shortest runs and the fewest abrupt changes in direction. "Loops" in the system must be avoided as they lead to unpredictable and uneven distribution of flow.

Although not shown in Figure 3, the elevation of the shutoff valve of the lowest-lying pump in each zone should be recorded and used in the final determination of static head loss. Since Environment One grinder pumps are semi-positive displacement and relatively insensitive to changes in head, precisely surveyed profiles are unnecessary.

Air/vacuum valves, air release valves and combination air valves serve to prevent the concentration of air at high points within a system. This is accomplished by exhausting large quantities of air as the system is filled and also by releasing pockets of air as they accumulate while the system is in operation and under pressure. Air/vacuum valves and combination air valves also serve to prevent a potentially destructive vacuum from forming.

Air/vacuum valves should be installed at all system high points and significant changes in grade. Combination air valves should be installed at those high points where air pockets can form. Air release valves should be installed at intervals of 2,000 to 2,500 feet on all long horizontal runs that lack a clearly defined high point.

Air relief valves should be installed at the beginning of each downward leg in the system that exhibits a 30-foot or more drop. Trapped pockets of air in the system not only add static head, but also increase friction losses by reducing the cross sectional area available for flow. Air will accumulate in downhill runs preceded by an uphill run.

Long ascending or descending lines require air and vacuum or dual-function valves placed at approximately 2000-foot intervals. Long horizontal runs require dual function valves placed at approximately 2000-foot intervals.

Pressure air release valves allow air and/or gas to continuously and automatically released from a pressurized liquid system. If air or gas pockets collect at the high points in a pumped system, then those pressurized air pockets can begin to displace usable pipe cross section. As the cross section of the pipe artificially decreases, the pump sees this situation as increased resistance to its ability to force the liquid through the pipe.

Air relief valves at high points may be necessary, depending on total system head, flow velocity and the particular profile. The engineer should consult Environment One in cases where trapped air is considered a potential problem.

Cleanout and flushing stations should be incorporated into the pipe layout. In general, cleanouts should be installed at the terminal end of each main, every 1,000 to 1,500 feet on straight runs of pipe, and whenever two or more mains come together and feed into another main.

Zone Designations

The LPS system illustrated in Figure 3 contains 72 pumps and is divided into 14 individually numbered zones. Division into zones facilitates final selection of pipe sizes, which are appropriate in relation to the requirements that flow velocity in the system is adequate and that both static and dynamic head losses are within design criteria. Assignment of individual zones follows from the relationship between the accumulating total number of pumps in a system to the predicted number that will periodically operate simultaneously (Table 3).


Table 4 was initially developed after careful analysis of more than 58,000 pump events in a 307-day period during the Albany project (4). It was extended for larger systems by application of probability theory. The validity of this table has since been confirmed by actual operating experience with thousands of large and small LPS systems during a 34-year period.

Using Figure 3, the actual exercise of assigning zones is largely mechanical. The single pump farthest from the discharge point in any main or lateral constitutes a zone. This and downstream pumps along the main are accumulated until their aggregate number is sufficient to increase the number of pumps in simultaneous operations by one, i.e., until the predicted maximum flow increases by 11 gpm.

Figure 3 shows that zones 1, 2 and 3 end when the number of pumps connected total 3, 6 and 9, and the number of pumps in daily simultaneous operation are 2, 3 and 4, respectively.

Any place where two or more sections of main join, or where the outfall is reached, also determines the end of a zone. This design rule takes precedence over the procedure stated above, as seen in

Figure 3



zones 3, 4, 6, 8, 9, 11, 12, 13 and 14.

Completion of Pipe Schedule and Zone Analysis

The data recorded on the System Flow Diagram (Figure 3) is then transferred to Table 4.

Table 4 Column No.	Designation
1	Zone Number
2	Connects to Zone
3	Number of Pumps in Zone
4	Accumulated Pumps in Zone
11	Length of Main this Zone in Feet

Column 4 is completed by referring to Table 3, where the maximum number of pumps in simultaneous operation is given as a function of the number of pumps upstream from the end of the particular zone. The output of each zone will vary slightly with head requirements, but under typical conditions, the flow is approximately 11 gpm. Calculate the maximum anticipated flow for each zone by multiplying the number of simultaneous operations in Column 7 by 11 gpm and record the results in Column 8.

To complete columns 9, 10, 12 and 13, refer to Flow Velocity and Friction Head Loss table for the type of pipe selected — in this case, Table 5 for SDR-21. It will be seen that the engineer will frequently be presented with more than one option when selecting pipe size. Sometimes a compromise in pipe size will be required to meet present needs as well as planned future development. As a general rule, pipe sizes should be selected to minimize friction losses while keeping velocity near or above 2 feet per second.

For example, Zone 1 has a maximum of two pumps running (Column 7). Table 5 offers a choice of 1.25-inch, 1.5-inch or 2-inch pipe. 1.5-inch pipe is selected since flow velocity equals

**Table 3
MAXIMUM NUMBER OF GRINDER
PUMPCORES OPERATING DAILY**

Number of Grinder Pump Cores Connected	Maximum Daily Number of Grinder Pump Cores Operating Simultaneously
1	1
2-3	2
4-9	3
10-18	4
19-30	5
31-50	6
51-80	7
81-113	8
114-146	9
147-179	10
180-212	11
213-245	12
246-278	13
279-311	14
312-344	15
345-377	16
378-410	17
411-443	18
444-476	19
477-509	20
510-542	21
543-575	22
576-608	23
609-641	24
642-674	25
675-707	26
708-740	27
741-773	28
774-806	29
807-839	30
840-872	31
873-905	32
906-938	33
939-971	34
972-1,004	35

BY:		PRELIMINARY LOW-PRESSURE SEWER SYSTEM PIPE SCHEDULE AND ZONE ANALYSIS OF:														Environment/One CORPORATION		
PIPE: SDR 21 PVC		Illustrated Example Table 4														AE		
PREPARED FOR:		SHEET NO.														OF		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	
ZONE NO.	CONN. TO ZONE	NO. PUMPS IN ZONE	ACCUM. PUMPS IN ZONE	GAL/DAY PER CORE	MAX. FLOW PER CORE	MAX. SIM OPS	MAX. FLOW (gpm)	PIPE SIZE (in)	MAX. VELOCITY (FPS)	LENGTH OF MAIN THIS ZONE	FRIC LOSS FACTOR (ft/100 ft)	FRIC LOSS THIS ZONE	ACCUM. FRICTION LOSS (ft)	MAX. MAIN ELEV.	MIN. PUMP ELEV.	STATIC HEAD (ft)	TOTAL DYNAMIC HEAD (ft)	
1	2	3	3	200	11	2	22	1.5	3.04	205	2.15	4.41	73.41	40	10	30	103.41	
2	3	6	9	200	11	3	33	2.0	2.92	380	1.54	5.86	69.00	40	10	30	99.00	
3	5	9	18	200	11	4	44	2.0	3.89	630	2.63	16.56	63.14	40	5	35	98.14	
4	5	3	3	200	11	2	22	1.5	3.04	310	2.15	8.46	53.25	40	5	35	88.25	
5	6	9	30	200	11	5	55	3.0	2.24	800	0.60	4.83	46.58	40	5	35	81.58	
6	9	17	47	200	11	6	66	3.0	2.69	1,000	0.85	8.46	41.75	40	5	35	76.75	
7	8	3	3	200	11	2	22	1.5	3.04	175	2.15	3.77	49.56	40	5	35	84.56	
8	9	4	7	200	11	3	33	2.0	2.92	810	1.54	12.50	45.80	40	30	10	55.80	
9	12	6	60	200	11	7	77	3.0	3.14	520	1.12	5.85	33.30	40	10	30	63.30	
10	11	3	3	200	11	2	22	1.5	3.04	230	2.15	4.95	37.03	40	10	30	67.03	
11	12	3	6	200	11	3	33	2.0	2.92	300	1.54	4.63	32.08	40	10	30	62.08	
12	14	1	67	200	11	7	77	3.0	3.14	240	1.12	2.70	27.45	40	10	30	57.45	
13	14	3	3	200	11	2	22	1.5	3.04	985	2.15	21.19	45.94	40	5	35	80.94	
14	14	2	72	200	11	7	77	3.0	3.14	2,200	1.12	24.75	24.75	40	30	10	34.75	

3.04 ft/sec and friction loss equals 2.15 ft/100 ft. Since the zone is 205 feet in length (Column 11), the total friction loss (Column 13) is:

$$HF = (2.15 \text{ ft}/100 \text{ ft})(205 \text{ ft}) = 4.41 \text{ ft}$$

For Zone 14, with 72 upstream pumps, it is seen that a maximum of seven pumps can be running simultaneously. Table 5 provides options of:

$$3\text{-inch pipe: } V = 3.14 \text{ ft}/\text{sec}; HF = 1.12 \text{ ft}/100 \text{ ft}$$

or

$$4\text{-inch pipe: } V = 1.90 \text{ ft}/\text{sec}; HF = 0.33 \text{ ft}/100 \text{ ft}$$

The smaller-diameter 3-inch pipe is selected because of the increased velocities, especially with the TDH below 185 feet. A choice of 3-inch pipe would lead to a friction loss in this zone of:

$$HF = (1.12 \text{ ft}/100 \text{ ft}) (2200 \text{ ft}) = 24.75 \text{ ft}$$

Accumulated friction loss (Column 14) for each zone is next determined by adding the friction loss for each zone from the system outfall (Zone 14) to the zone in question. Thus, from Figure 3 it is seen that the accumulated friction loss for Zone 1 is:

Zone Number	Friction Loss (ft)
14	24.75
12	2.70
9	5.85
6	8.46
5	4.83
3	16.56
2	5.86
1	4.41

$$73.41 \text{ ft} = \text{Accumulated friction loss, Zone 1}$$

The same summation is completed for each zone.

To complete the hydraulic analysis, refer to the drawing contours and record in Column 15 the maximum line elevation between the point of discharge and the zone under consideration. In Column 16, record the elevation of the lowest pump in the zone. Subtract the values in Column 16 from

those in Column 15 and record only positive elevation differentials in Column 17. Add the values in Column 14 to those in Column 17 and record the total in Column 18 to show the maximum combination of friction and static head a pump will experience at any given point in the system.

Review

The accumulated data in Table 4 should finally be reviewed for conformity with the criteria of flow velocity greater than or equal to 2.0 ft/sec and total design head less than or equal to 185 feet. If the system pressure exceeds 92 feet, the number of cores operating will remain the same and the flow from each pump will be reduced from 11 gpm to 9 gpm.

Data should be reviewed to determine whether system improvements could result from construction modifications. As an example, deeper burial of pipe in one or two critical high-elevation zones might bring the entire system into compliance with design criteria. Environment One should be consulted in marginal cases and/or concerning:

- Odor control issues
- Frost protection issues
- Excessive static head conditions
- Excessive total dynamic head conditions
- Unusual applications

Table 5
SDR 21 PVC PIPE

Flow Velocity and Friction Head Loss vs Pumps in Simultaneous Operation (C = 150)

	1 1/4 in.		1 1/2 in.		2 in.		2 1/2 in.		3 in.		4 in.		5 in.		6 in.		8 in.		
N	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	N
1	1.99	1.15	1.52	0.60															1
2	3.99	4.16	3.04	2.15	1.95	0.73													2
3	5.98	8.82	4.56	4.56	2.92	1.54	1.99	0.61											3
4	7.97	15.02	6.08	7.77	3.89	2.63	2.66	1.04	1.79	0.40									4
5					4.87	3.97	3.32	1.57	2.24	0.60									5
6					5.84	5.57	3.99	2.20	2.69	0.85									6
7					6.81	7.41	4.65	2.93	3.14	1.12	1.90	0.33							7
8							5.32	3.75	3.59	1.44	2.17	0.42							8
9							5.98	4.66	4.04	1.79	2.44	0.53							9
10							6.64	5.67	4.49	2.18	2.71	0.64							10
11									4.93	2.60	2.98	0.76	1.95	0.27					11
12									5.38	3.05	3.25	0.90	2.13	0.32					12
13									5.83	3.54	3.52	1.04	2.31	0.37					13
14									6.28	4.06	3.80	1.19	2.48	0.43					14
15											4.07	1.36	2.66	0.48	1.88	0.21			15
16											4.34	1.53	2.84	0.55	2.00	0.23			16
17											4.61	1.71	3.02	0.61	2.13	0.26			17
18											4.88	1.90	3.19	0.68	2.25	0.29			18
19											5.15	2.10	3.37	0.75	2.38	0.32			19
20											5.42	2.31	3.55	0.82	2.50	0.35			20
21											5.69	2.53	3.73	0.90	2.63	0.39			21
22											5.96	2.76	3.90	0.98	2.75	0.42			22
23											6.24	2.99	4.08	1.07	2.88	0.46			23
24													4.26	1.16	3.00	0.49			24
25													4.44	1.25	3.13	0.53			25
26													4.61	1.34	3.25	0.57			26
27													4.79	1.44	3.38	0.61	1.99	0.17	27
28													4.97	1.54	3.50	0.66	2.07	0.18	28
29													5.15	1.64	3.63	0.70	2.14	0.19	29
30													5.32	1.75	3.75	0.75	2.21	0.21	30
31													5.50	1.86	3.88	0.79	2.29	0.22	31
32													5.68	1.97	4.01	0.84	2.36	0.23	32
33													5.86	2.08	4.13	0.89	2.44	0.25	33
34													6.03	2.20	4.26	0.94	2.51	0.26	34
35													6.21	2.32	4.38	0.99	2.58	0.28	35
36															4.51	1.05	2.66	0.29	36
37															4.63	1.10	2.73	0.30	37
38															4.76	1.16	2.81	0.32	38
39															4.88	1.21	2.88	0.34	39
40															5.01	1.27	2.95	0.35	40
41															5.13	1.33	3.03	0.37	41
42															5.26	1.39	3.10	0.39	42
43															5.38	1.45	3.17	0.40	43
44															5.51	1.52	3.25	0.42	44
45															5.63	1.58	3.32	0.44	45
46															5.76	1.65	3.40	0.46	46
47															5.88	1.72	3.47	0.47	47
48															6.01	1.78	3.54	0.49	48
49															6.13	1.85	3.62	0.51	49
50															6.26	1.92	3.69	0.53	50

Head Loss Calculations
From Modified Hazen - Williams Formula

$$H_F = .2083 \left[\left(\frac{100}{C} \right)^{1.852} \times \frac{q^{1.852}}{d^{4.8655}} \right]$$

$$V = .3208 \frac{q}{A}$$

$$A = \frac{d^2 \pi}{4} = \text{cross-sectional flow, sq. in.}$$

C = 150

q = flow in gallons per minute

d = I.D. of pipe in inches =

[average O.D. - (2 x min. wall thickness)]

N = Number of pumps operating at 11 gpm

V = Flow velocity in ft/sec

H_F = Friction head loss in ft/100 ft of pipe

Table 6
SCHEDULE 40 PVC PIPE

Flow Velocity and Friction Head Loss vs Pumps in Simultaneous Operation (C = 150)

	1 1/4 in.		1 1/2 in.		2 in.		2 1/2 in.		3 in.		4 in.		5 in.		6 in.		8 in.		
N	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	N
1	2.36	1.74	1.73	0.82	1.05	0.24													1
2	4.72	6.28	3.47	2.97	2.10	0.88	1.47	0.37											2
3	7.08	13.31	5.20	6.29	3.15	1.86	2.21	0.79											3
4			6.93	10.71	4.21	3.18	2.95	1.34	1.91	0.46									4
5					5.26	4.80	3.68	2.02	2.39	0.70									5
6					6.31	6.73	4.42	2.83	2.87	0.99									6
7							5.16	3.77	3.34	1.31	1.94	0.35							7
8							5.89	4.83	3.82	1.68	2.22	0.45							8
9							6.63	6.01	4.30	2.09	2.49	0.56							9
10									4.78	2.54	2.77	0.68							10
11									5.25	3.03	3.05	0.81	1.94	0.27					11
12									5.73	3.56	3.33	0.95	2.12	0.32					12
13									6.21	4.13	3.60	1.10	2.29	0.37					13
14											3.88	1.26	2.47	0.42					14
15											4.16	1.43	2.65	0.48					15
16											4.44	1.62	2.82	0.54	1.95	0.22			16
17											4.71	1.81	3.00	0.60	2.08	0.25			17
18											4.99	2.01	3.17	0.67	2.20	0.27			18
19											5.27	2.22	3.35	0.74	2.32	0.30			19
20											5.54	2.44	3.53	0.81	2.44	0.33			20
21											5.82	2.67	3.70	0.89	2.56	0.36			21
22											6.10	2.91	3.88	0.97	2.69	0.40			22
23													4.06	1.05	2.81	0.43			23
24													4.23	1.14	2.93	0.47			24
25													4.41	1.23	3.05	0.50			25
26													4.59	1.32	3.17	0.54			26
27													4.76	1.42	3.30	0.58			27
28													4.94	1.52	3.42	0.62	1.98	0.16	28
29													5.11	1.62	3.54	0.66	2.05	0.17	29
30													5.29	1.72	3.66	0.70	2.12	0.19	30
31													5.47	1.83	3.79	0.75	2.19	0.20	31
32													5.64	1.94	3.91	0.79	2.26	0.21	32
33													5.82	2.06	4.03	0.84	2.33	0.22	33
34													6.00	2.17	4.15	0.89	2.40	0.23	34
35													6.17	2.29	4.27	0.94	2.47	0.25	35
36															4.40	0.99	2.54	0.26	36
37															4.52	1.04	2.61	0.27	37
38															4.64	1.09	2.68	0.29	38
39															4.76	1.15	2.75	0.30	39
40															4.88	1.20	2.82	0.32	40
41															5.01	1.26	2.89	0.33	41
42															5.13	1.31	2.96	0.35	42
43															5.25	1.37	3.03	0.36	43
44															5.37	1.43	3.11	0.38	44
45															5.49	1.49	3.18	0.39	45
46															5.62	1.56	3.25	0.41	46
47															5.74	1.62	3.32	0.43	47
48															5.86	1.68	3.39	0.44	48
49															5.98	1.75	3.46	0.46	49
50															6.11	1.81	3.53	0.48	50

**Head Loss Calculations
From Modified Hazen - Williams Formula**

$$H_F = .2083 \left[\left(\frac{100}{C} \right)^{1.852} \times \frac{q^{1.852}}{d^{4.8655}} \right]$$

$$V = .3208 \frac{q}{A}$$

$$A = \frac{d^2 \pi}{4} = \text{cross-sectional flow, sq. in.}$$

C = 150

q = flow in gallons per minute

d = I.D. of pipe in inches =

[average O.D. - (2 x min. wall thickness)]

N = Number of pumps operating at 11 gpm

V = Flow velocity in ft/sec

H_F = Friction head loss in ft/100 ft of pipe

Table 7
SDR 11 HDPE PIPE

Flow Velocity and Friction Head Loss vs Pumps in Simultaneous Operation (C = 155)

	1 1/4 in.		1 1/2 in.		2 in.		3 in.		4 in.		5 in.		6 in.		8 in.		
N	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	V	H_F	N
1	2.47	1.84	1.86	0.92													1
2	4.95	6.63	3.72	3.32	2.38	1.12											2
3	7.42	14.04	5.58	7.03	3.57	2.37	1.64	0.36									3
4			7.44	11.98	4.76	4.04	2.19	0.61									4
5					5.95	6.11	2.74	0.92									5
6					7.14	8.56	3.29	1.30	1.99	0.38							6
7							3.83	1.72	2.32	0.51							7
8							4.38	2.21	2.65	0.65							8
9							4.93	2.75	2.98	0.81	1.95	0.29					9
10							5.48	3.34	3.31	0.98	2.17	0.35					10
11							6.03	3.98	3.65	1.17	2.39	0.42					11
12									3.98	1.38	2.60	0.49					12
13									4.31	1.60	2.82	0.57	1.99	0.24			13
14									4.64	1.83	3.04	0.65	2.14	0.28			14
15									4.97	2.08	3.25	0.74	2.29	0.32			15
16									5.30	2.35	3.47	0.84	2.45	0.36			16
17									5.63	2.63	3.69	0.94	2.60	0.40			17
18									5.97	2.92	3.90	1.04	2.75	0.44			18
19									6.30	3.23	4.12	1.15	2.90	0.49			19
20											4.34	1.27	3.06	0.54			20
21											4.56	1.39	3.21	0.59			21
22											4.77	1.51	3.36	0.64	1.98	0.18	22
23											4.99	1.64	3.52	0.70	2.08	0.19	23
24											5.21	1.77	3.67	0.76	2.17	0.21	24
25											5.42	1.91	3.82	0.82	2.26	0.23	25
26											5.64	2.06	3.98	0.88	2.35	0.24	26
27											5.86	2.21	4.13	0.94	2.44	0.26	27
28											6.07	2.36	4.28	1.01	2.53	0.28	28
29													4.43	1.08	2.62	0.30	29
30													4.59	1.15	2.71	0.32	30
31													4.74	1.22	2.80	0.34	31
32													4.89	1.29	2.89	0.36	32
33													5.05	1.37	2.98	0.38	33
34													5.20	1.44	3.07	0.40	34
35													5.35	1.52	3.16	0.42	35
36													5.50	1.60	3.25	0.44	36
37													5.66	1.69	3.34	0.47	37
38													5.81	1.77	3.43	0.49	38
39													5.96	1.86	3.52	0.52	39
40													6.12	1.95	3.61	0.54	40
41															3.70	0.57	41
42															3.79	0.59	42
43															3.88	0.62	43
44															3.97	0.65	44
45															4.06	0.67	45
46															4.15	0.70	46
47															4.24	0.73	47
48															4.33	0.76	48
49															4.42	0.79	49
50															4.51	0.82	50

Head Loss Calculations
From Modified Hazen - Williams Formula

$$H_F = .2083 \left[\left(\frac{100}{C} \right)^{1.852} \times \frac{q^{1.852}}{d^{4.8655}} \right]$$

$$V = .3208 \frac{q}{A}$$

$$A = \frac{d^2 \pi}{4} = \text{cross-sectional flow, sq. in.}$$

C = 150

q = flow in gallons per minute

d = I.D. of pipe in inches =
[average O.D. - (2 x min. wall thickness)]

N = Number of pumps operating at 11 gpm


V = Flow velocity in ft/sec

H_F = Friction head loss in ft/100 ft of pipe


References


1. Carcich, I., Hetling, L.J., and Farrell, R.P. "A Pressure Sewer System Demonstration," EPA-R2-72-091, Office of Research and Monitoring, U.S. Environmental Protection Agency, Washington, D.C., November 1972.
2. Farrell, R.P. "Long-Term Observation of Wastewater Observation Stations," TM-2, American Society of Civil Engineers, April 1968.
3. "Handbook of PVC Pipe: Design and Construction," Uni-Bell PVC Pipe Association, Dallas, Texas, Second Edition, 1982.
4. Hicks, T.G., and Edwards, T. W. "Pump Application Engineering," McGraw Hill, New York, 1971.
5. Stepanoff, A.J. "Centrifugal and Axial Flow Pumps," John Wiley and Sons, New York, 1948.
6. Tucker, L.S. "Hydraulics of a Pressurized Sewerage System and Use of Centrifugal Pumps," TM-6, American Society of Civil Engineers, 1967.
7. Tucker, L.S. "Sewage Flow Variations in Individual Homes," TM-2, American Society of Civil Engineers, February 1967.
8. Waller, D.H. "Peak Flow of Sewage from Individual Homes," TM-9, American Society of Civil Engineers, January 1968.

TYPICAL INDOOR INSTALLATION




TYPICAL OUTDOOR INSTALLATION






PLAN VIEW





TYPICAL FLUSHING CONNECTION ON LPSS MAIN

TYPICAL LATERAL INSTALLATION




TYPICAL DROP CONNECTION LPSS IN EXISTING MANHOLE





e one	
ENVIRONMENT ONE CORPORATION	
REDUNDANT CHECK VALVE	
ENG MODEL: US Assembly K7	SERVICE #:
DRAWING NUMBER	SH 1 OF 1



SECTION A-A
SCALE 5 : 8

e one	
ENVIRONMENT ONE CORPORATION	
ANTI-SIPHON CHECK VALVE	
SERVICE #:	
DRAWING NUMBER	SH 1 OF 1

Manufacturer Evaluation List

General Requirements for Low Pressure Sewer Systems

Service and Maintenance Check List	<ul style="list-style-type: none">• Local fast-response service and maintenance organization has been designated• Manufacturers of all equipment specified for the system have supplied all installation details• Warranties for all equipment specified for the system have been evaluated• Fast replacement parts availability for all equipment in the system has been ensured by each equipment manufacturer• User instructions have been supplied to homeowners
Grinder Pump	<ul style="list-style-type: none">• Designated for the specific purpose of grinding and pumping domestic wastewater• Suitable for parallel operation in a system containing thousands of pumps connected to a common discharge line• Has a history of reliable operation• Compatible with existing power sources and provides economical operation• Simple to service and troubleshoot, easily accessible for removal of grinder pump core; designed with simple wiring and controls; easily disassembled and reassembled• Warranty covering parts and labor for a reasonable length of time• Supported by a thoroughly detailed installation manual, service manual and facilities for service training
Certifications	<ul style="list-style-type: none">• Canadian Standards Association• Underwriters Laboratories, Inc.• National Sanitation Foundation
Required Features	<ul style="list-style-type: none">• Non-clogging pump• Non-jamming grinder• Anti-siphon valve integral with grinder pump• All valves of non-clogging design: integral check valve, anti-siphon valve and redundant check valve• High-level warning alarm
Motor	<ul style="list-style-type: none">• Low rpm (1,725)• Overload protection, built-in, automatic reset• High torque, low starting current
Tank	<ul style="list-style-type: none">• Self scouring• Completely sealed• Non-corroding material
Level Sensing Control	<ul style="list-style-type: none">• Non-fouling type• No moving parts in contact with sewage
Motor Controls	<ul style="list-style-type: none">• Completely protected• Simple to service or replace• UL-listed alarm panel



A Precision Castparts Company

Environment One Corporation
2773 Balltown Road
Niskayuna, New York USA 12309-1090

Voice: (01) 518.346.6161
Fax: 518.346.6188

www.eone.com

LM000353 Rev. A
060208

APPENDIX C

Watermain Design

Hydrant Flow Test – Flow at 20 psi Residual Calculation

Fire Hydrant Flow Test (614 Dundas St E.)

Domestic Water Demand

Fire Flow Requirements

Junction Table – Maximum Day Demand

Pipe Table – Maximum Day Demand

Hydrant Table – Watermain Model Calibration

Hydrant Table (H-5) Maximum Day Demand and Fire Flow

Hydrant Table (H-6) Maximum Day Demand and Fire Flow

Hydrant Table (H-14) Maximum Day Demand and Fire Flow

Hydrant Table (H-18) Maximum Day Demand and Fire Flow

Hydrant Table (H-19) Maximum Day Demand and Fire Flow


Watermain Design – Pipe Network

Drawing DUN/621-W1

HYDRANT FLOW TEST - Flow at 20 psi Residual Calculation

Hydrant 665 South side of Dundas Street, Belleville

Size of Watermain 300 mm		Comments:									
<input type="checkbox"/> Dead End <input checked="" type="checkbox"/> Two Way <input type="checkbox"/> Loop											
Flow Hydrant Location:		South Side of Dundas Street East, No 665									
Residual Hydrant Location:		North Side of Dundas Street East, No 614									
Static Pressure:		71 psi		Date: November 19, 2019		Time:					
Test No.	No. of Outlets	Orifice		Pitot Reading (psi)	Equivalent Flow gpm (U.S.)	Total Flow gpm (U.S.)	Residual Pressure (psi)	Comments			
		Size (in.)	Coef								
1	1	2.287	0.9	60	1087.7	1087.7	69				
2	2	2.287	0.9	45	942.0	1883.9	66				
3											
4											




Routing
 White - 1. Op. Mgr. 2. Draft. 3. FF bk.
 Pink - File 842
 Canary - Originator



Belleville Utilities Commission
 459 SIDNEY STREET
 P.O. BOX 939
 BELLEVILLE, ONT., K8N 5B6
 (613) 968-3651

Date: Nov. 27/19
 Time: _____
 Performed by JM, CM
 File: 842

FIRE HYDRANT FLOW TEST



Provide Four Pressure Readings:

	OUTLETS	one - 1"				one - 1 1/8"		one - 1 1/2"		one - 2"		two - 2 1/2"	
Step One - Adjacent Hydrant										<u>71</u>	<u>71</u>	psi (static)	
Step Two - Pitot Hydrant										<u>60</u>	<u>45</u>	psi (flow)	
Step Three - Adjacent Hydrant										<u>69</u>	<u>66</u>	psi (residual)	
Step Four - Adjacent Hydrant										<u>71</u>	<u>71</u>	psi (static check)	

low with 20 psi residual at adjacent hydrant
 = measured flow $\left(\frac{\text{available drop}}{\text{test drop}} \right)^{.54}$


Available drop is static less 20
 Test drop is static less residual

Information below can be obtained at a later date from records at Water Purification Plant.


	PUMP	MIGPD		
Water Purification Plant:	No. 1 Electric	4	<input type="checkbox"/> Off	<input type="checkbox"/> On
	No. 2 Electric	4	<input type="checkbox"/> Off	<input type="checkbox"/> On
	No. 3 Electric	4	<input type="checkbox"/> Off	<input type="checkbox"/> On
	No. 4 Electric	4	<input type="checkbox"/> Off	<input type="checkbox"/> On
	Diesel	3.5	<input type="checkbox"/> Off	<input type="checkbox"/> On
	Diesel	3.5	<input type="checkbox"/> Off	<input type="checkbox"/> On

Elevated Tank Water Level _____ Ft.

	PUMP	MIGPD		
Pine Street Reservoir:	No. 1 Electric	1	<input type="checkbox"/> Off	<input type="checkbox"/> On
	No. 2 Electric	2	<input type="checkbox"/> Off	<input type="checkbox"/> On
	Diesel	5	<input type="checkbox"/> Off	<input type="checkbox"/> On



Purification Plant Pressure _____ psi.



DOMESTIC WATER DEMAND

621 DUNDAS STREET EAST at Haig Road, Belleville

Includes Osprey Shores West Subdivision

Number of Single Detached Lots		51	
Number of Persons / Lot		3	
Number of Townhouses		145	
Number of Persons / Unit		2.5	
Number of Stacked Townhouses		242	
Number of Persons / Unit		2.5	
Number of Apartment Units		162	
Number of Persons / Unit		2.5	
Total Number of Units		600	
Total Number of Persons		1525.5	
Average Consumption	350 l/cap.day	6.180	l/s

Peaking Factors (Per Table 3-1)

Local Minimum Hour	0.45	2.781	l/s	1,001 - 2,000 Population
Local Maximum Day	2.50	15.449	l/s	
Local Peak Hour	3.75	23.174	l/s	
Minimum Hour	0.65	4.017	l/s	25,001 - 50,000 Population
Maximum Day	1.8	11.123	l/s	
Peak Hour	2.7	16.685	l/s	

Extended Period Simulation Demand Pattern - Residential

TIME		MULTIPLIER	FLOW	DURATION
FROM	TO			
12:00 am	1:00 am	0.45	2.781 l/s	1
1:00 am	2:00 am	0.45	2.781 l/s	1
2:00 am	3:00 am	0.45	2.781 l/s	1
3:00 am	4:00 am	0.45	2.781 l/s	1
4:00 am	5:00 am	0.6	3.708 l/s	1
5:00 am	6:00 am	0.6	3.708 l/s	1
6:00 am	7:00 am	2.5	15.449 l/s	1
7:00 am	8:00 am	1	6.180 l/s	1
8:00 am	9:00 am	1	6.180 l/s	1
9:00 am	10:00 am	0.45	2.781 l/s	1
10:00 am	11:00 am	0.45	2.781 l/s	1
11:00 am	12:00 pm	1	6.180 l/s	1
12:00 pm	1:00 pm	1	6.180 l/s	1
1:00 pm	2:00 pm	1	6.180 l/s	1
2:00 pm	3:00 pm	1	6.180 l/s	1
3:00 pm	4:00 pm	0.6	3.708 l/s	1
4:00 pm	5:00 pm	2.5	15.449 l/s	1
5:00 pm	6:00 pm	3.75	23.174 l/s	1
6:00 pm	7:00 pm	1	6.180 l/s	1
7:00 pm	8:00 pm	1	6.180 l/s	1
8:00 pm	9:00 pm	1	6.180 l/s	1
9:00 pm	10:00 pm	0.65	4.017 l/s	1
10:00 pm	11:00 pm	0.65	4.017 l/s	1
11:00 pm	12:00 am	0.45	2.781 l/s	1

FIRE FLOW REQUIRED

1-Storey Detached

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Detached Dwelling One Storey				
		240 m ²	2,600 ft ²			
Building Floor Area (A) =						
Type V Wood Frame Construction		C = 1.5				
		F = 220 C A ^{1/2}				
		= 5,112 L/min				
		Rounded to	5,000 L/min			
Occupancy Consideration						
Limited Combustible Content	Table 3		-15%			
			-750 L/min			
			4,250 L/min			
Automatic Sprinkler Consideration	No Sprinklers		0%			
			0 L/min			
Exposure Adjustment Charges (Table 6)						
		BLOCK "E"				
		Front	Side 1	Side 2	Rear	
Distance to Exposure (m)		30	23	2.4	10	
Height of Exposed Building (Stories)		1	1	1	1	
Length of Exposed Building Facing Wall (m)		9	15	15	9	
Length-Height Factor		9	15	15	9	
Exposure Adjustment Charge		0%	0%	20%	15%	35%
						1,750 L/min
						RFF = 6,000 L/min
						Rounded to 6,000 L/min
Required Duration of Fire Flow	Table 1					2.00 hours
Standard Hydrant Distribution	Table 2					
		Average Area per Hydrant				14,000 m ²
		Maximum Recommended Spacing				150 m
		Maximum Distance from Any Point on Street or Road Frontage to a Hydrant				75 m
		Minimum Number of Hydrants (total available)				1
		Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads				120 m
		Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads				60 m

FIRE FLOW REQUIRED

2-Storey Detached

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Detached Dwelling	
		One Storey	
		300 m ²	3,250 ft ²
Building Floor Area (A) =			
Type V Wood Frame Construction		C = 1.5	
		F = 220 C A ^{1/2}	
		= 5,716 L/min	
		Rounded to	6,000 L/min
Occupancy Consideration			
Limited Combustible Content	Table 3	-15%	
		-900 L/min	
		5,100 L/min	
Automatic Sprinkler Consideration	No Sprinklers	0%	
		0 L/min	
Exposure Adjustment Charges (Table 6)			
	BLOCK "E"		
	Front Side 1 Side 2 Rear		
Distance to Exposure (m)	20 3 3 >30m		
Height of Exposed Building (Stories)	2 2 2 2		
Length of Exposed Building Facing Wall (m)	9 15 15 9		
Length-Height Factor	18 30 30 18		
Exposure Adjustment Charge	10% 21% 21% 9%	61%	
		3,660 L/min	
		RFF =	8,760 L/min
		Rounded to	9,000 L/min
Required Duration of Fire Flow	Table 1		2.00 hours
Standard Hydrant Distribution	Table 2		
	Average Area per Hydrant	12,500 m ²	
	Maximum Recommended Spacing	135 m	
	Maximum Distance from Any Point on Street or Road Frontage to a Hydrant	70 m	
	Minimum Number of Hydrants (total available)	3	
	Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads	105 m	
	Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads	55 m	

FIRE FLOW REQUIRED

2-Storey Detached

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Detached Dwelling	
		One Storey	
		300 m ²	3,250 ft ²
Building Floor Area (A) =			
Type V Wood Frame Construction		C = 1.5	
		F = 220 C A ^{1/2}	
		= 5,716 L/min	
		Rounded to	6,000 L/min
Occupancy Consideration			
Limited Combustible Content	Table 3	-15%	
		-900 L/min	
		5,100 L/min	
Automatic Sprinkler Consideration	No Sprinklers	0%	
		0 L/min	
Exposure Adjustment Charges (Table 6)			
		BLOCK "E"	
		Front	Side 1
		Side 2	Rear
Distance to Exposure (m)		30	23
Height of Exposed Building (Stories)		2	2
Length of Exposed Building Facing Wall (m)		9	15
Length-Height Factor		18	30
Exposure Adjustment Charge		0%	2%
			21%
			15%
			38%
			2,280 L/min
		RFF =	7,380 L/min
		Rounded to	7,000 L/min
Required Duration of Fire Flow	Table 1		2.00 hours
Standard Hydrant Distribution	Table 2		
		Average Area per Hydrant	13,500 m ²
		Maximum Recommended Spacing	142 m
		Maximum Distance from Any Point on Street or Road Frontage to a Hydrant	72 m
		Minimum Number of Hydrants (total available)	2
		Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads	112 m
		Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads	57 m

FIRE FLOW REQUIRED

TOWNHOUSE BLOCK - 2-Storey

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Townhouse Two Storey		
Building Floor Area (A) =	Bsmt Area Included	1540 m ²	16,686 ft ²	
Type V Wood Frame Construction		C = 1.5		
		F = 220 C A ^{1/2}		
		= 12,950 L/min		
		Rounded to	13,000 L/min	
Occupancy Consideration				
Limited Combustible Content	Table 3	-15%		
		-1,950 L/min		
		11,050 L/min		
Automatic Sprinkler Consideration	No Sprinklers	0%		
		0 L/min		
Exposure Adjustment Charges (Table 6)				
	BLOCK "E"			
	Front	Side 1	Side 2	Rear
Distance to Exposure (m)	36	5	5	>30
Height of Exposed Building (Stories)	2	2	2	2
Length of Exposed Building Facing Wall (m)	48	16	16	48
Length-Height Factor	96	32	32	96
Exposure Adjustment Charge	0%	16%	16%	0%
				32%
				4,160 L/min
				RFF = 15,210 L/min
				Rounded to 15,000 L/min
Required Duration of Fire Flow	Table 1			3.50 hours
Standard Hydrant Distribution	Table 2			
		Average Area per Hydrant		9,500 m ²
		Maximum Recommended Spacing		90 m
		Maximum Distance from Any Point on Street or Road Frontage to a Hydrant		55 m
		Minimum Number of Hydrants (total available)		5
		Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads		60 m
		Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads		40 m

FIRE FLOW REQUIRED

TOWNHOUSE BLOCK - 2-Storey with vertical firewall with a fire-resistance rating of not less than 2 hours

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Townhouse with Fire Wall	
		Two Storey	
		770 m ²	8,343 ft ²
Building Floor Area (A) =	Bsmt Area Included	C =	1.5
Type V Wood Frame Construction		F =	220 C A ^{1/2}
		=	9,157 L/min
		Rounded to	9,000 L/min
Occupancy Consideration	Table 3		-15%
Limited Combustible Content			-1,350 L/min
			7,650 L/min
Automatic Sprinkler Consideration	No Sprinklers		0%
			0 L/min
Exposure Adjustment Charges (Table 6)	BLOCK "E"		
	Front	Side 1	Side 2
Distance to Exposure (m)	36	0	5
Height of Exposed Building (Stories)	2	2	2
Length of Exposed Building Facing Wall (m)	48	16	16
Length-Height Factor	96	32	32
Exposure Adjustment Charge	0%	0%	16%
			16%
			1,440 L/min
		RFF =	9,090 L/min
		Rounded to	9,000 L/min
Required Duration of Fire Flow	Table 1		2.00 hours
Standard Hydrant Distribution	Table 2		
		Average Area per Hydrant	12,000 m ²
		Maximum Recommended Spacing	135 m
		Maximum Distance from Any Point on Street or Road Frontage to a Hydrant	70 m
		Minimum Number of Hydrants (total available)	3
		Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads	105 m
		Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads	55 m

FIRE FLOW REQUIRED

TOWNHOUSE BLOCK - 2-Storey with vertical firewalls with a fire-resistance rating of not less than 2 hours. Reduced Floor Area

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Townhouse with Fire Wall3																								
		Two Storey																								
Building Floor Area (A) = Type V Wood Frame Construction	Bsmt Area Included	540 m ² 5,851 ft ²																								
		C = 1.5																								
		F = 220 C A ^{1/2}																								
		= 7,669 L/min																								
		Rounded to 8,000 L/min																								
Occupancy Consideration Limited Combustible Content	Table 3	-15% -1,200 L/min 6,800 L/min																								
Automatic Sprinkler Consideration	No Sprinklers	0% 0 L/min																								
Exposure Adjustment Charges (Table 6)	BLOCK "E"																									
	<table border="1" style="display: inline-table; border-collapse: collapse;"> <thead> <tr> <th style="padding: 2px;">Front</th> <th style="padding: 2px;">Side 1</th> <th style="padding: 2px;">Side 2</th> <th style="padding: 2px;">Rear</th> </tr> </thead> <tbody> <tr> <td style="padding: 2px;">Distance to Exposure (m)</td> <td style="padding: 2px;">36</td> <td style="padding: 2px;">0</td> <td style="padding: 2px;">5</td> </tr> <tr> <td style="padding: 2px;">Height of Exposed Building (Stories)</td> <td style="padding: 2px;">2</td> <td style="padding: 2px;">2</td> <td style="padding: 2px;">2</td> </tr> <tr> <td style="padding: 2px;">Length of Exposed Building Facing Wall (m)</td> <td style="padding: 2px;">48</td> <td style="padding: 2px;">16</td> <td style="padding: 2px;">16</td> </tr> <tr> <td style="padding: 2px;">Length-Height Factor</td> <td style="padding: 2px;">96</td> <td style="padding: 2px;">32</td> <td style="padding: 2px;">32</td> </tr> <tr> <td style="padding: 2px;">Exposure Adjustment Charge</td> <td style="padding: 2px;">0%</td> <td style="padding: 2px;">0%</td> <td style="padding: 2px;">16%</td> </tr> </tbody> </table>	Front	Side 1	Side 2	Rear	Distance to Exposure (m)	36	0	5	Height of Exposed Building (Stories)	2	2	2	Length of Exposed Building Facing Wall (m)	48	16	16	Length-Height Factor	96	32	32	Exposure Adjustment Charge	0%	0%	16%	
Front	Side 1	Side 2	Rear																							
Distance to Exposure (m)	36	0	5																							
Height of Exposed Building (Stories)	2	2	2																							
Length of Exposed Building Facing Wall (m)	48	16	16																							
Length-Height Factor	96	32	32																							
Exposure Adjustment Charge	0%	0%	16%																							
		16%																								
		1,280 L/min																								
		RFF = 8,080 L/min																								
		Rounded to 8,000 L/min																								
Required Duration of Fire Flow	Table 1	2.00 hours																								
Standard Hydrant Distribution	Table 2																									
	Average Area per Hydrant	13,000 m ²																								
	Maximum Recommended Spacing	135 m																								
	Maximum Distance from Any Point on Street or Road Frontage to a Hydrant	70 m																								
	Minimum Number of Hydrants (total available)	2																								
	Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads	105 m																								
	Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads	55 m																								

FIRE FLOW REQUIRED

STACKED TOWNHOUSE - 3-Storey

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural components, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Stacked Townhouse Three Storey	
		1000 m ²	10,835 ft ²
Building Floor Area (A) =	Bsmt Area Excluded		
Type V Wood Frame Construction		C = 1.5	
		F = 220 C A ^{1/2}	
		= 10,436 L/min	
		Rounded to	10,000 L/min
Occupancy Consideration			
Limited Combustible Content	Table 3	-15%	
		-1,500 L/min	
		8,500 L/min	
Automatic Sprinkler Consideration	No Sprinklers	0%	
		0 L/min	
Exposure Adjustment Charges (Table 6)			
	BLOCK "E"		
	Front Side 1 Side 2 Rear		
Distance to Exposure (m)	>30 4 4 >30		
Height of Exposed Building (Stories)	3 3 3 3		
Length of Exposed Building Facing Wall (m)	36 14 14 36		
Length-Height Factor	108 42 42 108		
Exposure Adjustment Charge	0% 17% 17% 0%		34%
			3,400 L/min
		RFF =	11,900 L/min
		Rounded to	12,000 L/min
Required Duration of Fire Flow	Table 1		2.50 hours
Standard Hydrant Distribution	Table 2		
	Average Area per Hydrant		11,000 m ²
	Maximum Recommended Spacing		120 m
	Maximum Distance from Any Point on Street or Road Frontage to a Hydrant		70 m
	Minimum Number of Hydrants (total available)		3
	Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads		90 m
	Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads		55 m

FIRE FLOW REQUIRED

APARTMENT BUILDING

621 DUNDAS STREET EAST at Haig Road, Belleville

REQUIRED FIRE FLOW (L/min)

(Per Fire Underwriters Survey)

$$RFF = 220 C A^{1/2}$$

F = the required fire flow in litres per minute

C = Coefficient related to type of construction

- = 1.5 for wood frame construction (structure essentially all combustible)
- = 1.0 for ordinary construction (brick or other masonry, combustible floor and interior)
- = 0.8 for non-combustible (unprotected metal structural componets, masonry or metal walls)
- = 0.6 for fire-resistive construction (fully protected frame, floors, roof)

A = the total floor area in square metres (including all storeys, but excluding basements at least 50 percent below grade) in the building being considered.

		Stacked Townhouse	
		Three Storey	
Building Floor Area (A) =		2250 m ²	24,378 ft ²
Type I Fire Resistive Construction		C = 0.6	
		F = 220 C A ^{1/2}	
		= 6,261 L/min	
		Rounded to 6,000 L/min	
Occupancy Consideration			
Limited Combustible Content	Table 3	-15%	
		-900 L/min	
		5,100 L/min	
Automatic Sprinkler Consideration			
	Installation per NFPA 13	15%	
	Consider 50% Building Coverage	900 L/min	
Exposure Adjustment Charges (Table 6)			
	BLOCK "E"		
	Front Side 1 Side 2 Rear		
Distance to Exposure (m)	>30 >30 >30 >30		
Height of Exposed Building (Stories)	7 7 7 7		
Length of Exposed Building Facing Wall (m)	60 30 25 60		
Length-Height Factor	420 210 175 420		
Exposure Adjustment Charge	0% 0% 0% 0%	0%	
		0 L/min	
		RFF = 6,000 L/min	
		Rounded to 6,000 L/min	100
Required Duration of Fire Flow	Table 1	2.00 hours	
Standard Hydrant Distribution	Table 2		
	Average Area per Hydrant	14,000 m ²	
	Maximum Recommended Spacing	150 m	
	Maximum Distance from Any Point on Street or Road Frontage to a Hydrant	75 m	
	Minimum Number of Hydrants (total available)	1	
	Per Note a. Reduce Maximum Hydrant Spacing by 30m for Dead End Streets or Roads	N/A m	
	Per Note d. Reduce Maximum Distance from Any Point on Street by 15m for Dead End Streets or Roads	N/A m	

Junction Table - Maximum Day Demand

ID	Label	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
59	J-9	87.50	0	137.30	487
60	J-10	85.00	0	137.27	512
62	J-11	85.00	0	137.27	512
64	J-12	85.00	0	137.27	512
76	J-14	82.20	0	137.22	538
84	J-18	79.80	0	137.14	561
94	J-23	79.60	64	137.19	564
99	J-25	79.60	59	137.14	563
103	J-26	82.20	0	137.22	538
107	J-27	79.25	164	137.13	566
150	J-39	85.00	0	137.27	512
165	J-41	78.20	40	137.15	577
174	J-42	85.00	0	137.27	512
178	J-44	79.10	0	137.19	568
184	J-45	82.00	172	137.19	540
202	J-53	80.52	105	137.14	554
205	J-54	80.90	196	137.16	551
208	J-55	78.50	27	137.16	574
211	J-56	78.60	47	137.14	573
216	J-57	78.20	35	137.19	577
221	J-58	78.56	0	137.17	574
224	J-59	78.50	18	137.17	574

Pipe Table - Maximum Day Demand

Label	Start Node	Stop Node	Diameter (mm)	Material	Hazen-Williams C	Length (User Defined) (m)	Flow (L/min)	Velocity (m/s)	Hydraulic Grade (Start) (m)	Hydraulic Grade (Stop) (m)	Headloss (m)
P-10	J-9	J-10	297.0	PVC	120.0	119.10	950	0.23	137.30	137.27	0.03
P-11	J-10	J-11	297.0	PVC	120.0	7.00	479	0.12	137.27	137.26	0.00
P-16	H-1	J-42	297.0	PVC	120.0	50.00	0	0.00	137.26	137.26	0.00
P-29	J-23	H-11	204.0	PVC	110.0	89.00	-762	0.39	137.12	137.24	0.11
P-31	J-18	J-25	204.0	PVC	110.0	56.00	-491	0.25	136.65	136.68	0.03
P-34	H-11	J-26	204.0	PVC	110.0	9.00	-762	0.39	137.24	137.25	0.01
P-36	J-26	J-14	250.0	PVC	110.0	8.00	-283	0.10	137.25	137.25	0.00
P-37	J-18	J-27	204.0	PVC	110.0	86.00	146	0.07	136.65	136.65	0.01
P-43	H-5	J-27	204.0	PVC	110.0	77.00	-32	0.02	136.65	136.65	0.00
P-47	J-25	H-7	204.0	PVC	110.0	95.00	-554	0.28	136.68	136.75	0.07
P-53	R-9	PMP-3	1,000.0	PVC	120.0	0.01	950	0.02	87.50	87.50	0.00
P-54	PMP-3	J-9	297.0	PVC	120.0	10.00	950	0.23	137.30	137.30	0.00
P-58	H-13	J-12	204.0	PVC	110.0	2.00	0	0.00	137.26	137.26	0.00
P-59	H-12	H-13	204.0	PVC	110.0	216.00	0	0.00	137.26	137.26	0.00
P-60	H-13	J-39	204.0	PVC	110.0	10.00	0	0.00	137.26	137.26	0.00
P-61	J-14	J-10	250.0	PVC	110.0	92.00	-472	0.16	137.25	137.27	0.02
P-62	J-26	J-11	250.0	PVC	110.0	90.00	-478	0.16	137.25	137.26	0.02
P-63	J-11	J-12	297.0	PVC	120.0	6.30	0	0.00	137.26	137.26	0.00
P-68	J-41	H-8	204.0	PVC	110.0	87.00	-639	0.33	136.78	136.86	0.08
P-69	H-7	J-41	204.0	PVC	110.0	40.00	-554	0.28	136.75	136.78	0.03
P-71	J-23	H-15	204.0	PVC	110.0	235.00	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)
P-72	H-15	J-25	204.0	PVC	110.0	120.00	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)
P-75	H-9	J-44	204.0	PVC	110.0	27.00	-685	0.35	137.07	137.10	0.03
P-76	J-44	J-23	204.0	PVC	110.0	24.00	-692	0.35	137.10	137.12	0.03
P-77	J-44	H-18	204.0	PVC	110.0	103.00	7	0.00	137.10	137.10	0.00
P-78	J-14	J-45	204.0	PVC	110.0	45.55	188	0.10	137.25	137.24	0.00
P-79	J-45	H-6	204.0	PVC	110.0	55.00	0	0.00	137.24	137.24	0.00
P-80	H-14	J-46	204.0	PVC	110.0	10.00	-281	0.14	136.64	136.64	0.00
P-81	J-46	J-18	204.0	PVC	110.0	30.00	-345	0.18	136.64	136.65	0.01
P-82	H-5	J-49	204.0	PVC	110.0	48.00	32	0.02	136.65	136.65	0.00
P-83	J-49	H-4	204.0	PVC	110.0	32.00	-40	0.02	136.65	136.65	0.00
P-89	J-53	H-14	204.0	PVC	110.0	62.00	-281	0.14	136.63	136.64	0.01
P-90	H-6	J-54	204.0	PVC	110.0	121.00	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)
P-91	J-54	J-53	204.0	PVC	110.0	88.14	-214	0.11	136.62	136.63	0.01
P-92	H-8	J-55	204.0	PVC	110.0	75.00	-639	0.33	136.86	136.92	0.07
P-93	J-55	H-9	204.0	PVC	110.0	143.00	-685	0.35	136.92	137.07	0.15
P-95	J-41	H-19	204.0	PVC	110.0	265.00	53	0.03	136.78	136.77	0.00
P-96	H-19	J-56	204.0	PVC	110.0	63.00	53	0.03	136.77	136.77	0.00
P-97	J-57	H-18	204.0	PVC	110.0	32.00	-7	0.00	137.10	137.10	0.00
P-99	J-27	H-4	204.0	PVC	110.0	51.00	40	0.02	136.65	136.65	0.00
P-100	J-12	H-1	295.0	PVC	120.0	37.00	0	0.00	137.26	137.26	0.00

Hydrant Table H-4 (100 L/s)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	133.37	464
H-4	6.10	79.50	6,000	111.03	309
H-6	6.10	81.80	0	128.99	462
H-7	6.10	78.50	0	124.95	455
H-8	6.10	78.50	0	126.59	471
H-9	6.10	78.60	0	129.29	496
H-11	6.10	81.80	0	130.42	476
H-12	6.10	86.00	0	133.37	464
H-13	6.10	85.77	0	133.37	466
H-14	6.10	80.30	0	123.44	422
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	129.59	500
H-19	6.10	78.00	0	125.59	466

Hydrant Table H-4 (140 kPa Residual)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	131.41	445
H-4	6.10	79.50	8,040	93.85	140
H-6	6.10	81.80	0	124.33	416
H-7	6.10	78.50	0	117.60	383
H-8	6.10	78.50	0	120.34	410
H-9	6.10	78.60	0	124.80	452
H-11	6.10	81.80	0	126.65	439
H-12	6.10	86.00	0	131.41	444
H-13	6.10	85.77	0	131.41	447
H-14	6.10	80.30	0	115.05	340
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	125.30	458
H-19	6.10	78.00	0	118.68	398

Hydrant Table H-6 (100 L/s)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	133.37	464
H-4	6.10	79.50	0	128.31	478
H-6	6.10	81.80	6,000	126.07	433
H-7	6.10	78.50	0	128.95	494
H-8	6.10	78.50	0	129.52	499
H-9	6.10	78.60	0	130.48	508
H-11	6.10	81.80	0	130.90	481
H-12	6.10	86.00	0	133.37	464
H-13	6.10	85.77	0	133.37	466
H-14	6.10	80.30	0	128.27	469
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	130.59	510
H-19	6.10	78.00	0	129.17	501

Hydrant Table H-6 (140kPa Residual)

Label	Lateral Length	Elevation	Demand	Hydraulic Grade	Pressure
H-1	6.10	85.93	0	125.30	385
H-4	6.10	79.50	0	106.56	265
H-6	6.10	81.80	13,200	96.12	140
H-7	6.10	78.50	0	109.10	299
H-8	6.10	78.50	0	111.23	320
H-9	6.10	78.60	0	114.72	353
H-11	6.10	81.80	0	116.18	336
H-12	6.10	86.00	0	125.30	385
H-13	6.10	85.77	0	125.30	387
H-14	6.10	80.30	0	106.34	255
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	115.11	358
H-19	6.10	78.00	0	109.93	313

Hydrant Table H-8 (180 L/s)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	128.34	415
H-4	6.10	79.50	0	109.77	296
H-6	6.10	81.80	0	119.20	366
H-7	6.10	78.50	0	103.87	248
H-8	6.10	78.50	10,800	94.11	153
H-9	6.10	78.60	0	113.12	338
H-11	6.10	81.80	0	118.80	362
H-12	6.10	86.00	0	128.34	414
H-13	6.10	85.77	0	128.34	417
H-14	6.10	80.30	0	110.46	295
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	114.66	354
H-19	6.10	78.00	0	101.95	234

Hydrant Table H-8 (140 kPa Residual)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	128.12	413
H-4	6.10	79.50	0	109.02	289
H-6	6.10	81.80	0	118.72	361
H-7	6.10	78.50	0	102.93	239
H-8	6.10	78.50	10,980	92.86	141
H-9	6.10	78.60	0	112.46	331
H-11	6.10	81.80	0	118.30	357
H-12	6.10	86.00	0	128.12	412
H-13	6.10	85.77	0	128.12	414
H-14	6.10	80.30	0	109.73	288
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	114.05	348
H-19	6.10	78.00	0	100.95	225

Hydrant Table H-18 (150 L/s)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	130.39	435
H-4	6.10	79.50	0	122.08	417
H-6	6.10	81.80	0	125.01	423
H-7	6.10	78.50	0	120.45	411
H-8	6.10	78.50	0	119.20	398
H-9	6.10	78.60	0	117.33	379
H-11	6.10	81.80	0	121.85	392
H-12	6.10	86.00	0	130.39	434
H-13	6.10	85.77	0	130.39	437
H-14	6.10	80.30	0	122.29	411
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	9,000	101.03	221
H-19	6.10	78.00	0	119.92	410

Hydrant Table H-18 (140 kPa Residual)

Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	129.18	423
H-4	6.10	79.50	0	119.16	388
H-6	6.10	81.80	0	122.70	400
H-7	6.10	78.50	0	117.14	378
H-8	6.10	78.50	0	115.59	363
H-9	6.10	78.60	0	113.26	339
H-11	6.10	81.80	0	118.78	362
H-12	6.10	86.00	0	129.18	423
H-13	6.10	85.77	0	129.18	425
H-14	6.10	80.30	0	119.42	383
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	10,080	93.13	143
H-19	6.10	78.00	0	116.48	377

Hydrant Table H-19 (117 L/s)


Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	132.44	455
H-4	6.10	79.50	0	122.40	420
H-6	6.10	81.80	0	127.69	449
H-7	6.10	78.50	0	119.24	399
H-8	6.10	78.50	0	120.29	409
H-9	6.10	78.60	0	125.82	462
H-11	6.10	81.80	0	128.11	453
H-12	6.10	86.00	0	132.44	455
H-13	6.10	85.77	0	132.44	457
H-14	6.10	80.30	0	122.78	416
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	126.44	469
H-19	6.10	78.00	7,000	94.75	164

Hydrant Table H-19 (140 kPa Residual)


Label	Lateral Length (m)	Elevation (m)	Demand (L/min)	Hydraulic Grade (m)	Pressure (kPa)
H-1	6.10	85.93	0	132.25	453
H-4	6.10	79.50	0	121.73	413
H-6	6.10	81.80	0	127.27	445
H-7	6.10	78.50	0	118.40	390
H-8	6.10	78.50	0	119.49	401
H-9	6.10	78.60	0	125.30	457
H-11	6.10	81.80	0	127.71	449
H-12	6.10	86.00	0	132.25	453
H-13	6.10	85.77	0	132.25	455
H-14	6.10	80.30	0	122.13	409
H-15	6.10	80.30	(N/A)	(N/A)	(N/A)
H-18	6.10	78.50	0	125.95	464
H-19	6.10	78.00	7,200	92.59	143

REVISIONS	
Date	Description
JAN 8/24	REVISED SITE LAYOUT FROM ARCHITECT 24-0-17
JAN 8/24	REVISED SITE LAYOUT FROM ARCHITECT 24-0-04
DEC 20/23	UNDERLAY 23-2-15 SITE LAYOUT FROM ARCHITECT
NOV 8/23	REVISED SITE LAYOUT FROM ARCHITECT
S.O.S.	
S.O.S.	
S.O.S.	
S.O.S.	
S.O.S.	
By	Chk'd By

SCALE: 1:250
 DESIGNER: A.H.V.
 DRAWN: S.O.S.
 DATE: 7/07
 COMPUTER: Dundas 621 Belleville Property



WATERMAIN DESIGN
 PIPE NETWORK
 DRAWING Dm/621-W1
 DRAWINGS 621 Dundas St. E. 24-01-06-04



APPENDIX D

Storm Sewer Design

Storm Sewer Design Sheets – 5-Year Storm Event

Storm Sewer Design Sheets – 100-Year Storm Event

Storm Sewer Design

Drainage Area Plan & Pipe Network

Drawing DUN/621-St1

Storm Sewer Design

Haig Road Sub-catchment

Drawing DUN/621-St2

Ontario IDF Curve Look-up

STORM SEWER DESIGN SHEET

5 Year Storm Event (Q=2.78 AIR, I=27.7i^{-0.699})

EXTERNAL DRAINAGE AREAS
HAIG ROAD
INTERNAL AREAS

LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q ₁) (l/s) n= 0.013	Qp/Qf	Vp (m/s)	TIME of FLOW (min)	
STREET	FROM	TO	R=0.45	R=0.60	R=0.65													R=0.7
HAIG ROAD	100,101	CB 8, CB 9	0.44				0.547	15.00	73	39.9	300	7.4	96.7	0.41	0.96	1.37	0.09	
	102 - 105	ST 5	0.47				0.586	15.09	73	82.4	375	106.6	103.7	0.79	1.11	0.94	1.70	
	106 - 108	ST 3	0.47				0.582	16.80	67	115.7	375	86.5	103.7	Such	1.12	0.94	1.07	
	110a	EXGB		1.38			2.303	15.00	73	168.1	300	50.0	68.4	Such	2.46	1.14	1.10	
	109, 110	ST 3	0.26				0.326	18.14	64	277.6	525	47.5	333.1	0.83	1.12	1.54	1.72	
	112a, 112b	ST 2	0.28				0.345	18.60	63	294.5	525	21.6	384.7	0.77	1.10	1.78	1.95	
	111-115	ST 1	0.98				1.224	18.79	62	368.8	750	58.4	497.9	0.75	1.10	1.13	1.24	
	ROAD A	ST-A1	Headwall					5.913	19.57	61	358.4	750	23.6	1269.3	0.28	0.87	2.87	2.50
		ST-A2	ST-A2					5.913	19.73	60	356.4	750	70.4	1219.5	0.29	0.88	2.76	2.42
		ST-A3	ST-A3					5.913	20.22	59	350.4	750	79.5	1829.3	0.19	0.78	4.14	3.23
ST-A4		ST-A4					5.913	20.22	59	350.4	750	71.8	1408.2	0.25	0.83	3.19	2.65	
ST-A5		ST-A5					5.913	20.63	58	345.5	750	46.5	658.6	0.52	1.00	1.49	1.49	
ST-A6		ST-A6																
SQU-100	BLOCK A (East)	CB A-1A					0.556	15.00	73	40.6	300	47.0	68.4	0.59	1.03	0.97	1.00	
		CB A-2E	0.29				0.923	15.79	70	65.0	300	22.9	68.4	0.95	1.14	0.97	1.10	
		BLDG	0.16				0.321	15.00	73	23.4	300	15.0	68.4	0.34	0.91	0.97	0.88	
		ST-1001					1.243	16.13	69	86.3	375	15.8	254.1	0.34	0.90	2.30	2.07	
		ST-1002					1.243	16.26	69	85.8	375	50.8	130.0	0.66	1.06	1.18	1.25	
		CB/MH 103					0.314	15.00	73	23.0	300	7.4	294.9	0.08	0.59	4.17	2.46	
STREET A	BLOCK B	CB 101	0.16				0.123	15.05	73	31.9	375	9.3	146.7	0.22	0.80	1.33	1.06	
		CB 102	0.06				0.602	16.94	67	40.4	375	9.3	146.7	0.28	0.86	1.33	1.14	
		CB/MH 103	0.08				0.220	15.00	73	16.1	300	13.9	68.4	0.23	0.82	0.97	0.79	
		CB 104	0.11				0.240	15.00	73	17.5	300	39.1	68.4	0.26	0.84	0.97	0.81	
		CB 105	0.12				0.233	15.80	70	33.2	300	28.2	110.3	0.30	0.88	1.56	1.37	
		CB 106	0.12				0.393	16.14	69	60.0	300	8.3	270.1	0.22	0.81	3.82	3.09	
		CB/MH 107	0.20				0.291	15.00	73	21.2	300	7.7	68.4	0.31	0.89	0.97	0.86	
		CB 108	0.15				0.162	17.07	67	225.6	300	8.3	270.1	0.22	0.84	3.82	4.28	
		CB/MH 109	0.08															
		ST-1004																

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 1 of 5

STORM SEWER DESIGN SHEET

5 Year Storm Event (Q=2.78 AIR, I=27.7i^{-0.699})

EXTERNAL DRAINAGE AREAS
HAIG ROAD
INTERNAL AREAS

STREET	LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA				TIME of FLOW (min)				
	FROM	TO	R=0.45	R=0.60	R=0.65	R=0.7						R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)		CAPACITY (Q _t) (l/s) n= 0.013	Qp/Qf	Vp (m/s)	Vf (m/s)
BLOCK E	110	CB/MH 111				0.30	0.587	15.00	73	42.8	300	0.80%	43.6	86.5	OK	0.50	1.00	1.22	1.22	0.60
	111	CB/MH 111 ST-1004				0.14	0.271	15.60	71	60.9	300	2.20%	8.6	143.4	OK	0.42	0.96	2.03	1.95	0.07
	112	DI 112 ST-1004		0.18			0.296	15.00	73	21.6	300	0.50%	18.8	68.4	OK	0.32	0.89	0.97	0.86	0.37
	113	CB 113 ST-1004		0.33			0.551	15.00	73	40.2	300	6.50%	8.6	246.5	OK	0.16	0.74	3.49	2.58	0.06
	114	CB/MH 115 CB/MH 115		0.09			5.088	17.11	67	338.8	525	1.00%	47.6	430.1	OK	0.79	1.11	1.99	2.21	0.36
115	CB/MH 115 DCB/MH 120		0.10			0.143	15.00	73	10.5	300	0.90%	7.7	91.7	OK	0.11	0.67	1.30	0.87	0.15	
BLOCK D	116	CB 117		0.40			0.170	17.47	66	354.5	525	0.60%	29.1	333.1	OK	1.06	1.14	1.54	1.75	0.28
	117	CB/MH 118		0.05			0.662	15.00	73	48.3	300	1.10%	21.5	101.4	OK	0.48	0.99	1.43	1.41	0.25
	118	CB/MH 118 DCB/MH 119		0.11			0.077	15.25	72	53.3	375	0.50%	7.8	124.0	OK	0.43	0.97	1.12	1.08	0.12
	119	DCB/MH 119 DCB/MH 120		0.07			0.181	15.37	72	66.0	375	0.50%	19.4	124.0	OK	0.53	1.01	1.12	1.13	0.29
	120	DCB/MH 120 SQU-100		0.07			0.125	15.66	71	74.0	426.5	0.50%	8.8	124.0	OK	0.60	1.03	1.12	1.16	0.13
STREET A	201	SQU-100 MC-3500		0.07			6.570	17.74	65	425.9	600	8.10%	10.9	1747.5	OK	0.24	0.83	6.18	5.13	0.04
	202	MC-3500 ST-1005					6.570	17.78	65	425.9	600	2.30%	3.2	931.2	OK	0.46	0.98	3.29	3.21	0.02
	203	ST-1005 ST-A6					6.570	17.79	65	425.6	600	11.00%	4.4	2036.4	OK	0.21	0.79	7.20	5.69	0.01
	204	OUTLET					6.570	17.81	65	425.4	600	0.55%	3.3	455.4	OK	0.93	1.14	1.61	1.84	0.03
	A-1W	ST-A6					12.483	21.15	57	716.8	750	0.40%	59.5	704.1	OK	1.02	1.14	1.59	1.82	0.55
SQU-200	201	CB/MH 202		0.10			0.163	15.00	73	11.9	300	5.50%	7.8	226.8	OK	0.05	0.53	3.21	1.70	0.08
	202	CB/MH 202 ST-2001		0.19			0.312	15.08	73	34.6	300	1.60%	35.0	122.3	OK	0.28	0.87	1.73	1.51	0.39
	203	CB 203 CB/MH 204		0.10			0.172	15.00	73	12.6	300	0.50%	7.8	68.4	OK	0.18	0.77	0.97	0.74	0.18
	204	CB/MH 204 ST-2001		0.16			0.259	15.18	72	31.2	300	0.50%	39.4	68.4	OK	0.46	0.98	0.97	0.94	0.70
	A-2W	CB A-1W CB/MH A-3W		0.21			0.344	15.00	73	25.1	300	0.50%	42.8	68.4	OK	0.37	0.92	0.97	0.89	0.80
A-3W	A-2W	CB A-2W CB/MH A-3W		0.31			0.523	15.00	73	38.2	300	2.50%	41.2	152.9	OK	0.25	0.83	2.16	1.80	0.38
	A-3W	CB/MH A-3W ST-A100W		0.16			1.126	15.38	72	80.8	375	0.50%	28.6	124.0	OK	0.65	1.06	1.12	1.19	0.40
	A-4W	CB A-3W CB A-4W		0.34			0.564	15.00	73	41.2	300	0.50%	57.0	68.4	OK	0.60	1.04	0.97	1.01	0.94
	A-4W	CB A-4W ST-A200W		0.12			0.193	15.94	70	52.9	300	0.50%	59.2	68.4	OK	0.77	1.10	0.97	1.06	0.93
	A-5W	BLDG ST-A200W		0.17			0.292	15.00	73	21.3	300	0.50%	2.0	68.4	OK	0.31	0.89	0.97	0.86	0.04

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 2 of 5

STORM SEWER DESIGN SHEET

5 Year Storm Event (Q=2.78 AIR, I=27.7i^{-0.699})

EXTERNAL DRAINAGE AREAS HAIG ROAD INTERNAL AREAS

STREET	LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA								
	FROM	TO	R=0.45	R=0.60	R=0.65	R=0.7						R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q _i) (l/s) n= 0.013	Qp/Qf	Vf (m/s)	Vp (m/s)	TIME of FLOW (min)
BLOCK A (West)	ST-A100W	ST-2001						3.081	67	207.2	450	0.50%	13.3	201.6	1.03	1.14	1.27	1.45	0.15	
	ST-2001	CB/MH 208						3.081	67	205.9	450	1.10%	54.0	299.0	0.69	1.07	1.88	2.01	0.45	
	CB 205	CB/MH 208	0.24				0.394	0.394	15.00	73	28.8	300	2.50%	20.2	152.9	0.19	0.77	2.16	1.65	0.20
	CB 206	CB/MH 208	0.11				0.178	0.178	15.00	73	13.0	300	1.90%	51.2	133.3	0.10	0.64	1.89	1.21	0.71
	CB 207	CB 207	0.06				0.100	0.100	15.00	73	7.3	300	1.00%	7.6	96.7	0.08	0.59	1.37	0.81	0.16
	CB/MH 208	ST-2001	0.25				0.410	4.164	17.47	66	273.2	450	1.00%	30.9	285.1	0.96	1.14	1.79	2.04	0.25
	CB 209	ST-2002	0.19				0.313	0.313	15.00	73	22.9	300	2.10%	27.4	140.1	0.16	0.74	1.98	1.47	0.31
	ST-2002	ST-2003					4.477	4.477	17.72	65	290.9	525	2.00%	8.7	608.2	0.48	0.99	2.81	2.77	0.05
	ST-2003	CB/MH 210					4.477	4.477	17.78	65	290.3	525	2.00%	34.2	608.2	0.48	0.99	2.81	2.77	0.21
	CB/MH 210	ST-2004	0.34				0.076	4.477	17.98	64	287.9	525	1.60%	35.7	544.0	0.53	1.01	2.51	2.54	0.23
CB 211	CB/MH 212	0.05				0.192	0.076	15.00	73	5.6	300	0.50%	7.8	68.4	0.08	0.62	0.97	0.60	0.22	
CB/MH 212	ST-2004	0.11				0.373	0.268	15.22	72	19.4	300	0.50%	33.9	68.4	0.28	0.87	0.97	0.84	0.67	
ST-2004	CB/MH 213	0.22				0.167	4.745	18.22	64	302.4	525	0.50%	11.6	304.1	0.99	1.14	1.40	1.60	0.12	
CB/MH 213	CB/MH 214	0.10				0.335	5.119	18.34	63	324.7	525	0.50%	7.6	304.1	1.07	1.14	1.40	1.60	0.08	
CB/MH 214	SQU-200					0.167	5.286	18.34	63	335.3	750	9.50%	8.6	3431.4	0.10	0.64	7.77	4.97	0.03	
SQU-200	MC-3500					0.167	5.286	18.42	63	334.3	750	9.50%	5.4	3431.4	0.10	0.64	7.77	4.97	0.02	
MC-3500	ST-2005					0.176	5.286	18.44	63	334.1	750	0.10%	2.6	352.0	0.95	1.14	0.80	0.91	0.05	
SQU-300	F-1E	CB F-1E	0.10				0.158	0.158	15.00	73	11.6	300	2.80%	15.3	161.8	0.07	0.59	2.29	1.35	0.19
	F-2E	CB F-4E	0.15				0.248	0.407	15.19	72	29.4	300	0.50%	65.1	68.4	0.43	0.97	0.97	0.93	1.16
	F-3E	CB F-4E	0.05				0.084	0.084	15.00	73	6.2	300	6.50%	15.4	246.5	0.02	0.34	3.49	1.19	0.22
	F-4E	ST-3001	0.23				0.378	0.869	16.35	69	59.7	300	0.50%	31.2	68.4	0.87	1.13	0.97	1.09	0.48
	F-5E	ST-3001	0.08				0.130	0.130	15.00	73	9.5	300	2.10%	32.9	140.1	0.07	0.57	1.98	1.13	0.49
	301	CB 301	0.07				0.117	0.117	15.00	73	8.6	300	0.50%	2.4	68.4	0.13	0.69	0.97	0.67	0.06
	BLOCK F (East)	CB/MH 303					1.116	1.116	16.83	67	75.2	375	0.50%	15.6	124.0	0.61	1.04	1.17	1.17	0.22
	302	CB 302	0.36				0.599	0.599	15.00	73	43.7	300	0.50%	43.8	68.4	0.64	1.05	0.97	1.02	0.72
	303	ST-3002	0.14				0.226	1.942	17.05	67	129.6	375	0.50%	56.4	124.0	1.05	1.14	1.12	1.28	0.73
	CB/MH 306	CB/MH 306					0.291	1.942	17.79	65	125.8	375	0.50%	10.4	124.0	1.01	1.14	1.12	1.28	0.14
CB 304	CB/MH 306	0.17				0.136	0.291	15.00	73	21.2	300	6.80%	7.8	252.2	0.08	0.62	3.57	2.21	0.06	
CB 305	CB 305	0.08				0.136	0.136	15.00	73	9.9	300	7.40%	6.8	263.1	0.04	0.46	3.72	1.71	0.07	
CB/MH 310	CB/MH 310	0.14				0.233	2.601	17.92	64	167.7	450	0.70%	56.3	238.5	0.70	1.08	1.50	1.62	0.58	
CB 307	CB/MH 310	0.09				0.156	0.156	15.00	73	11.4	300	7.30%	6.1	261.3	0.04	0.50	3.70	1.85	0.06	
CB 308	CB/MH 310	0.06				0.095	0.095	15.00	73	6.9	300	7.80%	7.8	270.1	0.03	0.34	3.82	1.30	0.10	
CB 309	CB 309	0.07				0.125	0.125	15.00	73	9.1	300	0.50%	7.0	68.4	0.13	0.71	0.97	0.69	0.17	
CB/MH 310	CB/MH 312	0.08				0.135	3.113	18.50	63	196.3	450	0.50%	61.5	201.6	0.97	1.14	1.27	1.45	0.71	
CB 311	CB/MH 312	0.06				0.105	0.105	15.00	73	7.6	300	0.50%	7.8	68.4	0.11	0.67	0.97	0.65	0.20	
CB/MH 312	ST-3003	0.11				0.176	3.393	19.21	61	208.4	450	0.50%	9.2	201.6	1.03	1.14	1.27	1.45	0.11	

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 3 of 5

STORM SEWER DESIGN SHEET

5 Year Storm Event (Q=2.78 AIR, I=27.7i^{-0.699})

EXTERNAL DRAINAGE AREAS
HAIG ROAD
INTERNAL AREAS

STREET	LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA									
	FROM	TO	R=0.45	R=0.60	R=0.65	R=0.7						R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q _r) (l/s) n= 0.013	Qp/Qf	Vp/Vf	Vp (m/s)	TIME of FLOW (min)	
313	ST-3003	CB/MH 314						3.393	19.32	61	207.6	450	0.50%	29.2	201.6	OK	1.03	1.14	1.27	1.45	0.34
314	CB 313	CB/MH 314					0.193	0.193	15.00	73	14.1	300	0.50%	7.8	68.4	OK	0.21	0.79	0.97	0.76	0.17
315	CB/MH 314	CB/MH 320		0.12			0.109	3.696	19.65	60	223.4	525	0.50%	38.6	304.1	OK	0.73	1.09	1.40	1.53	0.42
316	CB 315	DCB/MH 316		0.15			0.257	0.257	15.00	73	18.8	300	1.90%	26.2	133.3	OK	0.14	0.72	1.89	1.36	0.32
317	DCB/MH 316	CB/MH 317		0.20			0.332	0.589	15.32	72	42.4	375	1.70%	34.2	228.6	OK	0.19	0.77	2.07	1.58	0.36
318	CB/MH 317	CB/MH 320		0.24			0.400	0.989	15.68	71	70.0	375	2.00%	35.7	248.0	OK	0.28	0.87	2.25	1.95	0.30
319	CB 318	CB 319		0.06			0.101	0.101	15.00	73	7.4	300	0.50%	13.4	68.4	OK	0.11	0.65	0.97	0.63	0.36
320	CB 319	CB/MH 320		0.08			0.134	0.236	15.36	72	16.9	375	0.50%	7.8	124.0	OK	0.14	0.71	1.12	0.80	0.16
321	CB/MH 320	DCB/MH 321		0.09			0.152	5.073	20.07	60	302.1	525	0.50%	40.0	304.1	OK	0.99	1.14	1.40	1.60	0.42
322	DCB/MH 321	DCB/MH 322		0.19			0.318	5.391	20.49	59	316.4	525	0.50%	7.8	304.1	OK	1.04	1.14	1.40	1.60	0.08
	DCB/MH 322	SQU-300		0.12			0.199	5.590	20.57	59	327.2	750	9.40%	9.4	3413.2	OK	0.10	0.64	7.73	4.94	0.03
	SQU-300	ST-2005					0.000	5.590	20.74	58	325.4	750	0.10%	9.4	352.0	OK	0.92	1.14	0.80	0.90	0.17
	ST-2005	OUTLET						10.876	20.91	58	629.3	750	0.35%	7.9	658.6	OK	0.96	1.14	1.49	1.70	0.08

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 4 of 5

STORM SEWER DESIGN SHEET

5 Year Storm Event (Q=2.78 AIR, I=27.7i^{-0.699})

EXTERNAL DRAINAGE AREAS HAIG ROAD INTERNAL AREAS

STREET	LOCATION		AREAS (ha)			Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA								
	FROM	TO	R=0.45	R=0.60	R=0.65						R=0.7	R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q ₁) (l/s) n= 0.013	Qp/Qf	Vp/Vf	Vf (m/s)
SQU-400	401	CB 401				0.293	0.293	15.00	73	21.4	300	0.50%	67.6	68.4	0.31	0.89	0.97	0.86	1.32
	402	CB 402	0.18			0.184	0.184	15.00	73	13.5	300	0.50%	31.7	68.4	0.20	0.78	0.97	0.75	0.70
	403	CB 403	0.22			0.359	0.359	15.70	71	38.4	300	0.60%	16.1	74.9	0.51	1.00	1.06	1.06	0.25
	404	ST-4001				0.000	0.836	15.95	70	58.5	300	1.10%	23.3	101.4	0.58	1.03	1.43	1.48	0.26
	405	CB/MH 406				0.280	0.280	15.00	73	20.4	300	1.00%	31.3	96.7	0.21	0.80	1.37	1.09	0.48
	406	CB 404	0.17			0.265	0.545	15.48	71	38.9	300	0.50%	19.4	68.4	0.57	1.02	0.97	0.99	0.33
	407	CB/MH 406	0.22			0.375	1.756	16.22	69	121.4	375	0.75%	33.2	151.8	0.80	1.11	1.37	1.53	0.36
	408	CB 407	0.10			0.169	0.169	15.00	73	12.3	300	3.70%	47.2	186.0	0.07	0.57	2.63	1.50	0.52
SQU-500	501	CB/MH 408	0.08			0.140	2.065	16.58	68	140.6	450	11.50%	6.0	966.8	0.15	0.72	6.08	4.38	0.02
	502	SQU-400				0.638	2.065	16.60	68	140.4	450	0.50%	13.7	201.6	0.70	1.07	1.27	1.36	0.17
	503	MC-3500				0.203	2.065	16.77	68	139.4	450	1.00%	5.4	285.1	0.49	0.99	1.79	1.77	0.05
	504	ST-4002				0.428	2.065	16.82	67	139.1	450	3.10%	33.3	502.0	0.28	0.86	3.16	2.71	0.20
	501	CB 501	0.38			0.638	0.638	15.00	73	46.6	450	1.80%	45.0	382.5	0.12	0.69	2.41	1.66	0.45
	502	CB 502	0.32			0.531	0.531	15.00	73	38.8	300	0.50%	52.5	68.4	0.57	1.02	0.97	0.99	0.89
	503	CB 503	0.12			0.203	0.734	15.89	70	51.5	300	0.50%	32.2	68.4	0.75	1.10	0.97	1.06	0.50
	504	CB/MH 504	0.26			0.428	1.801	16.39	69	123.6	450	4.10%	15.6	577.3	0.21	0.80	3.63	2.90	0.09
SQU-600	601	SQU-500				1.801	1.801	16.48	68	123.1	450	0.45%	4.5	191.3	0.64	1.05	1.20	1.26	0.06
	602	MC-3500				1.801	1.801	16.54	68	122.8	450	14.40%	2.3	1081.9	0.11	0.67	6.80	4.56	0.01
	603	ST-5001				1.801	1.801	16.55	68	122.7	450	0.35%	9.1	168.7	0.73	1.09	1.06	1.16	0.13
	601	CB 601	0.07			0.111	0.111	15.00	73	8.1	300	0.50%	7.6	68.4	0.12	0.67	0.97	0.65	0.20
	602	CB 602	0.26			0.435	0.435	15.00	73	31.7	300	0.50%	3.1	68.4	0.46	0.98	0.97	0.95	0.05
	603	ST-6001				0.744	0.546	15.20	72	39.5	300	0.50%	51.6	68.4	0.58	1.03	0.97	1.00	0.86
	603	DCB 603	0.45			1.289	1.289	16.06	70	89.7	450	5.40%	9.6	662.5	0.14	0.71	4.17	2.96	0.05
	603	SQU-600				1.289	1.289	16.11	69	89.5	450	0.50%	4.0	201.6	0.44	0.97	1.27	1.23	0.05
603	MC-3500				1.289	1.289	16.17	69	89.3	450	4.70%	6.0	618.1	0.14	0.72	3.89	2.80	0.04	
PROPOSED INFORMATION																			
EXISTING INFORMATION																			
			Shown in VERTICAL TEXT																
			Shown in ITALIZED TEXT																

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 5 of 5

STORM SEWER DESIGN SHEET

100 Year Storm Event (Q=2.78 AIR, I=46.1 f^{-0.699})

EXTERNAL DRAINAGE AREAS HAIG ROAD INTERNAL AREAS

LOCATION		AREAS (ha)				Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q ₁) (l/s) n= 0.013	Qp/Qf	Vp (m/s)	TIME of FLOW (min)
STREET	FROM	TO	R=0.45	R=0.60	R=0.65											
HAIG ROAD	100,101	CB 8, CB 9	0.44				0.684	15.00	83.1	300	7.4	96.7	0.86	1.13	0.08	
	102 - 105	ST 5	0.47				0.733	15.08	171.5	375	106.6	103.7	Surch	1.14	1.66	
	106 - 108	ST 4	0.47				0.727	16.74	241.2	375	86.5	103.7	Surch	1.14	1.35	
	110a	EXGB		1.38			2.878	15.00	349.7	300	50.0	68.4	Surch	1.14	0.76	
	109, 110	ST 3	0.26				0.408	18.09	578.8	525	47.5	333.1	Surch	1.14	0.45	
	112a, 112b	ST 2	0.28				0.431	18.54	614.2	525	21.6	384.7	Surch	1.14	0.18	
	111-115	ST 1	0.98				1.530	18.71	769.3	750	58.4	497.9	Surch	1.14	0.76	
	ROAD A	ST-A1	Headwall					7.391	19.47	748.2	750	23.6	1269.3	OK	1.03	0.13
		ST-A2	ST-A2					7.391	19.60	744.7	750	70.4	1219.5	OK	1.04	0.41
		ST-A3	ST-A3					7.391	20.01	734.0	750	79.5	1829.3	OK	0.95	0.34
ST-A4		ST-A4					7.391	20.35	725.5	750	71.8	1408.2	OK	1.00	0.38	
ST-A5		ST-A5					7.391	20.73	716.3	750	46.5	658.6	Surch	1.14	0.46	
ST-A6		ST-A6					7.391	20.73	716.3	750	46.5	658.6	Surch	1.14	0.46	
SQU-100	BLOCK A (East)															
	A-1E	CB A-1A				0.29	0.744	15.00	90.4	300	47.0	68.4	Surch	1.14	0.71	
	A-2E	CB A-2E				0.19	1.236	15.71	145.4	300	22.9	68.4	Surch	1.14	0.35	
	A-3E	BLDG				0.16	0.429	15.00	52.1	300	15.0	68.4	OK	1.10	0.23	
		ST-1001	ST-1001				1.665	16.06	192.9	375	254.1	254.1	OK	1.10	0.10	
		ST-1002	CB/MH 103				1.665	16.16	192.0	375	130.0	130.0	Surch	1.14	0.63	
STREET A	101	CB 101				0.16	0.421	15.00	51.2	300	7.4	294.9	OK	0.76	0.04	
	102	CB 102				0.06	0.586	15.04	71.1	375	9.3	146.7	OK	0.99	0.12	
	103	CB/MH 103				0.08	0.807	16.79	90.6	375	9.3	146.7	OK	1.04	0.11	
	104	CB 104				0.11	0.295	15.00	35.8	300	13.9	68.4	OK	1.00	0.24	
	BLOCK B	105	CB 105				0.12	0.321	15.00	39.0	300	39.1	68.4	OK	1.02	0.66
		106	CB 106				0.12	0.633	15.66	74.6	300	28.2	110.3	OK	1.07	0.28
107		CB/MH 107				0.20	1.159	15.94	134.9	300	8.3	270.1	OK	1.00	0.04	
108	CB 108	CB/MH 109			0.15	0.390	15.00	47.3	300	7.7	68.4	OK	1.07	0.12		
109	CB/MH 109	ST-1004			0.08	4.531	16.90	506.4	300	8.3	270.1	Surch	1.88	4.36		

STORM SEWER DESIGN SHEET

100 Year Storm Event (Q=2.78 AIR, I=46.1 f^{-0.699})

EXTERNAL DRAINAGE AREAS HAIG ROAD INTERNAL AREAS

STREET	LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	DIA. (mm)	SLOPE (%)	LENGTH (m)	SEWER DATA			TIME of FLOW (min)
	FROM	TO	R=0.45	R=0.60	R=0.65	R=0.7									R=0.85	Qp/Qf	Vf (m/s)	
BLOCK E	110	CB/MH 111					0.786	15.00	121	95.5	300	0.80%	43.6	1.10	1.22	1.39	0.52	
	111	CB/MH 111 ST-1004				0.30	1.148	15.52	119	136.2	300	2.20%	8.6	0.95	1.14	2.03	2.31	
	112	DI 112 ST-1004		0.18		0.14	0.369	15.00	121	44.9	300	0.50%	18.8	0.66	1.06	0.97	1.03	
	113	CB 113 ST-1004		0.33			0.689	15.00	121	83.7	300	6.50%	8.6	0.34	0.90	3.49	3.14	
	114	CB/MH 115 CB/MH 115		0.09			6.738	16.94	112	752.0	525	1.00%	47.6	1.75	1.14	1.99	2.26	
115	CB/MH 115 DCB/MH 120		0.10			0.179	15.00	121	21.8	300	0.90%	7.7	0.24	0.82	1.30	1.06		
BLOCK D	116	CB 117		0.28			7.130	17.29	110	784.4	525	0.60%	29.1	2.35	1.14	1.54	1.75	
	117	CB/MH 118		0.05			0.578	15.00	121	70.2	300	1.10%	21.5	0.69	1.07	1.43	1.54	
	118	CB/MH 118 DCB/MH 119		0.11			0.096	15.23	120	81.0	375	0.50%	7.8	0.65	1.06	1.12	1.19	
	119	DCB/MH 119 DCB/MH 120		0.07			0.227	15.34	120	107.7	375	0.50%	19.4	0.87	1.13	1.12	1.26	
	120	DCB/MH 120 SQU-100		0.07			0.156	15.60	118	124.9	375	0.50%	8.8	1.01	1.14	1.12	1.28	
STREET A	201	SQU-100 MC-3500		0.07			8.341	17.56	109	907.6	600	8.10%	10.9	0.52	1.00	6.18	6.18	
	202	MC-3500 ST-1005					8.341	17.59	109	906.5	600	2.30%	3.2	0.97	1.14	3.29	3.75	
	203	ST-1005 ST-A6					8.341	17.61	109	906.0	600	11.00%	4.4	0.44	0.97	7.20	6.99	
	204	OUTLET					8.341	17.62	109	905.7	600	0.55%	3.3	1.99	1.14	1.61	1.84	
	A-1W	ST-A6					15.732	21.18	95	1501.7	750	0.40%	59.5	2.13	1.14	1.59	1.82	
SQU-200	201	CB/MH 202		0.10			0.203	15.00	121	24.7	300	5.50%	7.8	0.11	0.65	3.21	2.09	
	202	CB/MH 202 ST-2001		0.19			0.391	15.06	121	72.0	300	1.60%	35.0	0.59	1.03	1.73	1.78	
	203	CB/MH 204		0.10			0.215	15.00	121	26.1	300	0.50%	7.8	0.38	0.94	0.97	0.91	
	204	CB/MH 204 ST-2001		0.16			0.324	15.14	121	65.0	300	0.50%	39.4	0.95	1.14	0.97	1.10	
	A-1W	CB/MH A-3W CB/MH A-3W		0.21			0.430	15.00	121	52.3	300	0.50%	42.8	0.76	1.10	0.97	1.06	
A-2W	CB A-2W CB/MH A-3W		0.31			0.654	15.00	121	79.5	300	2.50%	41.2	0.52	1.00	2.16	2.16		
A-3W	CB/MH A-3W ST-A100W		0.16			1.408	15.32	120	168.6	375	0.50%	28.6	1.36	1.14	1.12	1.28		
A-4W	CB A-3W CB A-4W		0.34			0.705	15.00	121	85.7	300	0.50%	57.0	1.25	1.14	0.97	1.10		
A-5W	CB A-4W ST-A200W ST-A200W		0.12			0.241	15.86	117	110.6	300	0.50%	59.2	1.62	1.14	0.97	1.10		
	BLDG		0.17			0.364	15.00	121	44.3	300	0.50%	2.0	0.65	1.05	0.97	1.02		

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 2 of 5

STORM SEWER DESIGN SHEET

100 Year Storm Event (Q=2.78 AIR, I=46.1 f^{-0.699})

EXTERNAL DRAINAGE AREAS HAIG ROAD INTERNAL AREAS

STREET	LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA							
	FROM	TO	R=0.45	R=0.60	R=0.65	R=0.7						R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q _i) (l/s) n= 0.013	Qp/Qf	Vf (m/s)	Vp (m/s)
BLOCK A (West)	ST-A100W	ST-2001					3.851	16.76	112	433.1	450	0.50%	13.3	201.6	2.15	1.14	1.27	1.45	0.15
	ST-2001	CB/MH 208					3.851	16.91	112	430.3	450	1.10%	54.0	299.0	1.44	1.14	1.88	2.14	0.42
	CB 205	CB/MH 208	0.24				0.493	15.00	121	59.9	300	2.50%	20.2	152.9	0.39	0.95	2.16	2.04	0.16
	CB 206	CB/MH 208	0.11				0.222	15.00	121	27.0	300	1.90%	51.2	133.3	0.20	0.79	1.89	1.49	0.57
	CB 207	CB 207	0.06				0.125	15.00	121	15.2	300	1.00%	7.6	96.7	0.16	0.73	1.37	1.00	0.13
	CB/MH 208	ST-2001	0.25				0.513	17.33	110	571.7	450	1.00%	30.9	285.1	2.01	1.14	1.79	2.04	0.25
	CB 209	ST-2002	0.19				0.392	15.00	121	47.6	300	2.10%	27.4	140.1	0.34	0.90	1.98	1.78	0.26
	ST-2002	ST-2003					5.597	17.58	109	608.5	525	2.00%	8.7	608.2	1.00	1.14	2.81	3.20	0.05
	ST-2003	CB/MH 210					5.597	17.63	109	607.4	525	2.00%	34.2	608.2	1.00	1.14	2.81	3.20	0.18
	CB/MH 210	ST-2004	0.34				6.304	17.80	108	679.4	525	1.60%	35.7	544.0	1.25	1.14	2.51	2.86	0.21
CB 211	CB/MH 212	0.05				0.095	15.00	121	11.6	300	0.50%	7.8	68.4	0.17	0.74	0.97	0.72	0.18	
CB/MH 212	ST-2004	0.11				0.240	15.18	120	40.3	300	0.50%	33.9	68.4	0.59	1.03	0.97	1.00	0.57	
ST-2004	CB/MH 213					6.639	18.01	107	709.7	525	0.50%	11.6	304.1	2.33	1.14	1.40	1.60	0.12	
CB/MH 213	CB/MH 214	0.22				7.105	18.13	106	756.0	525	0.50%	7.6	304.1	2.49	1.14	1.40	1.60	0.08	
CB/MH 214	SQU-200	0.10				0.467	18.13	106	778.2	750	9.50%	8.6	3431.4	0.23	0.81	7.77	6.29	0.02	
SQU-200	MC-3500					7.313	18.21	106	775.8	750	9.50%	5.4	3431.4	0.23	0.81	7.77	6.29	0.01	
MC-3500	ST-2005					7.313	18.23	106	775.4	750	0.10%	2.6	352.0	2.20	1.14	0.80	0.91	0.05	
SQU-300																			
F-1E	CB F-1E		0.10				0.198	15.00	121	24.1	300	2.80%	15.3	161.8	0.15	0.72	2.29	1.65	0.15
F-2E	CB F-4E		0.15				0.310	15.15	121	61.3	300	0.50%	65.1	68.4	0.90	1.13	0.97	1.09	0.99
F-3E	CB F-4E		0.05				0.106	15.00	121	12.8	300	6.50%	15.4	246.5	0.05	0.53	3.49	1.85	0.14
F-4E	ST-3001		0.23				0.472	16.15	115	125.3	300	0.50%	31.2	68.4	1.83	1.14	0.97	1.10	0.47
F-5E	ST-3001		0.08				0.162	15.00	121	19.7	300	2.10%	32.9	140.1	0.14	0.72	1.98	1.43	0.38
301	CB 301		0.07				0.147	15.00	121	17.8	300	0.50%	2.4	68.4	0.26	0.86	0.97	0.83	0.05
BLOCK F (East)	ST-3001	CB/MH 303					1.395	16.62	113	157.8	375	0.50%	15.6	124.0	1.27	1.14	1.12	1.28	0.20
302	CB 302		0.36				0.749	15.00	121	91.0	300	0.50%	43.8	68.4	1.33	1.14	0.97	1.10	0.66
303	CB/MH 303	ST-3002	0.14				2.427	16.82	112	272.2	375	0.50%	56.4	124.0	2.20	1.14	1.12	1.28	0.73
304	ST-3002	CB/MH 306					2.427	17.56	109	264.2	375	0.50%	10.4	124.0	2.13	1.14	1.12	1.28	0.14
305	CB 304	CB/MH 306	0.17				0.363	15.00	121	44.2	300	6.80%	7.8	252.2	0.18	0.76	3.57	2.71	0.05
306	CB/MH 306	CB 305	0.08				0.170	15.00	121	20.7	300	7.40%	6.8	263.1	0.08	0.59	3.72	2.20	0.05
307	CB/MH 310	CB/MH 310	0.14				3.252	17.69	108	352.0	450	0.70%	56.3	238.5	1.48	1.14	1.50	1.71	0.55
308	CB 308	CB/MH 310	0.09				0.195	15.00	121	23.7	300	7.30%	6.1	261.3	0.09	0.64	3.70	2.37	0.04
309	CB 309	CB/MH 310	0.06				0.119	15.00	121	14.4	300	7.80%	7.8	270.1	0.05	0.53	3.82	2.02	0.06
310	CB/MH 310	CB 309	0.07				0.156	15.00	121	19.0	300	0.50%	7.0	68.4	0.28	0.86	0.97	0.83	0.14
311	CB/MH 312	CB/MH 312	0.08				3.891	18.24	106	412.3	450	0.50%	61.5	201.6	2.05	1.14	1.27	1.45	0.71
312	CB 311	CB/MH 312	0.06				0.131	15.00	121	15.9	300	0.50%	7.8	68.4	0.23	0.82	0.97	0.79	0.16
	CB/MH 312	ST-3003	0.11				4.242	18.95	103	437.6	450	0.50%	9.2	201.6	2.17	1.14	1.27	1.45	0.11

PREPARED BY: SDS

DATE: December 12, 2023
REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 3 of 5

STORM SEWER DESIGN SHEET

100 Year Storm Event (Q=2.78 AIR, I=46.1 f^{-0.699})

EXTERNAL DRAINAGE AREAS
HAIG ROAD
INTERNAL AREAS

STREET	LOCATION		AREAS (ha)				Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA								
	FROM	TO	R=0.45	R=0.60	R=0.65	R=0.7						R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q _r) (l/s) n= 0.013	Qp/Qf	Vp/Vf	Vp (m/s)	TIME of FLOW (min)
313	ST-3003 CB 313	CB/MH 314 CB/MH 314					0.196	4.242	19.06	103	435.9	450	0.50%	29.2	201.6	2.16	1.14	1.27	1.45	0.34
314	CB/MH 314 CB 315	CB/MH 320 DCB/MH 316		0.09			0.137	0.196	15.00	121	23.8	300	0.50%	7.8	68.4	0.35	0.91	0.97	0.88	0.15
315	CB 315	DCB/MH 316		0.15			0.321	4.574	19.39	102	464.4	525	0.50%	38.6	304.1	1.53	1.14	1.40	1.60	0.40
316	DCB/MH 316 CB/MH 317	CB/MH 317 CB/MH 320		0.20			0.415	0.321	15.00	121	39.0	300	1.90%	26.2	133.3	0.29	0.88	1.89	1.65	0.26
317	CB/MH 317 CB 318	CB/MH 320 CB 319		0.24			0.500	0.736	15.26	120	88.4	375	1.70%	34.2	228.6	0.39	0.94	2.07	1.95	0.29
318	CB 318	CB 319		0.06			0.124	1.237	15.56	118	146.5	375	2.00%	35.7	248.0	1.03	2.25	2.31	0.26	0.26
319	CB 319	CB/MH 320		0.07			0.143	0.124	15.00	121	15.0	300	0.50%	13.4	68.4	0.22	0.81	0.97	0.78	0.29
320	CB/MH 320	DCB/MH 321		0.09			0.190	0.267	15.29	120	32.0	375	0.50%	7.8	124.0	0.26	0.84	1.12	0.94	0.14
321	DCB/MH 321	DCB/MH 322		0.19			0.397	6.268	19.79	100	627.3	525	0.50%	40.0	304.1	2.06	1.14	1.40	1.60	0.42
322	DCB/MH 322 SQU-300	SQU-300 ST-2005		0.10			0.218	6.665	20.21	99	657.4	525	0.50%	7.8	304.1	2.16	1.14	1.40	1.60	0.08
	SQU-300	ST-2005		0.10			0.218	6.665	20.29	98	673.5	750	9.40%	9.4	3413.2	0.19	0.78	7.73	6.03	0.03
	ST-2005	OUTLET		0.10			0.218	6.883	20.44	98	673.5	750	0.10%	9.4	352.0	1.91	1.14	0.80	0.91	0.17
								14.196	20.61	97	1381.1	750	0.355%	7.9	658.6	2.10	1.14	1.49	1.70	0.08

PREPARED BY: SDS

DATE: December 12, 2023

REV: December 13, 2024

van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE

2255718 Ontario Inc. - OWNER

Sheet 4 of 5

STORM SEWER DESIGN SHEET

100 Year Storm Event (Q=2.78 AIR, I=46.1 f^{-0.699})

EXTERNAL DRAINAGE AREAS HAIG ROAD INTERNAL AREAS

LOCATION		AREAS (ha)			Indiv. 2.78AR	Accum. 2.78AR	Time of Conc. min.	Rainfall Intensity I (mm/hr)	Peak Flow Q _p (l/s)	SEWER DATA									
STREET	FROM	TO	R=0.45	R=0.60						R=0.65	R=0.7	R=0.85	DIA. (mm)	SLOPE (%)	LENGTH (m)	CAPACITY (Q ₁) (l/s) n= 0.013	Vp/Vf	Vf (m/s)	TIME of FLOW (min)
SQU-400	401	CB 401	ST-4001				0.366	15.00	121	44.5	300	0.50%	67.6	0.65	1.06	0.97	1.03	1.10	
	402	CB 402	CB 403	0.18			0.231	15.00	121	28.0	300	0.50%	31.7	0.41	0.95	0.97	0.92	0.57	
	403	CB 403	ST-4001	0.22			0.449	15.57	118	80.4	300	0.60%	16.1	1.07	1.14	1.06	1.21	0.22	
	404	ST-4001	CB/MH 406				1.045	15.80	117	122.5	300	1.10%	23.3	1.21	1.14	1.43	1.64	0.24	
	405	CB 404	CB 405	0.17			0.350	15.00	121	42.5	300	1.00%	31.3	0.44	0.97	1.37	1.32	0.40	
	406	CB 405	CB/MH 406	0.16			0.331	15.40	119	81.3	300	0.50%	19.4	1.19	1.14	0.97	1.10	0.29	
	407	CB/MH 406	CB/MH 408	0.22			2.195	16.03	116	254.6	375	0.75%	33.2	1.68	1.14	1.37	1.57	0.35	
	408	CB 407	CB/MH 408	0.10			0.211	15.00	121	25.7	300	3.70%	47.2	0.14	0.71	2.63	1.87	0.42	
SQU-500	501	CB/MH 408	SQU-400	0.08			0.175	16.39	114	294.8	450	11.50%	6.0	0.30	0.88	6.08	5.35	0.02	
	502	SQU-400	MC-3500				2.581	16.41	114	294.6	450	0.50%	13.7	201.6	1.46	1.14	1.27	0.16	
	503	MC-3500	ST-4002				2.581	16.56	113	292.6	450	1.00%	5.4	285.1	1.03	1.14	1.79	0.04	
	504	ST-4002	OUTLET				2.581	16.61	113	292.0	450	3.10%	33.3	502.0	0.58	1.03	3.16	0.17	
	501	CB 501	SQU-500	0.31			0.655	15.00	121	79.5	450	1.80%	45.0	0.21	0.79	2.41	1.90	0.39	
	502	CB 502	CB 503	0.27			0.565	15.00	121	68.7	300	0.50%	52.5	0.84	1.00	1.14	0.97	1.10	
	503	CB 503	CB/MH 504	0.10			0.209	15.79	117	90.8	300	0.50%	32.2	68.4	1.33	1.14	0.97	1.10	
	504	CB/MH 504	SQU-500	0.19			0.397	16.28	115	209.6	450	4.10%	15.6	577.3	0.36	0.92	3.63	0.08	
SQU-600	601	SQU-500	MC-3500				1.827	16.36	114	208.9	450	0.45%	4.5	191.3	1.09	1.14	1.20	0.05	
	602	MC-3500	ST-5001				1.827	16.41	114	208.4	450	14.40%	2.3	1081.9	0.19	0.78	6.80	0.01	
	603	ST-5001	OUTLET				1.827	16.42	114	208.3	450	0.35%	9.1	168.7	1.24	1.14	1.06	0.13	
	601	CB 601	ST-6001	0.07			0.139	15.00	121	16.9	300	0.50%	7.6	0.25	0.83	0.97	0.80	0.16	
	602	CB 602	ST-6001	0.26			0.543	15.00	121	66.0	300	0.50%	3.1	68.4	0.97	1.14	0.97	1.10	
	603	ST-6001	DCB 603				0.682	15.16	121	82.3	300	0.50%	51.6	68.4	1.20	1.14	0.97	1.10	
	603	DCB 603	SQU-600	0.45			1.612	15.94	116	187.7	450	5.40%	9.6	662.5	0.28	0.87	4.17	0.04	
	603	SQU-600	MC-3500				1.612	15.98	116	187.3	450	0.50%	4.0	201.6	0.93	1.14	1.27	0.05	
PROPOSED INFORMATION		EXISTING INFORMATION		Shown in VERTICAL TEXT Shown in ITALIZED TEXT															

PREPARED BY: SDS

DATE: December 12, 2023
REV: December 13, 2024


van MEER limited

621 DUNDAS STREET EAST
CITY of BELLEVILLE
2255718 Ontario Inc. - OWNER

Sheet 5 of 5

REVISIONS	
Date	Description
DEC. 12/24	REVISED SITE LAYOUT FROM ARCHITECT 24-02-05
JAN. 02/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-17
JAN. 02/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-04
DEC. 20/23	INTERLAY 23-12-15 SITE LAYOUT FROM ARCHITECT
NOV. 02/23	REVISED SITE LAYOUT FROM ARCHITECT
By: Cmk D By	
S.D.S.	

SCALE: 1:250
 DESIGNER: A.H.V.
 DRAWN: S.D.S.
 DATE: 1/07
 COMPUTER: V:\projects\621 Dundas Street East\621-12-05.dwg






STORM SEWER DESIGN
 DRAWING Dnr/621-SH
 DRAWING: 621 Dundas St. 24-12-05.dwg



DATE	DESCRIPTION	BY	CHK'D BY
DEC. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-02-05	S.O.S.	
JAN. 8/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-17	S.O.S.	
JAN. 8/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.O.S.	
DEC. 20/23	UNDERWAY 23-21-25 SITE LAYOUT FROM ARCHITECT	S.O.S.	
NOV. 8/23	REVISED SITE LAYOUT FROM ARCHITECT	S.O.S.	

SCALE: 1/2500
 DESIGNER: A.H.V.
 DRAWN: S.O.S.
 DATE: 1/07
 COMPUTER: DUNDAS STREET EAST BELLEVILLE PROPERTY



Active coordinate

44° 9' 45" N, 77° 23' 15" W (44.162500,-77.387500)

Retrieved: Wed, 13 Dec 2023 16:28:41 GMT




Location summary

These are the locations in the selection.

IDF Curve: 44° 9' 45" N, 77° 23' 15" W (44.162500,-77.387500)

Results

An IDF curve was found.



Coefficient summary

IDF Curve: 44° 9' 45" N, 77° 23' 15" W (44.162500,-77.387500)

Retrieved: Wed, 13 Dec 2023 16:28:41 GMT

Data year: 2010

IDF curve year: 2010

Return period	2-yr	5-yr	10-yr	25-yr	50-yr	100-yr
A	20.9	27.7	32.1	37.8	41.9	46.1
B	-0.699	-0.699	-0.699	-0.699	-0.699	-0.699

Statistics

Rainfall intensity (mm hr⁻¹)

Duration	5-min	10-min	15-min	30-min	1-hr	2-hr	6-hr	12-hr	24-hr
2-yr	118.7	73.1	55.1	33.9	20.9	12.9	6.0	3.7	2.3
5-yr	157.3	96.9	73.0	45.0	27.7	17.1	7.9	4.9	3.0
10-yr	182.3	112.3	84.6	52.1	32.1	19.8	9.2	5.7	3.5
25-yr	214.7	132.3	99.6	61.4	37.8	23.3	10.8	6.7	4.1
50-yr	238.0	146.6	110.4	68.0	41.9	25.8	12.0	7.4	4.5
100-yr	261.8	161.3	121.5	74.8	46.1	28.4	13.2	8.1	5.0

Rainfall depth (mm)

Duration	5-min	10-min	15-min	30-min	1-hr	2-hr	6-hr	12-hr	24-hr
2-yr	9.9	12.2	13.8	17.0	20.9	25.7	35.8	44.2	54.4
5-yr	13.1	16.2	18.2	22.5	27.7	34.1	47.5	58.5	72.1
10-yr	15.2	18.7	21.1	26.1	32.1	39.5	55.0	67.8	83.6
25-yr	17.9	22.0	24.9	30.7	37.8	46.6	64.8	79.9	98.4
50-yr	19.8	24.4	27.6	34.0	41.9	51.6	71.9	88.5	109.1
100-yr	21.8	26.9	30.4	37.4	46.1	56.8	79.1	97.4	120.0



APPENDIX E

Stormwater Management – Design

Storm Sewer Design	Drawing DUN/621-St3
Pre-development Overland Flow Route 100yr Storm Event	
Storm Sewer Design	Drawing DUN/621-St4
Post-development Overland Flow Route 100yr Storm Event	
Storm Sewer Design Sheets – Imperviousness and Tc / Flow Calculations	
MOE Quality Event Calculations	
Summary of TSS Removal of Quality Treatment Units (Downstream Defender)	
Hydro International Downstream Defender Sizing	
Hydro International Downstream Defender Operation & Maintenance Manual	

REVISIONS	
Date	Description
DEC 12/24	REVISED SITE LAYOUT FROM ARCHITECT 24-2-05
JAN 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-0-17
JAN 8/24	REVISED SITE LAYOUT FROM ARCHITECT 24-0-14
DEC 20/23	LANDSLAY 23-10-15 SITE LAYOUT FROM ARCHITECT
NOV 8/23	REVISED SITE LAYOUT FROM ARCHITECT

SCALE: 1:2000
 DRAWN: S.D.S.
 DATE: 07/2023
 COMPUTER: UNKOWN STREET BELLEVILLE PROPERTY



STORM SEWER DESIGN SHEET
T_c / FLOW CALCULATIONS

Subcatchment - Haig Rd, Series 100, 200 & 300

<u>5yr Storm Event</u>					<u>100yr Storm Event</u>				
Runoff Coefficient (R)	0.606	0.2	0.6	0.9	Runoff Coefficient (R)	0.657	0.2	0.6	0.9
Area (A)	15.959	4.192	5.880	5.887	Area (A)	15.959	4.192	5.880	5.887
RA	9.665	0.838	3.528	5.298	RA	10.492	1.048	4.410	5.033
<u>Bransby-Williams Formula</u>					<u>Bransby-Williams Formula</u>				
(C values of 0.4 or greater)					(C values of 0.4 or greater)				
Elev _H =	86.30				Elev _H =	86.30			
Elev _L =	75.90				Elev _L =	75.90			
A (ha) =	15.959				A (ha) =	15.959			
C =	0.606				C =	0.657			
L =	1080				L =	1080			
S _w =	0.96%				S _w =	0.96%			
T _c =	47.02				T _c =	47.02			
I =	31				I =	51			
Q _p =	836.60				Q _p =	1479.57			

Subcatchment - 400

<u>5yr Storm Event</u>					<u>100yr Storm Event</u>				
Runoff Coefficient (R)	0.601	0.2	0.6	0.9	Runoff Coefficient (R)	0.597	0.2	0.6	0.9
Area (A)	6.654	2.839		3.814	Area (A)	6.654	2.839	0.000	3.814
RA	4.001	0.568	0.000	3.433	RA	3.971	0.710	0.000	3.261
<u>Bransby-Williams Formula</u>					<u>Bransby-Williams Formula</u>				
(C values of 0.4 or greater)					(C values of 0.4 or greater)				
Elev _H =	84.10				Elev _H =	84.10			
Elev _L =	75.90				Elev _L =	75.90			
A (ha) =	6.654				A (ha) =	6.654			
C =	0.601				C =	0.597			
L =	555				L =	555			
S _w =	1.48%				S _w =	1.48%			
T _c =	24.21				T _c =	24.21			
I =	49				I =	80			
Q _p =	542.82				Q _p =	878.38			

Subcatchment - 500

<u>5yr Storm Event</u>					<u>100yr Storm Event</u>				
Runoff Coefficient (R)	0.617	0.2	0.6	0.9	Runoff Coefficient (R)	0.611	0.2	0.6	0.9
Area (A)	1.238	0.500		0.738	Area (A)	1.238	0.500	0.000	0.738
RA	0.764	0.100	0.000	0.664	RA	0.756	0.125	0.000	0.631
<u>Bransby-Williams Formula</u>					<u>Bransby-Williams Formula</u>				
(C values of 0.4 or greater)					(C values of 0.4 or greater)				
Elev _H =	80.30				Elev _H =	80.30			
Elev _L =	75.95				Elev _L =	75.95			
A (ha) =	1.238				A (ha) =	1.238			
C =	0.617				C =	0.611			
L =	208				L =	208			
S _w =	2.09%				S _w =	2.09%			
T _c =	10.01				T _c =	10.01			
I =	89				I =	145			
Q _p =	188.45				Q _p =	304.20			

Subcatchment - 600

<u>5yr Storm Event</u>					<u>100yr Storm Event</u>				
Runoff Coefficient (R)	0.645	0.2	0.6	0.9	Runoff Coefficient (R)	0.635	0.2	0.6	0.9
Area (A)	0.876	0.319		0.557	Area (A)	0.876	0.319	0.000	0.557
RA	0.565	0.064	0.000	0.502	RA	0.556	0.080	0.000	0.476
<u>Bransby-Williams Formula</u>					<u>Bransby-Williams Formula</u>				
(C values of 0.4 or greater)					(C values of 0.4 or greater)				
Elev _H =	78.10				Elev _H =	78.10			
Elev _L =	76.10				Elev _L =	76.10			
A (ha) =	0.876				A (ha) =	0.876			
C =	0.645				C =	0.635			
L =	150				L =	150			
S _w =	1.33%				S _w =	1.33%			
T _c =	8.18				T _c =	8.18			
I =	102				I =	166			
Q _p =	159.89				Q _p =	256.73			

Subcatchment - 500

<u>5yr Storm Event</u>					<u>100yr Storm Event</u>				
Runoff Coefficient (R)	0.666	0.2	0.6	0.9	Runoff Coefficient (R)	0.653	0.2	0.6	0.9
Area (A)	0.773	0.258		0.515	Area (A)	0.773	0.258	0.000	0.515
RA	0.515	0.052	0.000	0.463	RA	0.505	0.065	0.000	0.440
<u>Bransby-Williams Formula</u>					<u>Bransby-Williams Formula</u>				
(C values of 0.4 or greater)					(C values of 0.4 or greater)				
Elev _H =	79.10				Elev _H =	79.10			
Elev _L =	76.10				Elev _L =	76.10			
A (ha) =	0.773				A (ha) =	0.773			
C =	0.666				C =	0.653			
L =	175				L =	175			
S _w =	1.71%				S _w =	1.71%			
T _c =	9.19				T _c =	9.19			
I =	94				I =	153			
Q _p =	134.60				Q _p =	215.28			

STORM SEWER DESIGN

MOE QUALITY EVENT CALCULATIONS

$$Q = \frac{CiA}{360}$$

Equation 4.8: Rational Method

where
 Q = peak flow rate (m³/s)
 C = runoff coefficient
 I = rainfall intensity (mm/hr)
 A = drainage area (ha)

$$i = 43C + 5.9$$

Equation 4.9: 25 mm Storm Intensity

where
 I = rainfall intensity mm/hr
 C = runoff coefficient

	<u>AREA</u>	<u>C</u>	<u>i</u>	<u>Q (L/s)</u>
SQU-100	3.58	0.62	32.6	200.5
SQU-200	3.35	0.60	31.7	177.1
SQU-300	3.35	0.62	32.6	188.0
SQU-400	1.24	0.62	32.6	69.4
SQU 500	1.08	0.65	33.9	65.8
SQU-600	0.77	0.67	34.7	49.9



ADS Treatment Train Sizing

Project Name:	Dundas St SQU100	
Consulting Engineer:	vanMEER limited	
Location:	Belleville, Ontario	
Sizing Completed By:	Haider Nasrullah	Email: haider.nasrullah@ads-pipe.com

Summary of Results	
Isolator Row PLUS TSS Removal:	80.2%
DD10 TSS Removal:	59.0%
Combined TSS Removal:	91.8%
Total Volume Treated:	>90%

Individual OGS Results		
Model	TSS Removal	Volume Treated
DD4	31.0%	>90%
DD6	46.0%	>90%
DD8	55.0%	>90%
DD10	59.0%	>90%
DD12	62.0%	>90%

Overall System Capacities	
Total Sediment Storage Capacity:	19.45 m ³
Oil Storage Capacity:	3,975 L
Max. OGS Pipe Diameter:	750 mm
Peak OGS Flow Capacity:	708 L/s
Peak Isolator Row PLUS Flowrate:	167.9 L/s

OGS Specifications	
Unit Diameter (A):	3,000 mm
Inlet Pipe Diameter (B):	600 mm
Outlet Pipe Diameter (C):	600 mm
Top of Grade Elevation:	0.00 m
Bottom of Sump Elevation:	-2.85 m
Inlet Pipe Elevation:	0.00 m
Outlet Pipe Elevation:	0.00 m

Notes:

Isolator Row PLUS removal efficiency based on verified ETV test report. For dimensions and configuration of Isolator Row PLUS, please see Stormtech drawing package.


Site Details	
Site Area (ha):	3.58
Rational C:	0.62
Particle Size Distribution:	ETV
Rainfall Station:	Belleville, ONT

Note: Isolator Row PLUS removal efficiencies based solely on ETV/NJDEP PSD, above-noted PSD is for OGS sizing only

Stormtech Details	
Chamber Model:	MC-3500
No. Chambers in Isolator Row PLUS:	15
Volume Treated by Isolator Row PLUS:	>90%

Notes: Refer to Stormtech drawings for full IR+ configuration.

Isolator Row PLUS must include Flared End Ramp (FLAMP) for proper performance.





Project Name:

Dundas St SQU100

Consulting Engineer:

vanMEER limited

Location:

Belleville, Ontario

Net Annual Removal Efficiency Summary

Rainfall Intensity	Fraction of Rainfall	Removal Efficiency		Combined Removal Efficiency	Combined Weighted Removal Efficiency
		DD10	IR PLUS		
mm/hr	%	%	%	%	%
0.50	0.4%	68.8%	81.2%	94.1%	0.4%
1.00	13.2%	67.6%	81.2%	93.9%	12.4%
1.50	14.0%	66.4%	81.2%	93.7%	13.1%
2.00	14.0%	65.2%	81.2%	93.5%	13.0%
2.50	3.6%	64.1%	81.2%	93.2%	3.3%
3.00	2.5%	63.0%	81.2%	93.0%	2.4%
3.50	8.4%	61.9%	81.2%	92.8%	7.8%
4.00	5.1%	60.8%	81.2%	92.6%	4.7%
4.50	1.6%	59.7%	81.2%	92.4%	1.5%
5.00	5.1%	58.7%	81.2%	92.2%	4.7%
6.00	4.8%	56.7%	81.2%	91.9%	4.4%
7.00	4.5%	54.7%	81.2%	91.5%	4.1%
8.00	3.5%	52.8%	81.2%	91.1%	3.2%
9.00	2.4%	51.0%	81.2%	90.8%	2.2%
10.00	2.5%	49.2%	81.2%	90.5%	2.3%
20.00	9.7%	42.9%	81.2%	89.3%	8.6%
30.00	2.8%	42.9%	73.7%	85.0%	2.4%
40.00	0.9%	42.9%	55.3%	74.5%	0.7%
50.00	0.4%	42.9%	44.2%	68.2%	0.3%
100.00	0.6%	42.9%	22.1%	55.5%	0.3%
150.00	0.1%	42.9%	14.7%	51.3%	0.0%
200.00	0.0%	42.9%	11.1%	49.2%	0.0%
Total Net Annual Removal Efficiency					91.8%
Total Runoff Volume Treated					>90%

Notes:

- (1) Rainfall Data: 1960:2007, HLY03, Belleville, ONT, 6150700 & 6150689.
- (2) Canada ETV PSD & Test Protocols - ISO14034 Certified
- (3) actored to account for bypass flow.
- (4) Combined removal efficiencies calculated based on NCDENR Stormwater BMP Manual, Section 3.9.4, where
 Total Removal Efficiency = 1st BMP Efficiency + 2nd BMP Efficiency - (1st BMP Efficiency x 2nd BMP Efficiency)



ADS Treatment Train Sizing

Project Name:	Dundas St SQU200	
Consulting Engineer:	vanMEER limited	
Location:	Belleville, Ontario	
Sizing Completed By:	Haider Nasrullah	Email: haider.nasrullah@ads-pipe.com

Summary of Results	
Isolator Row PLUS TSS Removal:	80.5%
DD10 TSS Removal:	60.0%
Combined TSS Removal:	92.1%
Total Volume Treated:	>90%

Individual OGS Results		
Model	TSS Removal	Volume Treated
DD4	32.0%	>90%
DD6	48.0%	>90%
DD8	55.0%	>90%
DD10	60.0%	>90%
DD12	63.0%	>90%

Overall System Capacities	
Total Sediment Storage Capacity:	19.45 m ³
Oil Storage Capacity:	3,975 L
Max. OGS Pipe Diameter:	750 mm
Peak OGS Flow Capacity:	708 L/s
Peak Isolator Row PLUS Flowrate:	167.9 L/s

OGS Specifications	
Unit Diameter (A):	3,000 mm
Inlet Pipe Diameter (B):	600 mm
Outlet Pipe Diameter (C):	600 mm
Top of Grade Elevation:	0.00 m
Bottom of Sump Elevation:	-2.85 m
Inlet Pipe Elevation:	0.00 m
Outlet Pipe Elevation:	0.00 m

Notes:

Isolator Row PLUS removal efficiency based on verified ETV test report. For dimensions and configuration of Isolator Row PLUS, please see Stormtech drawing package.


Site Details	
Site Area (ha):	3.35
Rational C:	0.60
Particle Size Distribution:	ETV
Rainfall Station:	Belleville, ONT

Note: Isolator Row PLUS removal efficiencies based solely on ETV/NJDEP PSD, above-noted PSD is for OGS sizing only

Stormtech Details	
Chamber Model:	MC-3500
No. Chambers in Isolator Row PLUS:	15
Volume Treated by Isolator Row PLUS:	>90%

Notes: Refer to Stormtech drawings for full IR+ configuration.

Isolator Row PLUS must include Flared End Ramp (FLAMP) for proper performance.





ADS Treatment Train Sizing

Project Name:	Dundas St SQU300	
Consulting Engineer:	vanMEER limited	
Location:	Belleville, Ontario	
Sizing Completed By:	Haider Nasrullah	Email: haider.nasrullah@ads-pipe.com

Summary of Results	
Isolator Row PLUS TSS Removal:	80.4%
DD10 TSS Removal:	60.0%
Combined TSS Removal:	92.0%
Total Volume Treated:	>90%

Individual OGS Results		
Model	TSS Removal	Volume Treated
DD4	32.0%	>90%
DD6	47.0%	>90%
DD8	55.0%	>90%
DD10	60.0%	>90%
DD12	63.0%	>90%

Overall System Capacities	
Total Sediment Storage Capacity:	19.45 m ³
Oil Storage Capacity:	3,975 L
Max. OGS Pipe Diameter:	750 mm
Peak OGS Flow Capacity:	708 L/s
Peak Isolator Row PLUS Flowrate:	167.9 L/s

OGS Specifications	
Unit Diameter (A):	3,000 mm
Inlet Pipe Diameter (B):	600 mm
Outlet Pipe Diameter (C):	600 mm
Top of Grade Elevation:	0.00 m
Bottom of Sump Elevation:	-2.85 m
Inlet Pipe Elevation:	0.00 m
Outlet Pipe Elevation:	0.00 m

Notes:

Isolator Row PLUS removal efficiency based on verified ETV test report. For dimensions and configuration of Isolator Row PLUS, please see Stormtech drawing package.


Site Details	
Site Area (ha):	3.35
Rational C:	0.61
Particle Size Distribution:	ETV
Rainfall Station:	Belleville, ONT

Note: Isolator Row PLUS removal efficiencies based solely on ETV/NJDEP PSD, above-noted PSD is for OGS sizing only

Stormtech Details	
Chamber Model:	MC-3500
No. Chambers in Isolator Row PLUS:	15
Volume Treated by Isolator Row PLUS:	>90%

Notes: Refer to Stormtech drawings for full IR+ configuration.

Isolator Row PLUS must include Flared End Ramp (FLAMP) for proper performance.





ADS Treatment Train Sizing

Project Name:	Dundas St SQU400	
Consulting Engineer:	vanMEER limited	
Location:	Belleville, Ontario	
Sizing Completed By:	Haider Nasrullah	Email: haider.nasrullah@ads-pipe.com

Summary of Results

Isolator Row PLUS TSS Removal:	80.5%
DD6 TSS Removal:	58.0%
Combined TSS Removal:	91.5%
Total Volume Treated:	>90%

Individual OGS Results

Model	TSS Removal	Volume Treated
DD4	47.0%	>90%
DD6	58.0%	>90%
DD8	62.0%	>90%
DD10	65.0%	>90%
DD12	66.0%	>90%

Overall System Capacities

Total Sediment Storage Capacity:	6.71 m ³
Oil Storage Capacity:	818 L
Max. OGS Pipe Diameter:	450 mm
Peak OGS Flow Capacity:	227 L/s
Peak Isolator Row PLUS Flowrate:	67.1 L/s

OGS Specifications

Unit Diameter (A):	1,800 mm
Inlet Pipe Diameter (B):	600 mm
Outlet Pipe Diameter (C):	600 mm
Top of Grade Elevation:	0.00 m
Bottom of Sump Elevation:	-1.80 m
Inlet Pipe Elevation:	0.00 m
Outlet Pipe Elevation:	0.00 m

Notes:

Isolator Row PLUS removal efficiency based on verified ETV test report. For dimensions and configuration of Isolator Row PLUS, please see Stormtech drawing package.

Site Details

Site Area (ha):	1.24
Rational C:	0.62
Particle Size Distribution:	ETV
Rainfall Station:	Belleville, ONT


Note: Isolator Row PLUS removal efficiencies based solely on ETV/NJDEP PSD, above-noted PSD is for OGS sizing only

Stormtech Details

Chamber Model:	MC-3500
No. Chambers in Isolator Row PLUS:	6
Volume Treated by Isolator Row PLUS:	>90%

Notes: Refer to Stormtech drawings for full IR+ configuration.

Isolator Row PLUS must include Flared End Ramp (FLAMP) for proper performance.





Project Name:

Dundas St SQU400

Consulting Engineer:

vanMEER limited

Location:

Belleville, Ontario

Net Annual Removal Efficiency Summary

Rainfall Intensity	Fraction of Rainfall	Removal Efficiency		Combined Removal Efficiency	Combined Weighted Removal Efficiency
		DD6	IR PLUS		
mm/hr	%	%	%	%	%
0.50	0.4%	68.8%	81.2%	94.1%	0.4%
1.00	13.2%	67.6%	81.2%	93.9%	12.4%
1.50	14.0%	66.5%	81.2%	93.7%	13.1%
2.00	14.0%	65.4%	81.2%	93.5%	13.0%
2.50	3.6%	64.3%	81.2%	93.3%	3.3%
3.00	2.5%	63.2%	81.2%	93.1%	2.4%
3.50	8.4%	62.1%	81.2%	92.9%	7.8%
4.00	5.1%	61.1%	81.2%	92.7%	4.7%
4.50	1.6%	60.1%	81.2%	92.5%	1.5%
5.00	5.1%	59.1%	81.2%	92.3%	4.7%
6.00	4.8%	57.1%	81.2%	91.9%	4.4%
7.00	4.5%	55.2%	81.2%	91.6%	4.1%
8.00	3.5%	53.3%	81.2%	91.2%	3.2%
9.00	2.4%	51.6%	81.2%	90.9%	2.2%
10.00	2.5%	49.8%	81.2%	90.6%	2.3%
20.00	9.7%	35.5%	81.2%	87.9%	8.5%
30.00	2.8%	25.3%	81.2%	86.0%	2.4%
40.00	0.9%	18.0%	63.8%	70.3%	0.7%
50.00	0.4%	17.9%	51.1%	59.8%	0.3%
100.00	0.6%	17.9%	25.5%	38.9%	0.2%
150.00	0.1%	17.9%	17.0%	31.9%	0.0%
200.00	0.0%	17.9%	12.8%	28.4%	0.0%
Total Net Annual Removal Efficiency					91.5%
Total Runoff Volume Treated					>90%

Notes:

- (1) Rainfall Data: 1960:2007, HLY03, Belleville, ONT, 6150700 & 6150689.
- (2) Canada ETV PSD & Test Protocols - ISO14034 Certified
- (3) actored to account for bypass flow.
- (4) Combined removal efficiencies calculated based on NCDENR Stormwater BMP Manual, Section 3.9.4, where
 Total Removal Efficiency = 1st BMP Efficiency + 2nd BMP Efficiency - (1st BMP Efficiency x 2nd BMP Efficiency)



ADS Treatment Train Sizing

Project Name:	Dundas St SQU500	
Consulting Engineer:	vanMEER limited	
Location:	Belleville, Ontario	
Sizing Completed By:	Haider Nasrullah	Email: haider.nasrullah@ads-pipe.com

Summary of Results

Isolator Row PLUS TSS Removal:	80.1%
DD6 TSS Removal:	58.0%
Combined TSS Removal:	91.2%
Total Volume Treated:	>90%

Individual OGS Results

Model	TSS Removal	Volume Treated
DD4	47.0%	>90%
DD6	58.0%	>90%
DD8	62.0%	>90%
DD10	65.0%	>90%
DD12	66.0%	>90%

Overall System Capacities

Total Sediment Storage Capacity:	5.91 m ³
Oil Storage Capacity:	818 L
Max. OGS Pipe Diameter:	450 mm
Peak OGS Flow Capacity:	227 L/s
Peak Isolator Row PLUS Flowrate:	56 L/s

OGS Specifications

Unit Diameter (A):	1,800 mm
Inlet Pipe Diameter (B):	600 mm
Outlet Pipe Diameter (C):	600 mm
Top of Grade Elevation:	0.00 m
Bottom of Sump Elevation:	-1.80 m
Inlet Pipe Elevation:	0.00 m
Outlet Pipe Elevation:	0.00 m

Notes:

Isolator Row PLUS removal efficiency based on verified ETV test report. For dimensions and configuration of Isolator Row PLUS, please see Stormtech drawing package.

Site Details

Site Area (ha):	1.24
Rational C:	0.62
Particle Size Distribution:	ETV
Rainfall Station:	Belleville, ONT


Note: Isolator Row PLUS removal efficiencies based solely on ETV/NJDEP PSD, above-noted PSD is for OGS sizing only

Stormtech Details

Chamber Model:	MC-3500
No. Chambers in Isolator Row PLUS:	5
Volume Treated by Isolator Row PLUS:	>90%

Notes: Refer to Stormtech drawings for full IR+ configuration.

Isolator Row PLUS must include Flared End Ramp (FLAMP) for proper performance.





Project Name:

Dundas St SQU500

Consulting Engineer:

vanMEER limited

Location:

Belleville, Ontario

Net Annual Removal Efficiency Summary

Rainfall Intensity	Fraction of Rainfall	Removal Efficiency		Combined Removal Efficiency	Combined Weighted Removal Efficiency
		DD6	IR PLUS		
mm/hr	%	%	%	%	%
0.50	0.4%	68.8%	81.2%	94.1%	0.4%
1.00	13.2%	67.6%	81.2%	93.9%	12.4%
1.50	14.0%	66.5%	81.2%	93.7%	13.1%
2.00	14.0%	65.4%	81.2%	93.5%	13.0%
2.50	3.6%	64.3%	81.2%	93.3%	3.3%
3.00	2.5%	63.2%	81.2%	93.1%	2.4%
3.50	8.4%	62.1%	81.2%	92.9%	7.8%
4.00	5.1%	61.1%	81.2%	92.7%	4.7%
4.50	1.6%	60.1%	81.2%	92.5%	1.5%
5.00	5.1%	59.1%	81.2%	92.3%	4.7%
6.00	4.8%	57.1%	81.2%	91.9%	4.4%
7.00	4.5%	55.2%	81.2%	91.6%	4.1%
8.00	3.5%	53.3%	81.2%	91.2%	3.2%
9.00	2.4%	51.6%	81.2%	90.9%	2.2%
10.00	2.5%	49.8%	81.2%	90.6%	2.3%
20.00	9.7%	35.5%	81.2%	87.9%	8.5%
30.00	2.8%	25.3%	70.9%	78.3%	2.2%
40.00	0.9%	18.0%	53.2%	61.6%	0.6%
50.00	0.4%	17.9%	42.5%	52.8%	0.2%
100.00	0.6%	17.9%	21.3%	35.4%	0.2%
150.00	0.1%	17.9%	14.2%	29.6%	0.0%
200.00	0.0%	17.9%	10.6%	26.7%	0.0%
Total Net Annual Removal Efficiency					91.2%
Total Runoff Volume Treated					>90%

Notes:

- (1) Rainfall Data: 1960:2007, HLY03, Belleville, ONT, 6150700 & 6150689.
- (2) Canada ETV PSD & Test Protocols - ISO14034 Certified
- (3) actored to account for bypass flow.
- (4) Combined removal efficiencies calculated based on NCDENR Stormwater BMP Manual, Section 3.9.4, where
 Total Removal Efficiency = 1st BMP Efficiency + 2nd BMP Efficiency - (1st BMP Efficiency x 2nd BMP Efficiency)



ADS Treatment Train Sizing

Project Name:	Dundas St SQU600	
Consulting Engineer:	vanMEER limited	
Location:	Belleville, Ontario	
Sizing Completed By:	Haider Nasrullah	Email: haider.nasrullah@ads-pipe.com

Summary of Results

Isolator Row PLUS TSS Removal:	80.8%
DD6 TSS Removal:	61.0%
Combined TSS Removal:	92.3%
Total Volume Treated:	>90%

Individual OGS Results

Model	TSS Removal	Volume Treated
DD4	53.0%	>90%
DD6	61.0%	>90%
DD8	65.0%	>90%
DD10	66.0%	>90%
DD12	67.0%	>90%

Overall System Capacities

Total Sediment Storage Capacity:	5.91 m ³
Oil Storage Capacity:	818 L
Max. OGS Pipe Diameter:	450 mm
Peak OGS Flow Capacity:	227 L/s
Peak Isolator Row PLUS Flowrate:	56 L/s

OGS Specifications

Unit Diameter (A):	1,800 mm
Inlet Pipe Diameter (B):	600 mm
Outlet Pipe Diameter (C):	600 mm
Top of Grade Elevation:	0.00 m
Bottom of Sump Elevation:	-1.80 m
Inlet Pipe Elevation:	0.00 m
Outlet Pipe Elevation:	0.00 m

Notes:

Isolator Row PLUS removal efficiency based on verified ETV test report. For dimensions and configuration of Isolator Row PLUS, please see Stormtech drawing package.

Site Details

Site Area (ha):	0.77
Rational C:	0.67
Particle Size Distribution:	ETV
Rainfall Station:	Belleville, ONT


Note: Isolator Row PLUS removal efficiencies based solely on ETV/NJDEP PSD, above-noted PSD is for OGS sizing only

Stormtech Details

Chamber Model:	MC-3500
No. Chambers in Isolator Row PLUS:	5
Volume Treated by Isolator Row PLUS:	>90%

Notes: Refer to Stormtech drawings for full IR+ configuration.

Isolator Row PLUS must include Flared End Ramp (FLAMP) for proper performance.





Project Name:

Dundas St SQU600

Consulting Engineer:

vanMEER limited

Location:

Belleville, Ontario

Net Annual Removal Efficiency Summary

Rainfall Intensity	Fraction of Rainfall	Removal Efficiency		Combined Removal Efficiency	Combined Weighted Removal Efficiency
		DD6	IR PLUS		
mm/hr	%	%	%	%	%
0.50	0.4%	69.2%	81.2%	94.2%	0.4%
1.00	13.2%	68.4%	81.2%	94.1%	12.4%
1.50	14.0%	67.6%	81.2%	93.9%	13.1%
2.00	14.0%	66.9%	81.2%	93.8%	13.1%
2.50	3.6%	66.1%	81.2%	93.6%	3.3%
3.00	2.5%	65.4%	81.2%	93.5%	2.4%
3.50	8.4%	64.6%	81.2%	93.3%	7.9%
4.00	5.1%	63.9%	81.2%	93.2%	4.7%
4.50	1.6%	63.2%	81.2%	93.1%	1.5%
5.00	5.1%	62.4%	81.2%	92.9%	4.7%
6.00	4.8%	61.0%	81.2%	92.7%	4.4%
7.00	4.5%	59.7%	81.2%	92.4%	4.2%
8.00	3.5%	58.3%	81.2%	92.2%	3.2%
9.00	2.4%	57.0%	81.2%	91.9%	2.3%
10.00	2.5%	55.7%	81.2%	91.7%	2.3%
20.00	9.7%	44.4%	81.2%	89.5%	8.7%
30.00	2.8%	35.3%	81.2%	87.8%	2.4%
40.00	0.9%	28.1%	79.3%	85.1%	0.8%
50.00	0.4%	22.4%	63.4%	71.6%	0.3%
100.00	0.6%	17.9%	31.7%	43.9%	0.3%
150.00	0.1%	17.9%	21.1%	35.3%	0.0%
200.00	0.0%	17.9%	15.9%	30.9%	0.0%
Total Net Annual Removal Efficiency					92.3%
Total Runoff Volume Treated					>90%

Notes:

- (1) Rainfall Data: 1960:2007, HLY03, Belleville, ONT, 6150700 & 6150689.
- (2) Canada ETV PSD & Test Protocols - ISO14034 Certified
- (3) actored to account for bypass flow.
- (4) Combined removal efficiencies calculated based on NCDENR Stormwater BMP Manual, Section 3.9.4, where
 Total Removal Efficiency = 1st BMP Efficiency + 2nd BMP Efficiency - (1st BMP Efficiency x 2nd BMP Efficiency)

StormTech® Isolator® Row Plus

The StormTech Isolator Row Plus is an enhancement to our proven water quality treatment system. This updated system is both a NJCAT and ETV verified water quality treatment device that can be incorporated into any system layout.


Features

- Isolator Row Plus is now ETV verified. As a Manufactured Treatment Device it achieves over 81% TSS removal per the ISO 14034:2016 ETV standard and the Canadian Environmental Technology Verification Process.
- A patented Flamp™ (Flared End Ramp) provides a smooth transition from pipe invert to fabric bottom. The FLAMP is attached to the inlet pipe inside the chamber end cap and improves chamber function over time by distributing sediment and debris that would otherwise collect at the inlet. It also serves to improve the fluid and solid flow back into the inlet pipe during maintenance and cleaning.
- Proprietary ADS Plus fabric maintains durability and sediment removal while allowing for higher water quality flow rates. A single layer of ADS Plus fabric is placed between the angular base stone and the Isolator Row Plus chambers.

Technology Descriptions

The Isolator Row Plus is designed to capture the “first flush” runoff and offers the versatility to be sized on a volume or a flow basis. Considered an LID (low impact development) technology, the Isolator Row Plus can be part of the treatment train design for water quality. An upstream manhole not only provides access to the Isolator Row Plus but includes a high/low concept such that stormwater flow rates or volumes that exceed the capacity of the Isolator Row Plus bypass through a manifold to the other chambers. This creates a differential between the Isolator Row Plus row of chambers and the manifold to the rest of the system, thus allowing for settlement time in the Isolator Row Plus. Stormwater is then either infiltrated into the soils below or passed at a controlled rate through an outlet manifold and outlet control structure.


Schematic of the StormTech Isolator Row PLUS System



Summary of Verified Claims¹


Maximum Treatment Flow Rate (MTFR) (L/s/m ²)	2.8
Effective Filtration Treatment Area (m ²)	5.06
Test Sediment Size (microns)	1-1000
Mean Particle Concentration (mg/L)	200
TSS Removal Efficiency	81%

¹ Verification of StormTech SC-740 Isolator Row PLUS test results in accordance with the ISO 14034:2016 ETV standard. The full Verification Statement for the StormTech SC-740 Isolator Row PLUS can be downloaded from the VerifiGlobal website



StormTech Isolator Row Plus (not to scale)

Note: Non-woven fabric is only required over the chambers for the SC-310 and SC-740 chamber models.



Maintenance

The Isolator Row Plus was designed to reduce the cost of periodic maintenance. By “isolating” sediment to just one row of the StormTech system, costs are dramatically reduced by eliminating the need to clean out each row of the entire storage bed. If inspection indicates the potential need for maintenance, access is provided via a manhole(s) located on the end(s) of the row for cleanout. Maintenance is accomplished with the JetVac process. The JetVac® process utilizes a high-pressure water nozzle to propel itself down the Isolator Row Plus while scouring and suspending sediment. As the nozzle is retrieved, the captured pollutants are flushed back into the manhole for vacuuming. Most sewer and pipe maintenance companies have vacuum/JetVac combination vehicles. Selection of an appropriate JetVac nozzle will improve maintenance efficiency.

	Chamber Storage	Chamber Footprint	Treatment Rate
SC-160LP	0.42 m ³ (15.0 cf)	1.06 m ² (11.45 sf)	3.11 L/s (0.11 cfs)
SC-310	0.88 m ³ (31.0 cf)	1.64 m ² (17.7 sf)	4.53 L/s (0.16 cfs)
SC-740	2.12 m ³ (74.9 cf)	2.58 m ² (27.8 sf)	7.36 L/s (0.26 cfs)
DC-780	2.22 m ³ (78.4 cf)	2.58 m ² (27.8 sf)	7.36 L/s (0.26 cfs)
MC-3500	4.96 m ³ (175.0 cf)	3.99 m ² (42.9 sf)	11.32 L/s (0.40 cfs)
MC-4500	4.60 m ³ (162.6 cf)	2.80 m ² (30.1 sf)	7.93 L/s (0.28 cfs)

Installation

Installation of the stormwater treatment unit(s) shall be performed per manufacturer’s installation instructions. Such instructions can be obtained by calling Advanced Drainage systems at 888-367-7473 or by logging on to www.ads-pipe.com or www.stormtech.com.




ads-pipcanada.ca

519-699-0222

StormTech[®] MC-3500 Chamber

Designed to meet the most stringent industry performance standards for superior structural integrity while providing designers with a cost-effective method to save valuable land and protect water resources. The StormTech system is designed primarily to be used under parking lots, thus maximizing land usage for private (commercial) and public applications. StormTech chambers can also be used in conjunction with Green Infrastructure, thus enhancing the performance and extending the service life of these practices.



Nominal Chamber Specifications (not to scale)

Size (L x W x H)
 90" x 77" x 45"
 2286 mm x 1956 mm x 1143 mm

Chamber Storage
 109.9 ft³ (3.11 m³)

Min. Installed Storage*
 175.0 ft³ (4.96 m³)

Weight
 134 lbs (60.8 kg)

Shipping
 15 chambers/pallet
 7 end caps/pallet
 7 pallets/truck

*Assumes a minimum of 12" (300 mm) of stone above, 9" (230 mm) of stone below chambers, 6" (150 mm) of stone between chambers/ end caps and 40% stone porosity.

Nominal End Cap Specifications (not to scale)



Size (L x W x H)
 26.5" x 71" x 45.1"
 673 mm x 1803 mm x 1145 mm

End Cap Storage
 14.9 ft³ (0.42 m³)

Min. Installed Storage*
 45.1 ft³ (1.28 m³)

Weight
 49 lbs (22.2 kg)

*Assumes a minimum of 12" (300 mm) of stone above, 9" (230 mm) of stone below, 6" (150 mm) of stone perimeter, 6" (150 mm) of stone between chambers/ end caps and 40% stone porosity.



*MINIMUM COVER TO BOTTOM OF FLEXIBLE PAVEMENT. FOR UNPAVED INSTALLATIONS WHERE RUTTING FROM VEHICLES MAY OCCUR, INCREASE COVER TO 24" (600 mm).

StormTech MC-3500 Specifications

Storage Volume Per Chamber

	Bare Chamber Storage ft ³ (m ³)	Chamber and Stone Foundation Depth in. (mm)			
		9 in (230 mm)	12 in (300 mm)	15 in (375 mm)	18 in (450 mm)
Chamber	109.9 (3.11)	175.0 (4.96)	179.9 (5.09)	184.9 (5.24)	189.9 (5.38)
End Cap	14.9 (0.42)	45.1 (1.28)	46.6 (1.32)	48.3 (1.37)	49.9 (1.41)

Note: Assumes 6" (150 mm) row spacing, 40% stone porosity, 12" (300 mm) stone above and includes the bare chamber/end cap volume.

Amount of Stone Per Chamber

English Tons (yds ³)	Stone Foundation Depth			
	9 in	12 in	15 in	18 in
Chamber	8.5 (6.0)	9.1 (6.5)	9.7 (6.9)	10.4 (7.4)
End Cap	3.9 (2.8)	4.1 (2.9)	4.3 (3.1)	4.5 (3.2)
Metric Kilograms (m ³)	230 mm	300 mm	375 mm	450 mm
Chamber	7711 (4.6)	8255 (5.0)	8800 (5.3)	9435 (5.7)
End Cap	3538 (2.1)	3719 (2.2)	3901 (2.4)	4082 (2.5)

Note: Assumes 12" (300 mm) of stone above and 6" (150 mm) row spacing and 6" (150 mm) of perimeter stone in front of end caps.

Volume Excavation Per Chamber yd³ (m³)

	Stone Foundation Depth			
	9 in (230 mm)	12 in (300 mm)	15 in (375mm)	18 in (450 mm)
Chamber	11.9 (9.1)	12.4 (9.5)	12.8 (9.8)	13.3 (10.2)
End Cap	4.0 (3.1)	4.1 (3.3)	4.3 (3.3)	4.4 (3.4)

Note: Assumes 6" (150 mm) of separation between chamber rows and 24" (600 mm) of cover. The volume of excavation will vary as depth of cover increases.

ADS StormTech products, manufactured in accordance with ASTM F2418 or ASTM F2922, comply with all requirements in the Build America, Buy America (BABA) Act.

Working on a project?

Visit us at adspipe.com/stormtech and utilize the Design Tool




ACCEPTABLE FILL MATERIALS: STORMTECH MC-3500 CHAMBER SYSTEMS

MATERIAL LOCATION	DESCRIPTION	AASHTO MATERIAL CLASSIFICATIONS	COMPACTION / DENSITY REQUIREMENT
D	<p>FINAL FILL: FILL MATERIAL FOR LAYER 'D' STARTS FROM THE TOP OF THE 'C' LAYER TO THE BOTTOM OF FLEXIBLE PAVEMENT OR UNPAVED FINISHED GRADE ABOVE. NOTE THAT PAVEMENT SUBBASE MAY BE PART OF THE 'D' LAYER</p>	N/A	PREPARE PER SITE DESIGN ENGINEER'S PLANS. PAVED INSTALLATIONS MAY HAVE STRINGENT MATERIAL AND PREPARATION REQUIREMENTS.
C	<p>INITIAL FILL: FILL MATERIAL FOR LAYER 'C' STARTS FROM THE TOP OF THE EMBEDMENT STONE ('B' LAYER) TO 24" (600 mm) ABOVE THE TOP OF THE CHAMBER. NOTE THAT PAVEMENT SUBBASE MAY BE A PART OF THE 'C' LAYER.</p>	<p>AASHTO M145¹ A-1, A-2-4, A-3 OR AASHTO M43¹ 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10</p>	BEGIN COMPACTIONS AFTER 24" (600 mm) OF MATERIAL OVER THE CHAMBERS IS REACHED. COMPACT ADDITIONAL LAYERS IN 12" (300 mm) MAX LIFTS TO A MIN. 95% PROCTOR DENSITY FOR WELL GRADED MATERIAL AND 95% RELATIVE DENSITY FOR PROCESSED AGGREGATE MATERIALS.
B	<p>EMBEDMENT STONE: FILL SURROUNDING THE CHAMBERS FROM THE FOUNDATION STONE ('A' LAYER) TO THE 'C' LAYER ABOVE.</p>	AASHTO M43 ¹ 3, 4	NO COMPACTION REQUIRED.
A	<p>FOUNDATION STONE: FILL BELOW CHAMBERS FROM THE SUBGRADE UP TO THE FOOT (BOTTOM) OF THE CHAMBER.</p>	AASHTO M43 ¹ 3, 4	PLATE COMPACT OR ROLL TO ACHIEVE A FLAT SURFACE. ^{2,3}

PLEASE NOTE:

- THE LISTED AASHTO DESIGNATIONS ARE FOR GRADATIONS ONLY. THE STONE MUST ALSO BE CLEAN, CRUSHED, ANGULAR. FOR EXAMPLE, A SPECIFICATION FOR #4 STONE WOULD STATE: "CLEAN, CRUSHED, ANGULAR NO. 4 (AASHTO M43) STONE".
- STORMTECH COMPACTION REQUIREMENTS ARE MET FOR 'A' LOCATION MATERIALS WHEN PLACED AND COMPACTED IN 9" (230 mm) (MAX) LIFTS USING TWO FULL COVERAGES WITH A VIBRATORY COMPACTOR.
- WHERE INFILTRATION SURFACES MAY BE COMPROMISED BY COMPACTION, FOR STANDARD DESIGN LOAD CONDITIONS, A FLAT SURFACE MAY BE ACHIEVED BY RAKING OR DRAGGING WITHOUT COMPACTION EQUIPMENT. FOR SPECIAL LOAD DESIGNS, CONTACT STORMTECH FOR COMPACTION REQUIREMENTS.
- ONCE LAYER 'C' IS PLACED, ANY SOIL/MATERIAL CAN BE PLACED IN LAYER 'D' UP TO THE FINISHED GRADE. MOST PAVEMENT SUBBASE SOILS CAN BE USED TO REPLACE THE MATERIAL REQUIREMENTS OF LAYER 'C' OR 'D' AT THE SITE DESIGN ENGINEER'S DISCRETION.



NOTES:






- CHAMBERS SHALL MEET THE REQUIREMENTS OF ASTM F2418, "STANDARD SPECIFICATION FOR POLYPROPYLENE (PP) CORRUGATED WALL STORMWATER COLLECTION CHAMBERS" CHAMBER CLASSIFICATION 45x76 DESIGNATION SS.
- MC-3500 CHAMBERS SHALL BE DESIGNED IN ACCORDANCE WITH ASTM F2787 "STANDARD PRACTICE FOR STRUCTURAL DESIGN OF THERMOPLASTIC CORRUGATED WALL STORMWATER COLLECTION CHAMBERS".
- THE SITE DESIGN ENGINEER IS RESPONSIBLE FOR ASSESSING THE BEARING RESISTANCE (ALLOWABLE BEARING CAPACITY) OF THE SUBGRADE SOILS AND THE DEPTH OF FOUNDATION STONE WITH CONSIDERATION FOR THE RANGE OF EXPECTED SOIL MOISTURE CONDITIONS.
- PERIMETER STONE MUST BE EXTENDED HORIZONTALLY TO THE EXCAVATION WALL FOR BOTH VERTICAL AND SLOPED EXCAVATION WALLS.
- REQUIREMENTS FOR HANDLING AND INSTALLATION:
 - TO MAINTAIN THE WIDTH OF CHAMBERS DURING SHIPPING AND HANDLING, CHAMBERS SHALL HAVE INTEGRAL, INTERLOCKING STACKING LUGS.
 - TO ENSURE A SECURE JOINT DURING INSTALLATION AND BACKFILL, THE HEIGHT OF THE CHAMBER JOINT SHALL NOT BE LESS THAN 3".
 - TO ENSURE THE INTEGRITY OF THE ARCH SHAPE DURING INSTALLATION, a) THE ARCH STIFFNESS CONSTANT AS DEFINED IN SECTION 6.2.8 OF ASTM F2418 SHALL BE GREATER THAN OR EQUAL TO 500 LBS/FT² AND b) TO RESIST CHAMBER DEFORMATION DURING INSTALLATION AT ELEVATED TEMPERATURES (ABOVE 73° F / 23° C), CHAMBERS SHALL BE PRODUCED FROM REFLECTIVE GOLD OR YELLOW COLORS.

*FOR COVER DEPTHS GREATER THAN 8.0' (2.4 m) PLEASE CONTACT ADS

<p>StormTech 4640 TRUEMAN BLVD HILLIARD, OH 43026</p>	<p>888-892-2694 WWW.STORMTECH.COM</p>	<p>Chamber System</p>	<p>DATE: 8/03/22 DRAWN: KLU CHECKED: KLU</p>	<p>PROJECT #:</p>
<p>MC-3500 STANDARD CROSS SECTION</p>		<p>DATE: 8/03/22 DRAWN: KLU CHECKED: KLU</p>		

MC-3500 TECHNICAL SPECIFICATION

NTS



NOMINAL CHAMBER SPECIFICATIONS

SIZE (W X H X INSTALLED LENGTH)	77.0" X 45.0" X 86.0"	(1956 mm X 1143 mm X 2184 mm)
CHAMBER STORAGE	109.9 CUBIC FEET	(3.11 m ³)
MINIMUM INSTALLED STORAGE* WEIGHT	175.0 CUBIC FEET	(4.96 m ³)
	134 lbs.	(60.8 kg)


NOMINAL END CAP SPECIFICATIONS

SIZE (W X H X INSTALLED LENGTH)	75.0" X 45.0" X 22.2"	(1905 mm X 1143 mm X 564 mm)
END CAP STORAGE	14.9 CUBIC FEET	(0.42 m ³)
MINIMUM INSTALLED STORAGE* WEIGHT	45.1 CUBIC FEET	(1.28 m ³)
	49 lbs.	(22.2 kg)

*ASSUMES 12" (305 mm) STONE ABOVE, 9" (229 mm) STONE FOUNDATION, 6" (152 mm) STONE BETWEEN CHAMBERS, 6" (152 mm) STONE PERIMETER IN FRONT OF END CAPS AND 40% STONE POROSITY.


PARTIAL CUT HOLES AT BOTTOM OF END CAP FOR PART NUMBERS ENDING WITH "B"
 PARTIAL CUT HOLES AT TOP OF END CAP FOR PART NUMBERS ENDING WITH "T"
 END CAPS WITH A PREFABRICATED WELDED STUB END WITH "W"
 END CAPS WITH A WELDED CROWN PLATE END WITH "C"

PART #	STUB	B	C
MC3500IEPP06T	6" (150 mm)	33.21" (844 mm)	---
MC3500IEPP06B		---	0.66" (17 mm)
MC3500IEPP08T	8" (200 mm)	31.16" (791 mm)	---
MC3500IEPP08B		---	0.81" (21 mm)
MC3500IEPP10T	10" (250 mm)	29.04" (738 mm)	---
MC3500IEPP10B		---	0.93" (24 mm)
MC3500IEPP12T	12" (300 mm)	26.36" (670 mm)	---
MC3500IEPP12B		---	1.35" (34 mm)
MC3500IEPP15T	15" (375 mm)	23.39" (594 mm)	---
MC3500IEPP15B		---	1.50" (38 mm)
MC3500IEPP18TC	18" (450 mm)	20.03" (509 mm)	---
MC3500IEPP18TW			---
MC3500IEPP18BC		---	1.77" (45 mm)
MC3500IEPP18BW		---	---
MC3500IEPP24TC	24" (600 mm)	14.48" (368 mm)	---
MC3500IEPP24TW			---
MC3500IEPP24BC		---	2.06" (52 mm)
MC3500IEPP24BW		---	---
MC3500IEPP30BC	30" (750 mm)	---	2.75" (70 mm)



CUSTOM PARTIAL CUT INVERTS ARE AVAILABLE UPON REQUEST. INVENTORIED MANIFOLDS INCLUDE 12-24" (300-600 mm) SIZE ON SIZE AND 15-48" (375-1200 mm) ECCENTRIC MANIFOLDS. CUSTOM INVERT LOCATIONS ON THE MC-3500 END CAP CUT IN THE FIELD ARE NOT RECOMMENDED FOR PIPE SIZES GREATER THAN 10" (250 mm). THE INVERT LOCATION IN COLUMN 'B' ARE THE HIGHEST POSSIBLE FOR THE PIPE SIZE.

NOTE: ALL DIMENSIONS ARE NOMINAL



MC-3500 ISOLATOR ROW PLUS DETAIL
NTS


INSPECTION & MAINTENANCE

- STEP 1) INSPECT ISOLATOR ROW PLUS FOR SEDIMENT
- A. INSPECTION PORTS (IF PRESENT)
 - A.1. REMOVE/OPEN LID ON NYLOPLAST INLINE DRAIN
 - A.2. REMOVE AND CLEAN FLEXSTORM FILTER IF INSTALLED
 - A.3. USING A FLASHLIGHT AND STADIA ROD, MEASURE DEPTH OF SEDIMENT AND RECORD ON MAINTENANCE LOG
 - A.4. LOWER A CAMERA INTO ISOLATOR ROW PLUS FOR VISUAL INSPECTION OF SEDIMENT LEVELS (OPTIONAL)
 - A.5. IF SEDIMENT IS AT, OR ABOVE, 3" (80 mm) PROCEED TO STEP 2. IF NOT, PROCEED TO STEP 3.
 - B. ALL ISOLATOR PLUS ROWS
 - B.1. REMOVE COVER FROM STRUCTURE AT UPSTREAM END OF ISOLATOR ROW PLUS USING A FLASHLIGHT, INSPECT DOWN THE ISOLATOR ROW PLUS THROUGH OUTLET PIPE
 - B.2.
 - i) MIRRORS ON POLES OR CAMERAS MAY BE USED TO AVOID A CONFINED SPACE ENTRY
 - ii) FOLLOW OSHA REGULATIONS FOR CONFINED SPACE ENTRY IF ENTERING MANHOLE
 - B.3. IF SEDIMENT IS AT, OR ABOVE, 3" (80 mm) PROCEED TO STEP 2. IF NOT, PROCEED TO STEP 3.
- STEP 2) CLEAN OUT ISOLATOR ROW PLUS USING THE JETVAC PROCESS
- A. A FIXED CULVERT CLEANING NOZZLE WITH REAR FACING SPREAD OF 45° (1.1 m) OR MORE IS PREFERRED
 - B. APPLY MULTIPLE PASSES OF JETVAC UNTIL BACKFLUSH WATER IS CLEAN
 - C. VACUUM STRUCTURE SUMP AS REQUIRED
- STEP 3) REPLACE ALL COVERS, GRATES, FILTERS, AND LIDS; RECORD OBSERVATIONS AND ACTIONS.
- STEP 4) INSPECT AND CLEAN BASINS AND MANHOLES UPSTREAM OF THE STORMTECH SYSTEM.

NOTES

1. INSPECT EVERY 6 MONTHS DURING THE FIRST YEAR OF OPERATION. ADJUST THE INSPECTION INTERVAL BASED ON PREVIOUS OBSERVATIONS OF SEDIMENT ACCUMULATION AND HIGH WATER ELEVATIONS.
2. CONDUCT JETTING AND VACTORING ANNUALLY OR WHEN INSPECTION SHOWS THAT MAINTENANCE IS NECESSARY.

NOTE:
INSPECTION PORTS MAY BE CONNECTED THROUGH ANY CHAMBER CORRUGATION VALLEY.



4" PVC INSPECTION PORT DETAIL
(MC SERIES CHAMBER)
NTS

<p>4640 TRUEMAN BLVD HILLIARD, OH 43026</p>		<p>StormTech Chamber System 888-892-2694 WWW.STORMTECH.COM</p>							
<p>MC-3500</p> <p>ISOLATOR ROW PLUS DETAILS</p> <p>DATE: 8/03/22 DRAWN: KLU CHECKED: KLU</p>	<p>PROJECT #:</p>	<p>DESCRIPTION</p>	<table border="1"> <tr> <th>DATE</th> <th>DRWN</th> <th>CHKD</th> </tr> <tr> <td> </td> <td> </td> <td> </td> </tr> </table>	DATE	DRWN	CHKD			
DATE	DRWN	CHKD							

THIS DRAWING HAS BEEN PREPARED BASED ON INFORMATION PROVIDED TO ADS UNDER THE DIRECTION OF THE SITE DESIGN ENGINEER OR OTHER PROJECT REPRESENTATIVE. THE SITE DESIGN ENGINEER SHALL REVIEW THIS DRAWING PRIOR TO CONSTRUCTION. IT IS THE ULTIMATE RESPONSIBILITY OF THE SITE DESIGN ENGINEER TO ENSURE THAT THE PRODUCT(S) DEPICTED AND ALL ASSOCIATED DETAILS MEET ALL APPLICABLE LAWS, REGULATIONS, AND PROJECT REQUIREMENTS.

Isolator[®] Row Plus

O&M Manual



The Isolator[®] Row Plus

Introduction

An important component of any Stormwater Pollution Prevention Plan is inspection and maintenance. The StormTech Isolator Row Plus is a technique to inexpensively enhance Total Suspended Solids (TSS) and Total Phosphorus (TP) removal with easy access for inspection and maintenance.

The Isolator Row Plus

The Isolator Row Plus is a row of StormTech chambers, either SC-160, SC-310, SC-310-3, SC-740, DC-780, MC-3500 or MC-7200 models, that is surrounded with filter fabric and connected to a closely located manhole for easy access. The fabric-wrapped chambers provide for sediment settling and filtration as stormwater rises in the Isolator Row Plus and passes through the filter fabric. The open bottom chambers and perforated sidewalls (SC-310, SC-310-3 and SC-740 models) allow stormwater to flow both vertically and horizontally out of the chambers. Sediments are captured in the Isolator Row Plus protecting the adjacent stone and chambers storage areas from sediment accumulation.

ADS geotextile fabric is placed between the stone and the Isolator Row Plus chambers. The woven geotextile provides a media for stormwater filtration, a durable surface for maintenance, prevents scour of the underlying stone and remains intact during high pressure jetting. A non-woven fabric is placed over the chambers to provide a filter media for flows passing through the chamber's sidewall. The non-woven fabric is not required over the SC-160, DC-780, MC-3500 or MC-7200 models as these chambers do not have perforated side walls.

The Isolator Row Plus is designed to capture the "first flush" runoff and offers the versatility to be sized on a volume basis or a flow-rate basis. An upstream manhole provides access to the Isolator Row Plus and includes a high/low concept such that stormwater flow rates or volumes that exceed the capacity of the Isolator Row Plus bypass through a manifold to the other chambers. This is achieved with an elevated bypass manifold or a high-flow weir. This creates a differential between the Isolator Row Plus row of chambers and the manifold to the rest of the system, thus allowing for settlement time in the Isolator Row Plus. After Stormwater flows through the Isolator Row Plus and into the rest of the chamber system it is either exfiltrated into the soils below or passed at a controlled rate through an outlet manifold and outlet control structure.

The Isolator Row FLAMP[™] (patent pending) is a flared end ramp apparatus attached to the inlet pipe on the inside of the chamber end cap. The FLAMP provides a smooth transition from pipe invert to fabric bottom. It is configured to improve chamber function performance by enhancing outflow of solid debris that would otherwise collect at the chamber's end. It also serves to improve the fluid and solid flow into the access pipe during maintenance and cleaning and to guide cleaning and inspection equipment back into the inlet pipe when complete.

The Isolator Row Plus may be part of a treatment train system. The treatment train design and pretreatment device selection by the design engineer is often driven by regulatory requirements. Whether pretreatment is used or not, StormTech recommend using the Isolator Row Plus to minimize maintenance requirements and maintenance costs.


Note: See the StormTech Design Manual for detailed information on designing inlets for a StormTech system, including the Isolator Row Plus.



Looking down the Isolator Row PLUS from the manhole opening, ADS PLUS Fabric is shown between the chamber and stone base.



StormTech Isolator Row PLUS with Overflow Spillway (not to scale)



Isolator Row Plus Inspection/Maintenance

Inspection

The frequency of inspection and maintenance varies by location. A routine inspection schedule needs to be established for each individual location based upon site specific variables. The type of land use (i.e. industrial, commercial, residential), anticipated pollutant load, percent imperviousness, climate, etc. all play a critical role in determining the actual frequency of inspection and maintenance practices.

At a minimum, StormTech recommends annual inspections. Initially, the Isolator Row Plus should be inspected every 6 months for the first year of operation. For subsequent years, the inspection should be adjusted based upon previous observation of sediment deposition.

The Isolator Row Plus incorporates a combination of standard manhole(s) and strategically located inspection ports (as needed). The inspection ports allow for easy access to the system from the surface, eliminating the need to perform a confined space entry for inspection purposes.


If upon visual inspection it is found that sediment has accumulated, a stadia rod should be inserted to determine the depth of sediment. When the average depth of sediment exceeds 3 inches throughout the length of the Isolator Row Plus, clean-out should be performed.

Maintenance

The Isolator Row Plus was designed to reduce the cost of periodic maintenance. By "isolating" sediments to just one row, costs are dramatically reduced by eliminating the need to clean out each row of the entire storage bed. If inspection indicates the potential need for maintenance, access is provided


via a manhole(s) located on the end(s) of the row for cleanout. If entry into the manhole is required, please follow local and OSHA rules for a confined space entries.

Maintenance is accomplished with the JetVac process. The JetVac process utilizes a high pressure water nozzle to propel itself down the Isolator Row Plus while scouring and suspending sediments. As the nozzle is retrieved, the captured pollutants are flushed back into the manhole for vacuuming. Most sewer and pipe maintenance companies have vacuum/JetVac combination vehicles. Selection of an appropriate JetVac nozzle will improve maintenance efficiency. Fixed nozzles designed for culverts or large diameter pipe cleaning are preferable. Rear facing jets with an effective spread of at least 45" are best. StormTech recommends a maximum nozzle pressure of 2000 psi be utilized during cleaning. JetVac reels can vary in length. For ease of maintenance, ADS recommends Isolator Row Plus lengths up to 200' (61 m). **The JetVac process shall only be performed on StormTech Isolator Row Plus that have ADS Plus Fabric (as specified by StormTech) over their angular base stone.**



StormTech Isolator Row PLUS (not to scale)

Note: Non-woven fabric is only required over the inlet pipe connection into the end cap for SC-160LP, DC-780, MC-3500 and MC-7200 chamber models and is not required over the entire Isolator Row PLUS.



Isolator Row Plus Step By Step Maintenance Procedures

Step 1

Inspect Isolator Row Plus for sediment.

- A) Inspection ports (if present)
 - i. Remove lid from floor box frame
 - ii. Remove cap from inspection riser
 - iii. Using a flashlight and stadia rod, measure depth of sediment and record results on maintenance log.
 - iv. If sediment is at or above 3 inch depth, proceed to Step 2. If not, proceed to Step 3.
- B) All Isolator Row Plus
 - i. Remove cover from manhole at upstream end of Isolator Row Plus
 - ii. Using a flashlight, inspect down Isolator Row Plus through outlet pipe
 - 1. Mirrors on poles or cameras may be used to avoid a confined space entry
 - 2. Follow OSHA regulations for confined space entry if entering manhole
 - iii. If sediment is at or above the lower row of sidewall holes (approximately 3 inches), proceed to Step 2. If not, proceed to Step 3.

Step 2

Clean out Isolator Row Plus using the JetVac process.


- A) A fixed floor cleaning nozzle with rear facing nozzle spread of 45 inches or more is preferable
- B) Apply multiple passes of JetVac until backflush water is clean
- C) Vacuum manhole sump as required

Step 3

Replace all caps, lids and covers, record observations and actions.

Step 4

Inspect & clean catch basins and manholes upstream of the StormTech system.



Sample Maintenance Log


Date	Stadia Rod Readings		Sedi-ment Depth (1)-(2)	Observations/Actions	Inspector
	Fixed point to chamber bottom (1)	Fixed point to top of sediment (2)			
3/15/11	6.3 ft	none		New installation. Fixed point is CI frame at grade	DJM
9/24/11		6.2	0.1 ft	Some grit felt	SM
6/20/13		5.8	0.5 ft	Mucky feel, debris visible in manhole and in Isolator Row PLUS, maintenance due	NV
7/7/13	6.3 ft		0	System jetted and vacuumed	DJM

adspipe.com

800-821-6710

StormTech® Installation Guide

MC-3500 & MC-4500 Chamber



StormTech
Installation Video

Required Materials and Equipment List

- Acceptable fill materials per Table 1
- ADS Plus and non-woven geotextile fabrics
- StormTech solid end caps, pre-cored and pre-fabricated end caps
- StormTech chambers, manifolds and fittings

Note: MC-3500 chamber pallets are 77" x 90" (2.0 m x 2.3 m) and weigh about 2010 lbs. (912 kg) and MC-4500 pallets are 100" x 52" (2.5 m x 1.3 m) and weigh about 840 lbs. (381 kg). Unloading chambers requires 72" (1.8 m) (min.) forks and/or tie downs (straps, chains, etc).

Important Notes:

- This installation guide provides the minimum requirements for proper installation of chambers. Nonadherence to this guide may result in damage to chambers during installation. Replacement of damaged chambers during or after backfilling is costly and very time consuming. It is recommended that all installers are familiar with this guide, and that the contractor inspects the chambers for distortion, damage and joint integrity as work progresses.
- Use of a dozer to push embedment stone between the rows of chambers may cause damage to chambers and is not an acceptable backfill method. Any chambers damaged by using the "dump and push" method are not covered under the StormTech standard warranty.
- Care should be taken in the handling of chambers and end caps. End caps must be stored standing upright. Avoid dropping, prying or excessive force on chambers during removal from pallet and initial placement.

Requirements for System Installation



Excavate bed and prepare subgrade per engineer's plans. Plans and specifications should include Best Management Practices (BMPs) to deter contamination of open pits during construction.



Place non-woven geotextile over prepared soils and up excavation walls.



Place clean, crushed, angular stone foundation 9" (230 mm) min. Install underdrains if required. Compact to achieve a flat surface.

Manifold, Scour Fabric and Chamber Assembly




Install manifolds and lay out ADS PLUS fabric at inlet rows [min. 17.5 ft (5.33 m)] at each inlet end cap. Place a continuous piece (no seams) along entire length of Isolator® PLUS Row(s).

Align the first chamber and end cap of each row with inlet pipes. Contractor may choose to postpone stone placement around end chambers and leave ends of rows open for easy inspection of chambers during the backfill process.

Continue installing chambers by overlapping chamber end corrugations. Chamber joints are labeled "Lower Joint - Overlap Here" and "Build this direction - Upper Joint". Be sure that the chamber placement does not exceed the reach of the construction equipment used to place the stone. Maintain minimum 6" (150 mm) spacing between MC-3500 rows and 9" (230 mm) spacing between MC-4500 rows.

Place a continuous layer of ADS PLUS fabric between the foundation stone and the Isolator Row PLUS chambers, making sure the fabric lays flat and extends the entire width of the chamber feet. When used on an Isolator Row PLUS, a 24" FLAMP (flared end ramp) is attached to the inside of the inlet pipe with a provided threaded rod and bolt. The FLAMP then lays on top of the ADS PLUS fabric.


Manifold Insertion




NOTE: MANIFOLD STUB MUST BE LAID HORIZONTAL FOR A PROPER FIT IN END CAP OPENING.

Insert inlet and outlet manifolds a minimum 12" (300 mm) into chamber end caps. Manifold header should be a minimum 12" (300 mm) from base of end cap.

StormTech Isolator Row Plus Detail




Initial Anchoring of Chambers – Embedment Stone



Initial embedment shall be spotted along the centerline of the chamber evenly anchoring the lower portion of the chamber. This is best accomplished with a stone conveyor or excavator reaching along the row.


No equipment shall be operated on the bed at this stage of the installation. Excavators must be located off the bed. Dump trucks shall not dump stone directly on to the bed. Dozers or loaders are not allowed on the bed at this time.

Backfill of Chambers – Embedment Stone




Uneven Backfill

Backfill chambers evenly. Stone column height should never differ by more than 12" (300 mm) between adjacent chamber rows or between chamber rows and perimeter.




Even Backfill




Perimeter Not Backfilled

Perimeter stone must be brought up evenly with chamber rows. Perimeter must be fully backfilled, with stone extended horizontally to the excavation wall.



Perimeter Fully Backfilled

Backfill of Chambers – Embedment Stone and Cover Stone



Continue evenly backfilling between rows and around perimeter until embedment stone reaches tops of chambers and a minimum 12" (300 mm) of cover stone is in place. Perimeter stone must extend horizontally to the excavation wall for both straight or sloped sidewalls. The recommended backfill methods are with a stone conveyor outside of the bed or build as you go with an excavator inside the bed reaching along the rows. Backfilling while assembling chambers rows as shown in the picture will help to ensure that equipment reach is not exceeded.


Only after chambers have been backfilled to top of chamber and with a minimum 12" (300 mm) of cover stone on top of chambers can skid loaders and small LGP dozers be used to final grade cover stone and backfill material in accordance with ground pressure limits in Table 2. Equipment must push material parallel to rows only. Never push perpendicular to rows. StormTech recommends the contractor inspect chamber rows before placing final backfill. Any chambers damaged by construction equipment shall be removed and replaced.

Final Backfill of Chambers – Fill Material



Install non-woven geotextile over stone. Geotextile must overlap 24" (600 mm) where edges meet. Compact at 24" (600 mm) of fill. Roller travel parallel with rows.

Inserta Tee Detail



CHAMBER	MAX DIAMETER OF INSERTA TEE	HEIGHT FROM BASE OF CHAMBER (X)
MC-3500	12" (250 mm)	6" (150 mm)
MC-4500	12" (250 mm)	8" (200 mm)

INSERTA TEE FITTINGS AVAILABLE FOR SDR 26, SDR 35, SCH 40 IPS GASKETED & SOLVENT WELD, N-12, HP STORM, C-900 OR DUCTILE IRON

NOTE:
PART NUMBERS WILL VARY BASED ON INLET PIPE MATERIALS. CONTACT STORMTECH FOR MORE INFORMATION.

Table 1- Acceptable Fill Materials

Material Location	Description	AASHTO M43 Designation ¹	Compaction/Density Requirement
(D) Final Fill: Fill Material for layer 'D' starts from the top of the 'C' layer to the bottom of flexible pavement or ungraded finished grade above. Note that the pavement subbase may be part of the 'D' layer.	Any soil/rock materials, native soils or per engineer's plans. Check engineer's plans for pavement subgrade requirements.	N/A	Prepare per site design engineer's plans. Paved installations may have stringent material and preparation requirements.
(C) Initial Fill: Fill Material for layer 'C' starts from the top of the embedment stone ('B' layer) to 24" (600 mm) above the top of the chamber. Note that pavement subbase may be part of the 'C' layer.	Granular well-graded soil/aggregate mixtures, <35% fines or processed aggregate. Most pavement subbase materials can be used in lieu of this layer.	AASHTO M145 ¹ A-1, A-2-4, A-3 or AASHTO M43 ¹ 3, 357, 4, 467, 5, 56, 57, 6, 67, 68, 7, 78, 8, 89, 9, 10	Begin compaction after min. 24" (600 mm) of material over the chambers is reached. Compact additional layers in 12" (300 mm) max. lifts to a min. 95% Proctor density for well-graded material and 95% relative density for processed aggregate materials.
(B) Embedment Stone: Fill the surrounding chambers from the foundation stone ('A' layer) to the 'C' layer above.	Clean, crushed, angular stone	AASHTO M43 ¹ 3, 4	No compaction required.
(A) Foundation Stone: Fill below chambers from the subgrade up to the foot (bottom) of the chamber.	Clean, crushed, angular stone,	AASHTO M43 ¹ 3, 4	Place and compact in 9" (230 mm) max lifts using two full coverages with a vibratory compactor. ^{2,3}

Please Note:

- The listed AASHTO designations are for gradations only. The stone must also be clean, crushed, angular. For example, a specification for #4 stone would state: "clean, crushed, angular no. 4 (AASHTO M43) stone".
- StormTech compaction requirements are met for 'A' location materials when placed and compacted in 9" (230 mm) (max) lifts using two full coverages with a vibratory compactor.
- Where infiltration surfaces may be comprised by compaction, for standard installations and standard design load conditions, a flat surface may be achieved by raking or dragging without compaction equipment. For special load designs, contact StormTech for compaction requirements.

Figure 2 - Fill Material Locations





Figure 1 - Inspection Port Detail



Notes:

- 36" (900 mm) of stabilized cover materials over the chambers is recommended during the construction phase if general construction activities, such as full dump truck travel and dumping, are to occur over the bed.
- During paving operations, dump truck axle loads on 18" (450mm) of cover for MC-3500s may be necessary. Precautions should be taken to avoid rutting of the road base layer, to ensure that compaction requirements have been met, and that a minimum of 18" (450mm) of cover for MC-3500s exists over the chambers. Contact StormTech for additional guidance on allowable axle loads during paving.
- Ground pressure for track dozers is the vehicle operating weight divided by total ground contact area for both tracks. Excavators will exert higher ground pressures based on loaded bucket weight and boom extension.
- Mini-excavators (<8,000lbs/3,628 kg) can be used with at least 12" (300 mm) of stone over the chambers and are limited by the maximum ground pressures in Table 2 based on a full bucket at maximum boom extension.
- StormTech does not require compaction of initial fill at 18" (450 mm) of cover. However, requirements by others for 6" (150 mm) lifts may necessitate the use of small compactors at 18" (450 mm) of cover.
- Storage of materials such as construction materials, equipment, spoils, etc. should not be located over the StormTech system. The use of equipment over the StormTech system not covered in Table 2 (ex. soil mixing equipment, cranes, etc) is limited. Please contact StormTech for more information.
- Allowable track loads based on vehicle travel only. Excavators shall not operate on chamber beds until the total backfill reaches 3 feet (900 mm) over the entire bed.

Call StormTech at **888.892.2694** for technical and product information or visit www.stormtech.com



Table 2 - Maximum Allowable Construction Vehicle Loads⁶

Material Location	Fill Depth over Chambers in. (mm)	Maximum Allowable Wheel Loads		Maximum Allowable Track Loads ⁶		Maximum Allowable Roller Loads		
		Max Axle Load for Trucks lbs (kN)	Max Wheel Load for Loaders lbs (kN)	Track Width in. (mm)	Max Ground Pressure psf (kPa)			
Ⓓ Final Fill Material	36" (900) Compacted	32,000 (142)	16,000 (71)	12" (305)	4050 (194)	38,000 (169)		
				18" (457)	2760 (132)			
				24" (610)	2130 (102)			
				30" (762)	1770 (84)			
				36" (914)	1530 (73)			
Ⓒ Initial Fill Material	24" (600) Compacted	32,000 (142)	16,000 (71)	12" (305)	2750 (131)	20,000 (89)		
				18" (457)	1920 (92)			
				24" (610)	1520 (73)			
				30" (762)	1310 (63)			
				36" (914)	1180 (56)			
	Loose/Dumped	MC-3500			12" (305)	2430 (116)	16,000 (71)	
				18" (457)	1730 (82)			
				24" (610)	1390 (66)			
				30" (762)	1210 (58)			
				36" (914)	1100 (52)			
18" (450)	MC-3500			12" (305)	2140 (102)	5,000 (22) (static loads only) ⁵		
			18" (457)	1530 (73)				
			24" (610)	1260 (60)				
			30" (762)	1120 (53)				
			36" (914)	1030 (49)				
Ⓔ Embedment Stone	12" (300)	Not Allowed	Not Allowed	12" (305)	1100 (53)	Not Allowed		
				18" (457)	710 (34)			
				24" (610)	660 (32)			
				30" (762)	580 (28)			
				Not Allowed	Not Allowed			
6" (150)	Not Allowed	Not Allowed	Not Allowed	Not Allowed	Not Allowed	Not Allowed		

Table 3 - Placement Methods and Descriptions

Material Location	Placement Methods/Restrictions	Wheel Load Restrictions	Roller Load Restrictions	
			Track Load Restrictions	Roller Load Restrictions
Ⓓ Final Fill Material	A variety of placement methods may be used. All construction loads must not exceed the maximum limits in Table 2.	36" (900 mm) minimum cover required for dump trucks to dump over chambers.	See Table 2 for Maximum Construction Loads	
			Dozers to push parallel to rows. ⁴	Roller travel parallel to rows only until 36" (900 mm) compacted cover is reached.
Ⓒ Initial Fill Material	Excavator positioned off bed recommended. Small excavator allowed over chambers. Small dozer allowed.	Asphalt can be dumped into paver when compacted pavement subbase reaches 24" (600 mm) above top of chambers.	See Table 2 for Maximum Construction Loads	
			Small LGP track dozers & skid loaders allowed to grade cover stone with at least 12" (300 mm) stone under tracks at all times. Equipment must push parallel to rows at all times.	Use dynamic force of roller only after compacted fill depth reaches 24" (600 mm) over chambers. Roller travel parallel to chamber rows only.
Ⓕ Embedment Stone	No equipment allowed on bare chambers. Use excavator or stone conveyor positioned off bed or on foundation stone to evenly fill around all chambers to at least the top of chambers.	No wheel loads allowed. Material must be placed outside the limits of the chamber bed.	See Table 2 for Maximum Construction Loads	
			No tracked equipment is allowed on chambers until a min. 12" (300 mm) cover stone is in place.	No rollers allowed.
Ⓐ Foundation Stone	No StormTech restrictions. Contractor responsible for any conditions or requirements by others relative to subgrade bearing capacity, dewatering or protection of subgrade.	See Table 2 for Maximum Construction Loads		
		No StormTech restrictions. Contractor responsible for any conditions or requirements by others relative to subgrade bearing capacity, dewatering or protection of subgrade.		

StormTech® Standard Limited Warranty

STANDARD LIMITED WARRANTY OF STORMTECH LLC (“STORMTECH”): PRODUCTS

- (A) This Limited Warranty applies solely to the StormTech chambers and end plates manufactured by StormTech and sold to the original purchaser (the “Purchaser”). The chambers and end plates are collectively referred to as the “Products.”
- (B) The structural integrity of the Products, when installed strictly in accordance with StormTech’s written installation instructions at the time of installation, are warranted to the Purchaser against defective materials and workmanship for one (1) year from the date of purchase. Should a defect appear in the Limited Warranty period, the Purchaser shall provide StormTech with written notice of the alleged defect at StormTech’s corporate headquarters within ten (10) days of the discovery of the defect. The notice shall describe the alleged defect in reasonable detail. StormTech agrees to supply replacements for those Products determined by StormTech to be defective and covered by this Limited Warranty. The supply of replacement products is the sole remedy of the Purchaser for breaches of this Limited Warranty. StormTech’s liability specifically excludes the cost of removal and/or installation of the Products.
- (C) THIS LIMITED WARRANTY IS EXCLUSIVE. THERE ARE NO OTHER WARRANTIES WITH RESPECT TO THE PRODUCTS, INCLUDING NO IMPLIED WARRANTIES OF MERCHANTABILITY OR OF FITNESS FOR A PARTICULAR PURPOSE.
- (D) This Limited Warranty only applies to the Products when the Products are installed in a single layer. UNDER NO CIRCUMSTANCES, SHALL THE PRODUCTS BE INSTALLED IN A MULTI-LAYER CONFIGURATION.
- (E) No representative of StormTech has the authority to change this Limited Warranty in any manner or to extend this Limited Warranty. This Limited Warranty does not apply to any person other than to the Purchaser.
- (F) Under no circumstances shall StormTech be liable to the Purchaser or to any third party for product liability claims; claims arising from the design, shipment, or installation of the Products, or the cost of other goods or services related to the purchase and installation of the Products. For this Limited Warranty to apply, the Products must be installed in accordance with all site conditions required by state and local codes; all other applicable laws; and StormTech’s written installation instructions.
- (G) THE LIMITED WARRANTY DOES NOT EXTEND TO INCIDENTAL, CONSEQUENTIAL, SPECIAL OR INDIRECT DAMAGES. STORMTECH SHALL NOT BE LIABLE FOR PENALTIES OR LIQUIDATED DAMAGES, INCLUDING LOSS OF PRODUCTION AND PROFITS; LABOR AND MATERIALS; OVERHEAD COSTS; OR OTHER LOSS OR EXPENSE INCURRED BY THE PURCHASER OR ANY THIRD PARTY. SPECIFICALLY EXCLUDED FROM LIMITED WARRANTY COVERAGE ARE DAMAGE TO THE PRODUCTS ARISING FROM ORDINARY WEAR AND TEAR; ALTERATION, ACCIDENT, MISUSE, ABUSE OR NEGLIGENCE; THE PRODUCTS BEING SUBJECTED TO VEHICLE TRAFFIC OR OTHER CONDITIONS WHICH ARE NOT PERMITTED BY STORMTECH’S WRITTEN SPECIFICATIONS OR INSTALLATION INSTRUCTIONS; FAILURE TO MAINTAIN THE MINIMUM GROUND COVERS SET FORTH IN THE INSTALLATION INSTRUCTIONS; THE PLACEMENT OF IMPROPER MATERIALS INTO THE PRODUCTS; FAILURE OF THE PRODUCTS DUE TO IMPROPER SITING OR IMPROPER SIZING; OR ANY OTHER EVENT NOT CAUSED BY STORMTECH. A PRODUCT ALSO IS EXCLUDED FROM LIMITED WARRANTY COVERAGE IF SUCH PRODUCT IS USED IN A PROJECT OR SYSTEM IN WHICH ANY GEOTEXTILE PRODUCTS OTHER THAN THOSE PROVIDED BY ADVANCED DRAINAGE SYSTEMS ARE USED. THIS LIMITED WARRANTY REPRESENTS STORMTECH’S SOLE LIABILITY TO THE PURCHASER FOR CLAIMS RELATED TO THE PRODUCTS, WHETHER THE CLAIM IS BASED UPON CONTRACT, TORT, OR OTHER LEGAL THEORY.



Drainage



Filtration



Separation

ADS 0601T/O NONWOVEN GEOTEXTILE SPECIFICATION

Scope

This specification describes ADS 0601T/O nonwoven geotextile.

Filter Fabric Requirements

ADS 0601T/O is an orange nonwoven geotextile composed of polypropylene fibers, which are formed into a stable network such that the fibers retain their relative position. ADS 0601T/O is inert to biological degradation and resists naturally encountered chemicals, alkali and acids. ADS 0601T/O conforms to the physical property values listed below:

Filter Fabric Properties

Property	Test Method	Unit	Typical Value ¹ MD	Typical Value ¹ CD
Grab Tensile Strength	ASTM D4632	lbs (N)	175 (779)	175 (779)
Grab Tensile Elongation	ASTM D4632	%	75	75
Trapezoid Tear Strength	ASTM D4533	lbs (N)	85 (378)	85 (378)
CBR Puncture Strength	ASTM D6241	lbs (N)	480 (2136)	480 (2136)
Permittivity	ASTM D4491	sec ⁻¹	1.5	1.5
Flow Rate	ASTM D4491	gal/min/ft ² (l/min/m ²)	105 (4278)	105 (4278)
UV Resistance (at 500 hours) ¹	ASTM D4355	% strength retained	80	80

Physical Properties

Property	Test Method	Unit	Typical Value ²
Weight	ASTM D5161	oz/yd ² (g/m ²)	6.5 (220)
Thickness	ASTM D5199	mils (mm)	65 (1.7)
Roll Dimensions (W x L)	-	ft (m)	15 x 300 (4.5 x 91)
Roll Area	-	yd ² (m ²)	500 (418)
Estimated Roll Weight	-	lb (kg)	220 (100)

¹ Modified, Minimum Test Value

² ASTM D4439 Standard Terminology for Geosynthetics: typical value, *n-for geosynthetics*, the mean value calculated from documented manufacturing quality control test results for a defined population obtained from one test method associated with on specific property.



Separation

ADS 315W WOVEN GEOTEXTILE SPECIFICATION

Scope

This specification describes ADS 315W woven geotextile.

Filter Fabric Requirements

ADS 315W is manufactured using high-tenacity polypropylene yarns that are woven to form a dimensionally stable network, which allows the yarns to maintain their relative position. ADS 315W resists ultraviolet deterioration, rotting and biological degradation and is inert to commonly encountered soil chemicals. ADS 315W conforms to the physical property values listed below:

Filter Fabric Properties


Property	Test Method	Unit	M.A.R.V. (Minimum Average Roll Value) ²
Tensile Strength (Grab)	ASTM D4632	lbs (N)	315 (1400)
Elongation	ASTM D4632	%	15
CBR Puncture	ASTM D6241	lbs (N)	900 (4005)
Puncture	ASTM D4833	lbs (N)	150 (667)
Mullen Burst	ASTM D3786	psi (kPa)	600 (4134)
Trapezoidal Tear	ASTM D4533	lbs (N)	120 (533)
UV Resistance (at 500 hours)	ASTM D4355	%	70
Apparent Opening Size (AOS)*	ASTM D4751	U.S. Sieve (mm)	40 (.425)
Permittivity	ASTM D4491	sec ⁻¹	.05
Water Flow Rate	ASTM D4491	gpm/ft ² (l/min/m ²)	4 (163)

* Maximum average roll value.

Packaging

Roll Dimensions (W x L) - ft. (m)	12.5 x 360/ 15 x 300 / 17.5 x 258 (3.81 x 109.8/ 4.57 x 91.5 / 5.33 x 78.6)
-----------------------------------	---

Isolator[®] Row PLUS O&M Manual



THE ISOLATOR® ROW PLUS

INTRODUCTION

An important component of any Stormwater Pollution Prevention Plan is inspection and maintenance. The StormTech Isolator Row PLUS is a technique to inexpensively enhance Total Suspended Solids (TSS) and Total Phosphorus (TP) removal with easy access for inspection and maintenance.

THE ISOLATOR ROW PLUS

The Isolator Row PLUS is a row of StormTech chambers, either SC-160, SC-310, SC-310-3, SC-740, DC-780, MC-3500 or MC-4500 models, that is surrounded with filter fabric and connected to a closely located manhole for easy access. The fabric-wrapped chambers provide for settling and filtration of sediment as storm water rises in the Isolator Row PLUS and ultimately passes through the filter fabric. The open bottom chambers and perforated sidewalls (SC-310, SC-310-3 and SC-740 models) allow storm water to flow both vertically and horizontally out of the chambers. Sediments are captured in the Isolator Row PLUS protecting the storage areas of the adjacent stone and chambers from sediment accumulation.

ADS geotextile fabric is placed between the stone and the Isolator Row PLUS chambers. The woven geotextile provides a media for stormwater filtration, a durable surface for maintenance, prevents scour of the underlying stone and remains intact during high pressure jetting. A non-woven fabric is placed over the chambers to provide a filter media for flows passing through the perforations in the sidewall of the chamber. The non-woven fabric is not required over the SC-160, DC-780, MC-3500 or MC-4500 models as these chambers do not have perforated side walls.

The Isolator Row PLUS is designed to capture the “first flush” runoff and offers the versatility to be sized on a volume basis or a flow-rate basis. An upstream manhole not only provides access to the Isolator Row PLUS but includes a high/low concept such that stormwater flow rates or volumes that exceed the capacity of the Isolator Row PLUS bypass through a manifold to the other chambers. This is achieved with either an elevated bypass manifold or a high-flow weir. This creates a differential between the Isolator Row PLUS row of chambers and the manifold to the rest of the system, thus allowing for settlement time in the Isolator Row PLUS. After Stormwater flows through the Isolator Row PLUS and into the rest of the StormTech chamber system it is either exfiltrated into the soils below or passed at a controlled rate through an outlet manifold and outlet control structure.

The Isolator Row FLAMP™ (patent pending) is a flared end ramp apparatus that is attached to the inlet pipe on the inside of the chamber end cap. The FLAMP provides a smooth transition from pipe invert to fabric bottom. It is configured to improve chamber function performance over time by enhancing outflow of solid debris that would otherwise collect at an end of the chamber. It also serves to improve the fluid and solid flow into the access pipe during maintenance and cleaning and to guide cleaning and inspection equipment back into the inlet pipe when complete.

The Isolator Row PLUS may be part of a treatment train system. The design of the treatment train and selection of pretreatment devices by the design engineer is often driven by regulatory requirements. Whether pretreatment is used or not, the Isolator Row PLUS is recommended by StormTech as an effective means to minimize maintenance requirements and maintenance costs.


Note: See the StormTech Design Manual for detailed information on designing inlets for a StormTech system, including the Isolator Row PLUS.



Looking down the Isolator Row PLUS from the manhole opening, ADS PLUS Fabric is shown between the chamber and stone base.



StormTech Isolator Row PLUS with Overflow Spillway (not to scale)





ISOLATOR ROW PLUS INSPECTION/MAINTENANCE

INSPECTION

The frequency of inspection and maintenance varies by location. A routine inspection schedule needs to be established for each individual location based upon site specific variables. The type of land use (i.e. industrial, commercial, residential), anticipated pollutant load, percent imperviousness, climate, etc. all play a critical role in determining the actual frequency of inspection and maintenance practices.

At a minimum, StormTech recommends annual inspections. Initially, the Isolator Row PLUS should be inspected every 6 months for the first year of operation. For subsequent years, the inspection should be adjusted based upon previous observation of sediment deposition.

The Isolator Row PLUS incorporates a combination of standard manhole(s) and strategically located inspection ports (as needed). The inspection ports allow for easy access to the system from the surface, eliminating the need to perform a confined space entry for inspection purposes.

If upon visual inspection it is found that sediment has accumulated, a stadia rod should be inserted to determine the depth of sediment. When the average depth of sediment exceeds 3 inches throughout the length of the Isolator Row PLUS, clean-out should be performed.


MAINTENANCE

The Isolator Row PLUS was designed to reduce the cost of periodic maintenance. By “isolating” sediments to just one row, costs are dramatically reduced by eliminating the need to clean out each row of the entire storage bed. If inspection indicates the potential need for maintenance, access is provided via a manhole(s) located on the end(s) of the row for cleanout. If entry into the manhole is required, please follow local and OSHA rules for a confined space entries.

Maintenance is accomplished with the JetVac process. The JetVac process utilizes a high pressure water nozzle to propel itself down the Isolator Row PLUS while scouring and suspending sediments. As the nozzle is retrieved, the captured pollutants are flushed back into the manhole for vacuuming. Most sewer and pipe maintenance companies have vacuum/JetVac combination vehicles. Selection of an appropriate JetVac nozzle will improve maintenance efficiency. Fixed nozzles designed for culverts or large diameter pipe cleaning are preferable. Rear facing jets with an effective spread of at least 45° are best. StormTech recommends a maximum nozzle pressure of 2000 psi be utilized during cleaning. Most JetVac reels have 400 feet of hose allowing maintenance of an Isolator Row PLUS up to 50 chambers long. **The JetVac process shall only be performed on StormTech Isolator Row PLUS that have ADS PLUS Fabric (as specified by StormTech) over their angular base stone.**

StormTech Isolator Row PLUS (not to scale)

Note: Non-woven fabric is only required over the inlet pipe connection into the end cap for SC-160LP, DC-780, MC-3500 and MC-4500 chamber models and is not required over the entire Isolator Row PLUS.



ISOLATOR ROW PLUS STEP BY STEP MAINTENANCE PROCEDURES

STEP 1

Inspect Isolator Row PLUS for sediment.

- A) Inspection ports (if present)
 - i. Remove lid from floor box frame
 - ii. Remove cap from inspection riser
 - iii. Using a flashlight and stadia rod, measure depth of sediment and record results on maintenance log.
 - iv. If sediment is at or above 3 inch depth, proceed to Step 2. If not, proceed to Step 3.
- B) All Isolator Row PLUS
 - i. Remove cover from manhole at upstream end of Isolator Row PLUS
 - ii. Using a flashlight, inspect down Isolator Row PLUS through outlet pipe
 1. Mirrors on poles or cameras may be used to avoid a confined space entry
 2. Follow OSHA regulations for confined space entry if entering manhole
 - iii. If sediment is at or above the lower row of sidewall holes (approximately 3 inches), proceed to Step 2. If not, proceed to Step 3.

STEP 2

Clean out Isolator Row PLUS using the JetVac process.


- A) A fixed floor cleaning nozzle with rear facing nozzle spread of 45 inches or more is preferable
- B) Apply multiple passes of JetVac until backflush water is clean
- C) Vacuum manhole sump as required

STEP 3

Replace all caps, lids and covers, record observations and actions.

STEP 4

Inspect & clean catch basins and manholes upstream of the StormTech system.





SAMPLE MAINTENANCE LOG

Date	Stadia Rod Readings		Sediment Depth (1)-(2)	Observations/Actions	Inspector
	Fixed point to chamber bottom (1)	Fixed point to top of sediment (2)			
3/15/11	6.3 ft	none		New installation. Fixed point is CI frame at grade	DJM
9/24/11		6.2	0.1 ft	Some grit felt	SM
6/20/13		5.8	0.5 ft	Mucky feel, debris visible in manhole and in Isolator Row PLUS, maintenance due	NV
7/7/13	6.3 ft		0	System jetted and vacuumed	DJM

APPENDIX F

Engineering Drawings

<u>Drawing Name</u>		<u>Drawing Number</u>
Cover Page	Land Use	DUN/621-00
General Servicing Plan	Overall Development	DUN/621-01
General Servicing Plan	West Portion of Site	DUN/621-01A
General Servicing Plan	Middle Portion of Site	DUN/621-01B
General Servicing Plan	South Portion of Site	DUN/621-01C
General Servicing Plan	East Portion of Site	DUN/621-01D1



KEY PLAN
NOT TO SCALE

LEGAL DESCRIPTION

PART OF LOTS 12 and 13, CONCESSION 1
 PART OF LOTS 11, 12 and 13,
 BROKEN FRONT CONCESSION
 WATER LOTS lying in front of LOTS 11 and 12,
 BROKEN FRONT CONCESSION
 AND PART OF THE ROAD ALLOWANCE BETWEEN
 BROKEN FRONT CONCESSION and CONCESSION 1
 CITY OF BELLEVILLE, THURLOW WARD
 COUNTY OF HASTINGS

OWNER

225718 ONTARIO INC.

DRAWING LIST

DRAWING NUMBER	DESCRIPTION
Dur/621-00	CONTRACT USE
Dur/621-01	GENERAL SERVING PLAN
Dur/621-01A	GENERAL DEVELOPMENT
Dur/621-01B	GENERAL SERVING PLAN
Dur/621-01C	GENERAL SERVING PLAN
Dur/621-01D	GENERAL SERVING PLAN
Dur/621-01E	GENERAL SERVING PLAN
Dur/621-01F	GENERAL SERVING PLAN
Dur/621-01G	GENERAL SERVING PLAN
Dur/621-01H	GENERAL SERVING PLAN
Dur/621-01I	GENERAL SERVING PLAN
Dur/621-01J	GENERAL SERVING PLAN
Dur/621-01K	GENERAL SERVING PLAN
Dur/621-01L	GENERAL SERVING PLAN
Dur/621-01M	GENERAL SERVING PLAN
Dur/621-01N	GENERAL SERVING PLAN
Dur/621-01O	GENERAL SERVING PLAN
Dur/621-01P	GENERAL SERVING PLAN
Dur/621-01Q	GENERAL SERVING PLAN
Dur/621-01R	GENERAL SERVING PLAN
Dur/621-01S	GENERAL SERVING PLAN
Dur/621-01T	GENERAL SERVING PLAN
Dur/621-01U	GENERAL SERVING PLAN
Dur/621-01V	GENERAL SERVING PLAN
Dur/621-01W	GENERAL SERVING PLAN
Dur/621-01X	GENERAL SERVING PLAN
Dur/621-01Y	GENERAL SERVING PLAN
Dur/621-01Z	GENERAL SERVING PLAN

REVISIONS

NO.	DATE	DESCRIPTION	BY	CHK'D BY
1	DEC. 20/23	REVISED SITE LAYOUT FROM ARCHITECT	S.S.	
2	DEC. 20/23	UNDERLAY 23-24-15 SITE LAYOUT FROM ARCHITECT	S.S.	
3	JAN. 8/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.S.	
4	JAN. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-17	S.S.	
5	DEC. 13/24	REVISED SITE LAYOUT FROM ARCHITECT 24-12-05	S.S.	

SCALE: 1/8"=1'-0"

DATE: 13/23

DESIGNED: S.S.

DRAWN: S.S.

CHECKED: S.S.


COMPUTER: S.S.

PROJECT: 621 Dundas St. E. 24-12-05.dwg

DATE	DESCRIPTION	BY	CHECKED BY
DEC. 13/24	REVISED SITE LAYOUT FROM ARCHITECT 24-02-05	S.D.S.	
JAN. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-17	S.D.S.	
JAN. 18/24	REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.	
DEC. 20/23	INTERLAY 23-02-15 SITE LAYOUT FROM ARCHITECT	S.D.S.	
NOV. 02/23	REVISED SITE LAYOUT FROM ARCHITECT	S.D.S.	


SCALE: 1/8"=1'-0"
 H1000
 A.H.V.
 S.D.S.
 22/02/22
 HUNDAS ST (621) Barrie (Private Property)
 H. VANDERMEER
 PROVINCE OF ONTARIO
 REGISTERED PROFESSIONAL ENGINEER
 No. 1372

GENERAL SERVING PLAN
 OVERALL DEVELOPMENT
 DRAWING DWP/621-01
 DRAWING: 621 Dundas St. E-24-02-05.dwg



ENLARGEMENT OF ENTRANCE
 SCALE 1:250

NO.	DATE	DESCRIPTION
01	NOV. 08/23	REVISED SITE LAYOUT FROM ARCHITECT
02	DEC. 20/23	REVISED SITE LAYOUT FROM ARCHITECT
03	JAN. 08/24	REVISED SITE LAYOUT FROM ARCHITECT
04	JUN. 04/24	REVISED SITE LAYOUT FROM ARCHITECT
05	AUG. 08/24	REVISED SITE LAYOUT FROM ARCHITECT
06	SEP. 12/24	REVISED SITE LAYOUT FROM ARCHITECT



Boy of Quinte
 DRAWING KEY PLAN

- BENCH MARK**
- BM ELEV. 85.926
TOP NUT OF FIRE HYDRANT
EAST SIDE HAIG RD NORTH OF DUNDAS ST EAST
 - BM ELEV. 85.774
TOP NUT OF FIRE HYDRANT
SOUTH SIDE OF DUNDAS ST EAST SOUTH OF HAIG RD

NOTES
 SEE DRAWING ONE (E-D) FOR CONSTRUCTION NOTES AND DETAILS

LEGEND

DESCRIPTION	EXISTING	PROPOSED	AS-BUILT
EXISTING GROUND ELEVATION	(ELEV)	(ELEV)	(ELEV)
SWALE ELEVATION	(ELEV)	(ELEV)	(ELEV)
MAINTENANCE HOLE	○	○	○
CATCH BASIN	□	□	□
STORM SEWER	—	—	—
SAN. LATERAL c/w CLEAN-OUT	—	—	—
STORM RESIDENTIAL LATERAL	—	—	—
WATERMAIN APICAL DEFLECTION	—	—	—
WATER LATERAL c/w CURB STOP	—	—	—
GATE VALVE	○	○	○
BLOW OFF	○	○	○
FIRE HYDRANT	○	○	○
UTILITY POLE/LIGHT STANDARD	○	○	○
POLE MOUNT TRANSFORMER	○	○	○
STORM SEWER	—	—	—
BELL PEDESTAL	□	□	□
BELL GRADE LEVEL BOX	□	□	□
CABLE PEDestal	□	□	□
ELECTRICAL SERVICE	—	—	—
COMMUNITY MAIL BOX	□	□	□

*ALL UNCALLED BEST INDICATES EXISTING INFORMATION
 ALL UNCALLED BEST INDICATES AS-CONSTRUCTED INFORMATION*

SEDIMENTATION & EROSION CONTROL MEASURES

PRIOR TO REMOVAL OF TOPSOIL OR EARTH, SEDIMENT CONTROL FENCE SHALL BE INSTALLED PER STRAW BALE SILT DAMS ADJACENT TO ANY WORK AREAS AND STRAW BALE SILT DAMS SHALL BE INSTALLED PER THE FOLLOWING GUIDELINES ON EROSION & SEDIMENT CONTROL FOR URBAN CONSTRUCTION SITES MAY 1987.

STRAWBALE SILT FENCE SHALL BE CHECKED REGULARLY AND MAINTAINED ACCORDINGLY.

TOPSOIL TO BE STRIPPED AND STOCK PILED PRIOR TO EXCAVATION.

TOPSOIL STOCK PILE TO BE ENCLOSED IN STRAWBALE SILTATION FENCE.

ALL DISTURBED AREAS TO BE TOPSOILED AND SEEDED WITH NATIVE GRASS SPECIES AS SOON AS POSSIBLE.



STRAWBALE FILTERS TO BE PLACED 100m BELOW THE GRATES AS THEY ARE INSTALLED. EXISTING CONTRACTOR TO MAINTAIN AND CLEAN AS NECESSARY UNTIL CONSTRUCTION HAS BEEN COMPLETED.

STORM POND SHALL BE CONSTRUCTED WITH NATIVE MATERIAL.

BOTTOM OF POND TO BE TOPSOILED TO A DEPTH OF 100mm THROUGH OUT.

POND BERM TO BE HYDRO SEEDED IMMEDIATELY AFTER CONSTRUCTION IS COMPLETED.


PRIOR TO DECOMMISSIONING THE SILTATION FENCE AND SILT DAMS, ALL SILT SHALL BE COLLECTED AND REMOVED FROM THE SITE.



CANADIAN PACIFIC RAILWAY


VEGETATION SPREADER PILE

REVISIONS	DATE	DESCRIPTION	BY	CHK'D BY
REVISED SITE LAYOUT FROM ARCHITECT 24-12-06	1600	S.D.S.		
REVISED SITE LAYOUT FROM ARCHITECT 24-01-07	A.H.V.	DESIGNER		
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			
REVISED SITE LAYOUT FROM ARCHITECT 24-01-04	S.D.S.			



BENCH MARK

- BM ELEV. 85.926
 TOP NUT OF FIRE HYDRANT
 EAST SIDE HAIG RD NORTH OF DUNDAS ST EAST
- BM ELEV. 85.774
 TOP NUT OF FIRE HYDRANT
 SOUTH SIDE OF DUNDAS ST EAST SOUTH OF HAIG RD




SEDIMENTATION & EROSION CONTROL MEASURES

PRIOR TO REMOVAL OF TOPSOIL OR EARTH, SEDIMENT CONTROL FENCE SHALL BE INSTALLED PER O.P.S.D. 218.110. THIS INCLUDES ALL DOWNSTREAM SLOPES ADJACENT TO ANY WORK AREAS AND STRAIBLE FENCE CHECK DAMS ALONG ANY DRAINAGE PATH.

SEDIMENTATION FENCE SHALL BE CONSTRUCTED AS PER S.C.S.2 OF ONTARIO REG. 1016.01. SEDIMENTATION FENCE SHALL BE CONSTRUCTED AS PER S.C.S.2 OF ONTARIO REG. 1016.01. SEDIMENTATION FENCE SHALL BE CONSTRUCTED AS PER S.C.S.2 OF ONTARIO REG. 1016.01.

LEGEND

DESCRIPTION	EXISTING	PROPOSED	AS-BUILT
FINISHED GROUND ELEVATION	(ELEV)	(ELEV)	(ELEV)
SWALE ELEVATION	(ELEV)	(ELEV)	(ELEV)
MAINTENANCE HOLE	(MH)	(MH)	(MH)
DITCH INLET	(DI)	(DI)	(DI)
SAN. LATERAL c/w CLEAN-OUT	(SL)	(SL)	(SL)
STORM SEWER	(SS)	(SS)	(SS)
WATERMAIN	(WM)	(WM)	(WM)
WATERMAIN VERTICAL DEFLECTION	(VDF)	(VDF)	(VDF)
WATER LATERAL c/w CURB STOP	(WL)	(WL)	(WL)
GATE VALVE	(GV)	(GV)	(GV)
FIRE HYDRANT	(FH)	(FH)	(FH)
UTILITY POLE/LIGHT STANDARD	(UL)	(UL)	(UL)
POLE MOUNT TRANSFORMER	(PT)	(PT)	(PT)
STREETLIGHT PEDESTAL	(SL)	(SL)	(SL)
BELL PEDESTAL	(BP)	(BP)	(BP)
BELL GRADE LEVEL BOX	(BL)	(BL)	(BL)
ELECTRICAL SERVICE	(ES)	(ES)	(ES)
COMMUNITY MAIL BOX	(CM)	(CM)	(CM)



NOTES

SEE DETAIL DRAWING FOR CONSTRUCTION NOTES AND DETAILS

ALL ITALICIZED TEXT INDICATES EXISTING INFORMATION
 ALL UPPERCASE TEXT INDICATES AS CONSTRUCTED INFORMATION

